



Wellington Electricity 10 year Asset Management Plan

1 April 2018 - 31 March 2028

This page is intentionally blank

Wellington Electricity

10 Year Asset Management Plan

1 April 2018 – 31 March 2028

Any comments or suggestions regarding the Asset Management Plan can be made to:

General Manager – Asset Management

Wellington Electricity Lines Limited

PO Box 31049

Lower Hutt 5040

New Zealand

Phone +64 4 915 6100

Fax +64 4 915 6130

Email: WE_CustomerService@welectricity.co.nz

Web site: www.welectricity.co.nz



LIABILITY DISCLAIMER

Wellington Electricity Lines Limited (WELL) has prepared this Asset Management Plan (AMP) for public disclosure in accordance with the requirements of the Electricity Distribution Information Disclosure Determination, October 2012 (Consolidated in 2015).

Information, outcomes and statements in this version of the AMP are based on information available to WELL that was correct at the time of preparation. Some of this information may subsequently prove to be incorrect and some of the assumptions and forecasts made may prove inaccurate. In addition, with the passage of time, or with impacts from future events, circumstances may change and accordingly some of the information, outcomes and statements may need to change.

Neither WELL nor any other person involved in the preparation of this AMP will be liable, whether in contract, tort (including negligence), equity or otherwise, to compensate or indemnify any person for any loss, injury, or damage arising directly or indirectly from any person relying on this AMP, to the extent permitted by law.

Any person wishing to use any information contained in this AMP should seek and take expert advice in relation to their own circumstances and rely on their own judgement and advice.

Statement from the Chief Executive Officer

Wellington Electricity (WELL) welcomes the opportunity to submit an updated Asset Management Plan (AMP) for the period 2018 to 2028. We confirm that this AMP has been prepared in accordance with the Commerce Commission's *Electricity Distribution Information Disclosure Determination 2012* requirements.

Our operations over the last 12 months have continued to focus on delivering high levels of safety, reliability and service to our customers, while maintaining excellent performance from our network assets. We remain challenged to meet our quality targets for the 2017/18 year through events which neither represent a deterioration in supply nor reduction in our asset management practices. Having a marked increase in vehicles impacting assets and changes in risk management to meet new Health & Safety at Work legislation has a minor impact for a small number of our customers through reduced network availability in some areas.

Moving the business to a new location and re-establishing systems following the November 2016 earthquake provided an insight into how response and recovery is underpinned by readiness and preparedness. In conjunction with other lifelines utilities, WELL has submitted to the Commerce Commission an application to improve earthquake readiness for our Wellington businesses and community through a Streamlined Customised Price Path to improve response and recovery to an earthquake event. We appreciate the positive response the Commerce Commission and our community leaders have had to our application and look forward to a positive outcome from their final decision at the end of March. Our projected expenditure includes the SCPP expenditure for the next three years.

Health & Safety remains a positive driver for improved engagement with our field staff under an outsourced arrangement. Both businesses have continued development in this area with independent reviews acknowledging good standards and areas to focus for further improvement. Sharing these safety behaviours and standards with sub-contractors has improved safety performance, in particular with UFB and street lighting projects throughout the region.

Outcomes from the independent review from Strata following the 2011-2013 quality breach have been largely completed. We continue to encounter weather disruption as the climate changes towards a new equilibrium. However more targeted responses to areas being the worst affected is delivering improved performance results.

We continue to invest in the network assets where they require replacement or maintenance to meet the required asset performance standards. We continue to develop our maintenance management approach so that prioritisation occurs to target asset criticality. Our key focus is to ensure our expenditure efficiently meets providing a safe and reliable distribution system for our consumers. Further efficiencies are being developed around grouping these prioritised tasks with other work as part of a totex (total expenditure) approach to asset management. We continue to look for ways to leverage further effectiveness gains from our systems.

Strategically, the 2018 AMP introduces a section on emerging technology thought leadership where advantages can be gained by adopting trials and proof of concepts to enable better network performance. The 2018 Plan contemplates a trial of a trans-active platform where the LV network becomes visible in order to maintain quality standards for managing generation and storage across



the LV network environment. There are costs associated for implementing the systems to monitor and control the network at the LV level to enable new technology as a capacity solution rather than traditional network investment. Unlocking the benefits of new technology at the LV level for customers, retailers and network operators is an important step change in collaboration and co-operation for our sector.

The regional economy remains stable with low interest rates encouraging developers to look at subdivision of land for residential housing as house prices remain strong. Commercially there is a range of projects from new builds, to reinforcement, as well as deconstruction resulting from recent events playing out in the market.

In response to the Electricity Authority's request for greater cost reflectivity in network tariffs, our trial to shift EV charging demand proved successful with 87 EV owners participating. Incentivising charging behaviour, with the reward of lower network charges for plugging their vehicles in during less congested periods, is economically effective compared to the alternative of building new network capacity for a higher peak demand.

This is the first step on our Pricing Road Map to signal how these pricing changes will be phased in when supported by a change in control to a revenue cap in 2020. These changes will only become effective if the whole sector co-operates and co-ordinates their approach to engage retailers and customers in the benefits of price signals which reward customer behaviour to manage new load away from the network peak congestion period.

We have now completed reinforcement of 9 of the 27 buildings identified, from the 350 of our pre-1976 buildings evaluated, so these are no longer classified an earthquake risk. We have also remediated the two buildings which posed a public safety risk due to unreinforced masonry. The remaining 18 buildings will be completed along with the 91 identified in our CPP application.

WELL are also supporting larger cornerstone projects being developed through a lifeline utilities working group where utilities are supporting the top 5 initiatives that would secure both economic recovery and reduce social vulnerability. This targeted infrastructure investment allows communities to return to normal more quickly following a major disruption.

The GIS platform upgrade is now scheduled for 2018, largely due to the delays in completing the billing system upgrade which ran later than expected. The website upgrade continues to attract positive customer response especially the live reporting on restoration times when power outages occur. The OutageCheck App continues to be supported by customers wanting live updates on power restoration activities. This is a forerunner of our communications future with stakeholders on smart devices with information readily available to the public to make informed decisions. We will work closely with retailers on developing further engagement opportunities for customers to make informed choices for the future services they may value.

With these developments, WELL is comfortable that the expenditure allowances for the current period will meet the investment required in the network to deliver reliable services to customers at a quality which meets the expected regulatory quality targets. However we are at a cross roads where we need to provision a small additional allowance to test new technology and LV platform development to inform future network investment and lines function services as we move to a trans-active LV network future.



WELL continues to proactively engage with WorkSafe, the Commerce Commission and the Electricity Authority on improvements in safety performance, the price-quality path and market regulations so customers continue to receive the long term benefits from the sustainable investments made in electricity infrastructure. We also continue to provide a safe delivery system that has services and quality levels at price points welcomed by customers.

Being a member of the CK Infrastructure/Power Assets Group allows WELL to access skills and knowledge from our other electricity distribution businesses around the world and have direct access to international best practice in asset management.

In conjunction with our service companies and in alignment with its business strategy, WELL will continue to focus on the development of asset management strategies in parallel with the short to long term planning for the network.

We welcome any comments or suggestions regarding this AMP.

Greg Skelton

Chief Executive Officer



Contents

	Statement from the Chief Executive Officer	4
	Contents	7
1	Executive Summary	10
1.1	Term covered by the AMP	10
1.2	Changes from the 2017 AMP	10
1.3	The Changing Environment	10
1.4	Trend in Energy Consumption	13
1.5	Service Levels	14
1.6	Network Expenditure	20
1.7	Capability to Deliver	24
2	Introduction	26
2.1	Purpose of the AMP	26
2.2	Structure of this Document	26
2.3	Formats used in this AMP	27
2.4	Investment Projections	28
3	Overview of WELL	30
3.1	Strategic Alignment of this Plan	30
3.2	Organisational Structure	31
3.3	Distribution Area	34
3.4	The Network	35
3.5	Regional Demand and Consumer Mix	44
3.6	WELL's Stakeholders	46
3.7	Operating Environment	49
4	Asset Management, Safety and Risk Frameworks	56
4.1	Asset Management Framework	56
4.2	The Investment Selection Process	58
4.3	Asset Management Delivery	61
4.4	Asset Management Documentation and Control	64
4.5	Asset Management Maturity Assessment Tool (AMMAT)	64
4.6	Quality, Safety and the Environment (QSE)	66
4.7	Risk Management	71
5	Service Levels	78
5.1	Safety Performance Service Levels	78
5.2	Asset Efficiency Service Levels	81
5.3	Customer Experience Service Levels	82
6	Reliability Performance	90
6.1	Reliability Measures	91
6.2	Industry Comparison	95
6.3	Reliability Performance in 2016/17 and 2017/18	96
6.4	Previous Exceedance of Quality Limits	97
6.5	Reliability Event Types and Controls	98
6.6	Worst Performing Feeder Programme	110
6.7	Reliability Contribution by Area	113

7	Asset Lifecycle Management	118
7.1	Asset Fleet Summary	118
7.2	Risk-Based Asset Lifecycle Planning	119
7.3	Asset Health Analysis	120
7.4	Maintenance Practices	122
7.5	Asset Maintenance and Renewal Programmes	123
7.6	Asset Replacement and Renewal Summary for 2018-2028	201
8	Network Development	208
8.1	Network Planning Policies and Standards	208
8.2	Demand Forecast 2018 to 2028	216
8.3	Overview of the Network Development and Reinforcement Plan (NDRP)	233
8.4	Southern Area NDRP	233
8.5	Northwestern Area NDRP	256
8.6	Northeastern Area NDRP	287
8.7	Customer Initiated Projects and Relocations	297
8.8	Summary of the Capital Expenditure Forecasts	299
9	Emerging Technology	302
9.1	WELL's Innovative Goals	305
9.2	Summary of Emerging Technology Investment Plan	331
10	Support Systems	334
10.1	WELL Information Systems	334
10.2	Identifying Asset Management Data Requirements	338
10.3	Data Quality	338
10.4	Information Systems Plan	340
10.5	Plant and Machinery Assets	340
10.6	Land and Building Assets	340
10.7	Non-Network Asset Expenditure Forecast	341
11	Resilience	344
11.1	WELL's Resilience Framework	344
11.2	Emergency Response and Contingency Planning	344
11.3	High Impact Low Probability (HILP) Events	348
11.4	Business as Usual Resilience Work	355
11.5	WELL's Earthquake Readiness SCPP Application	360
11.6	Future Resilience Work	364
12	Expenditure Summary	368
12.1	Capital Expenditure 2018-2028	368
12.2	Operational Expenditure 2018-2028	373
Appendix A	Assumptions	376
Appendix B	Update from 2017 Plan	380
Appendix C	Schedules	386
	Schedule 14a: Mandatory Explanatory Notes on Forecast Information	412
Appendix D	Summary of AMP Coverage of Information Disclosure Requirements	413
Appendix E	Glossary of Abbreviations	421
Appendix F	Single Line Diagram	426





Section 1
Executive Summary

1 Executive Summary

The purpose of this Asset Management Plan (AMP) is to communicate Wellington Electricity's (WELL's) approach for the safe, reliable, effective and responsible long-term management of the company's network assets. The AMP explains how electricity supply will be delivered at a quality and price expected by electricity consumers connected to the network.

1.1 Term covered by the AMP

This AMP covers the 10-year period commencing 1 April 2018 through to 31 March 2028. It was approved by WELL's Board of Directors on 29 March 2018.

1.2 Changes from the 2017 AMP

The main changes in this AMP are:

- A new chapter on Emerging Technologies has been added explaining the impact and response by WELL to changes;
- The inclusion of a new chapter on Resilience including works related to the Streamlined Customised Price Path (SCPP) application submitted in December 2017; and
- The reliability performance section of the AMP has been expanded.

For further progress on items since the 2017 AMP, an update is provided in Appendix B.

1.3 The Changing Environment

The environment in which WELL operates is changing. This includes the increased opportunity available from emerging technologies onto the network as consumer needs and technology costs change. These changes will increasingly impact on WELL's operations going forward and require ongoing revision of investment plans and business models to enable wider benefits. This AMP highlights some of the major foreseeable changes that are on the horizon and illustrates how WELL plans to position itself to manage these changes.

1.3.1 A New Field Services Agreement

Since 2011, Northpower Ltd has been WELL's primary field service provider responsible for fault response and maintenance. The current Field Services Agreement (FSA) with Northpower will expire at the end of 2018 and will be tendered out to deliver a robust open-market tested agreement. This process is underway with a new agreement for a field services provider scheduled to begin undertaking maintenance and fault response for WELL in 2019.

1.3.2 The Emerging Technology Market

This AMP is consistent with views of the Business New Zealand Energy Council who have highlighted three major themes for change in the energy industry being:

1. Digitalisation;
2. Decarbonisation; and
3. Decentralisation.



These changes will have an effect on WELL as new technologies start to gain in their adoption rate with consumers. There is a risk that uncontrolled usage of these technologies will cause large changes to traditional demand profiles. This may lead to large network reinforcement requirements to ensure that the network is capable to deliver on these demands.

WELL's response to these challenges will set it on a potential transformation path to becoming a Distribution System Operator (DSO), a utility business designed to service distributed energy resources through a smart network.

The CK Infrastructure Group, of which WELL is a part, has established a strong global presence with investments in the electrical sectors of countries throughout the world. Having the support and backing of such an organisation, provides WELL with access to a large amount of intellectual property and resources across the electrical services industry internationally.

WELL is part of a colloquium of electrical sector companies within the CK Infrastructure Group which meets formally via teleconference every six weeks to discuss the latest developments in new technologies from around the globe. In addition, WELL has engaged with local Electricity Distribution Businesses (EDB's) to draw on New Zealand specific experience within the emerging technologies market. This is discussed further in Section 9.

1.3.2.1 The Risk on Future Asset Recoveries

The Regulatory Working Group (RWG) of the Electricity Networks Association (ENA) has been looking into the risks of future partial asset recoveries brought about by consumers making less use of the distribution network or by going off-grid all together. The RWG has acknowledged the fact that in future other parties may be in a position to provide network alternative solutions to consumers. The Commerce Commission (the Commission) has endorsed a mitigation option for these risks for those EDBs who may be affected, subject to price control. EDBs may now apply for accelerated depreciation recovery (allowing for up to 15% reduction asset lives), subject to the Commission's approval prior to the next regulatory period.

WELL acknowledges that the electricity landscape is changing in New Zealand, with technological advances providing more choice for consumers. WELL also acknowledges that these technologies may create opportunities and challenges for distribution networks in the near future.

Although the risks posed by new technologies may lead to underutilisation of assets for some EDB's requiring them to seek accelerated capital recoveries; WELL is of the opinion that this will generally not be the case in the Wellington region. There may be only small portions of the network where underutilisation may be a risk to capital recoveries over the lifetime of assets, rather than for the majority of the network. WELL's approach to move towards becoming a DSO, providing consumers with a platform to manage emerging technologies, will mean that the risk to potential underutilisation of assets will be managed and controlled. By providing consumers with options which could enable dual transfer of energy WELL aims to encourage consumers not to move off-grid.

This is considered a more prudent solution for consumers in the Wellington region rather than applying for accelerated depreciation recoveries as it allows WELL to be an enabler of new technologies for the benefit of consumers that seek to employ them.



1.3.3 The Focus on Resiliency Efforts

WELL regularly assesses the potential damage to the network should a major event such as a significant earthquake occur.

After the earthquake of November 2016, the government asked key infrastructure providers what could be done to improve the region's readiness to respond to a second significant earthquake, based on the earthquake series experienced in Christchurch (2010-11). The initial list produced by WELL has been expanded into a targeted SCPP application¹. The investigation and analysis of the SCPP have been summarised into a business case requesting allowance for expenditure of \$31.24 million over the next three years. The business case is premised on the wide-ranging impacts of such a significant event as summarised below:

- Electricity is an essential service for the community and losing supply for a prolonged period of time would have a devastating impact on people's quality of life. At a most basic level, access to fresh water, lighting, cooking, refrigeration, heating and communication would be seriously compromised without electricity.
- Wellington's electricity network, although strong in the face of the region's challenging weather with underground cabling, is especially vulnerable to damage from a major earthquake. The many fault lines that run across the region mean that the high proportion of assets which are located underground become difficult to manage following strong ground shaking events.
- In the event of a major earthquake, there is a very real risk that the region will be cut off from the rest of the country with transport links severed. The limited access into, out of and within the region will prevent the provision of outside assistance, including people and equipment to repair damage to our network, for many weeks. This also impacts Wellingtonians being unable to move away from the area. In this situation recovery at home will be required, making prompt return of electricity and other services very important for residents and businesses.
- The city's critical infrastructure services including Wellington airport, the Beehive disaster response bunker, several hospitals, telecommunication exchanges, water pumping stations, fuel storage and supply hubs, and emergency services headquarters all require electricity to function. Whilst many of these have emergency back-up generation, there could be a limit to fuel availability so WELL will need to be sufficiently prepared to return these businesses to operational status with the provision of a safe supply of electricity as soon as practical.
- These potential outages have been estimated to last as long as 100 days and could incur social and economic costs in the order of billions of dollars.

WELL's longer term resiliency planning is also continuing in parallel to the SCPP application as part of the work undertaken with the Wellington Lifelines Group. This includes the evaluation of solutions with Transpower on the options to manage the single point of supply risk of the Transpower Central Park grid exit point in Brooklyn.

¹ Full details of all documents related to the WELL SCPP can be found on the WELL website at: <https://welectricity.co.nz/disclosures/customised-price-path/>



1.3.4 The Health and Safety Work Act 2015 (HSW Act 2015)

The HSW Act 2015 introduced significant reform in workplace health and safety. This reinforced the ongoing requirement for due diligence and governance from Board level down and across all parties involved in the supply chain. Under the HSW Act, there are clearer obligations for the Principal (e.g. WELL) to ensure that those contracted to do its work (e.g. Northpower, Treescape etc.), and their subcontractors are free from harm, and that risk is considered and controls adopted so that health and safety is well managed in the workplace. WELL supports the ongoing commitment to continual improvement and working closely with contractors to improve processes, systems and operating standards through consultation, coordination and cooperation within the supply chain.

In addition, the 2015 HSW Act has caused many EDB's, including WELL, to review their live versus de-energised work policies and procedures. This has resulted in a material impact to planned outages due to the increase in de-energised planned interruptions compared to the reference period. It is anticipated that this will add significant pressure on WELL's ability to meet quality targets, which were set during a period of lower levels of de-energised work and planned outages.

1.3.5 Unreinforced Masonry (URM) Buildings

On 28 February 2017, in response to the 2016 Kaikoura earthquake, the government introduced a new requirement for owners of certain unreinforced masonry (URM) buildings to secure street-facing parapets and facades. Owners of URM buildings were notified by the City Councils if they were required to secure the street-facing parapets and facades of their buildings within 12 months of the date of the notice. The parapets and facades must be secured within this time frame to reduce the risk of falling masonry. Due to the prioritisation previously carried out, which highlighted these types of building as having a high risk to public safety, the URM ruling has had very little effect on the WELL seismic strengthening programme already underway. Wellington City Council (WCC) advised WELL of two sites where URM required strengthening, these being the Newtown Substation and Tory Street Substation. As discussed in Section 11, these sites have since been resolved with URM strengthening completed.

1.3.6 Earthquake Damage to WELL Headquarters

On 14 November 2016, the Wellington region was affected by the Kaikoura earthquake with several buildings damaged and a number of other buildings remaining unoccupied. This included the WELL headquarters at 75 The Esplanade in Petone. While decisions were being made on whether it was practical to carry out repairs, WELL and its staff were relocated to the disaster recovery site at Haywards substation for approximately 3 months until more permanent arrangements could be made. In February 2017, the business moved to 85 The Esplanade, Petone where it continues its operations.

1.4 Trend in Energy Consumption

Since 2011, annual energy consumption in the Wellington region has fallen by an average rate of 1.1% per annum. Actual consumption on the network will be driven by seasonal temperature variations and the associated consumer response, the uptake of emerging technologies and the timing of one-off consumer-led developments. WELL has a winter peaking network, and a colder than usual winter or higher uptake of EVs would both be situations which increased energy consumption. Changes in consumption also depend on clear pricing signals to enable consumers to make informed decisions. This is in line with the Electricity

Authority's (the Authority) concerns about consumers not having clear price signals regarding the change in economics from the introduction of new technologies.

As part of the SSCP application, WELL will move to a revenue cap from 1 April 2018. This will address WELL's concerns over the Constant Price Revenue Growth model used under a Price Cap which has no compensating measure for declining volume situations as growth forecasts are always anticipated under this mechanism.

1.5 Service Levels

WELL continues to deliver services to consumers and other stakeholders within the region at one of the highest levels in the country. In accordance with WELL's mission and stakeholder feedback, four areas of service level measures have been established for the period covered by the AMP. These are:

- Safety Performance;
- Customer Experience;
- Reliability Performance; and
- Asset Efficiency.

1.5.1 Safety Performance

WELL has continued to build on its strong foundation, set by past health and safety performance. Continual improvement in managing health and safety is at the core of WELL's values and involves ongoing review of health and safety practices, systems and documentation.

WELL welcomed the change in Work Safe New Zealand legislation (HSW Act 2015) to continue to improve workplace safety and focus on effective identification and management of risks to protect the welfare of workers engaged in delivering services, as well as the safety of the public. Within this context of continuous improvement, four primary measures have been adopted:

- Incident and near miss reporting;
- Corrective actions from site visits;
- Lost Time Injury Frequency Rate (LTIFR); and
- Total Notifiable Event Frequency Rate (TNEFR).

Planning Period Targets and Initiatives

WELL's targets for the 10-year planning period are to:

- Report on at least 300 near misses per annum;
- Maintain site visit assessments at 600 per year while continually reducing resulting actions; and
- Achieve a zero LTIFR and TNEFR over the whole period.

1.5.2 Customer Experience

It is important that WELL balances services that customers require, and what value they place on these now and into the future. WELL has used the insights received from customer engagement to test the service levels provided and to inform investment plans for the planning period.

In addition to good reliability and appropriate prices, customers increasingly expect good, timely information on their service and its status. Most customers accept occasional power cuts and the ability to keep them



informed when these events occur is most important. Ensuring good customer service and reliable, effective information flow is therefore a priority. To continue providing effective information to customers, WELL sets and tracks a set of performance targets for the contact centre.

1.5.2.1 Customer Engagement

WELL continues to engage with customers via the various initiatives that it undertakes in terms of trialling emerging technologies such as the electric vehicle (EV) charging trial to be undertaken in 2018. There is also collaborative work being undertaken in a similar technology space with a retailer trialling the use of domestic photovoltaics (PVs) and batteries within the region.

Larger consumers have been consulted as part of the SCPP application for readiness expenditure with support being given by members of all three City Councils, the Greater Wellington Regional Council, the Wellington Lifelines Group and the Wellington Chamber of Commerce amongst others.

Some statements received regarding the SCPP application were:

“We see ourselves as partners in this effort and fully support your proposal...” (Upper Hutt City Council)


“WCC is pleased to provide a letter of support for WELL’s application...” (WCC)

“Based on our own work we think customers across Wellington will be very supportive of your proposal...” (Wellington Water)


“We have a responsibility to our customers and we see ourselves as partners with you in this effort. We support WELL’s ability to submit a streamlined customised price path....” (Genesis Energy)

“...we are supportive of measures, such as those proposed in your business case, that seek to improve our current position, so long as they are cost effective and appropriately balance the additional costs to consumers with the benefit received.” (Business NZ)

To understand the impact of outages on connected customers, WELL surveys those who have recently had an outage to understand whether the costs-quality service they receive is appropriately balanced. The results for two critical questions taken from the survey undertaken in 2017 are shown in Figure 1-1.



Would you be prepared to pay a bit more for your power if it meant fewer power cuts?



Would you be prepared to have slightly more power cuts if it meant your electricity bill was a bit lower?

Figure 1-1 Sample of 2017 Customer Survey Results

These results suggest that customers are broadly satisfied with their current level of reliability and the price for delivering that service. This view is supported by WELL's position (yellow diamond) in the low SAIDI / low price² quadrant of the following benchmarking analysis. The larger grey diamonds represent other similar electricity lines companies.




Figure 1-2 Quality – Price Comparison

WELL continues to operate a web-based outage application to provide information on the location and forecast restoration times for unplanned outages. The application has resulted in positive feedback from customers and a reduction in calls to the contact centre. Further work is planned for 2018 where enhancements to this outage application are expected to improve its usability.

WELL has two customer related performance measures. These are:

- Power restoration service level targets; and
- Contact Centre performance.

1.5.2.2 Power Restoration Service Level Targets

WELL's published 'Electricity Network Pricing Schedule' provides standard service levels for the restoration of power to three different categories of consumers: CBD/Industrial, Urban and Rural. These service levels

² WELL uses revenue per ICP as a proxy for price given the availability of data this information disclosure.



reflect previous feedback from WELL consumers and are agreed between WELL and all retailers. The targets for power restoration service levels remain consistent over the planning period 2018-2028 and are shown in Figure 1-3.

	CBD / Industrial	Urban	Rural
Maximum time to restore power	3 hours	3 hours	6 hours

Figure 1-3 Standard Power Restoration Service Level Targets 2018-2028

1.5.2.3 Contact Centre Performance

WELL has developed a set of key performance indicators (KPIs) that provide service level benchmarks for the Contact Centre (Telnet). The eight reported service level performance measures for the Contact Centre are summarised in Figure 1-4.

	Service Element	Measure	Target 2018 to 2028
A1	Overall service level	Average service level across all categories	>80%
A2	Call response	Average wait time across all categories	<20 seconds
A3	Missed calls	Total missed/abandoned calls across all categories	<4%
B1	Initial Outage Notification	Energy retailers notified and the WELL website updated within the time threshold	<5 minutes
B2	Ongoing Outage Updates	Regular outage status updates provided	every 30 minutes
B3	Estimated Time of Restoration (ETR) Accuracy	Accurate ETR provided within the time threshold from initial outage notification	<1.5 hours
B4	Ongoing ETR Updates	Regular status updates to prolonged outages provided within the time threshold	within 2 hours
B5	Restoration Notification	Energy retailers notified and the WELL website updated within the time threshold from the time of restoration	<5 minutes

Figure 1-4 Contact Centre Service Level Targets 2018-2028

1.5.3 Reliability Performance

Electricity is an essential service for the community; it is the lifeblood for society's welfare and essential to a thriving economy. Losing it for a prolonged period of time has a devastating impact on people's quality of life, particularly if they are unable to seek alternatives. Wellington's electricity network, although strong due to its underground cabling, can be vulnerable to damage from external events. Society depends on

continuity of power supply and it is quite hard to imagine life without it. While large disruptions can occur, and some interruption is expected, customers also reasonably expect to have supply returned without undue delay, as their welfare and the region's economy will quickly suffer if the power stays off.

For this reason, WELL is committed to providing customers with a reliable and secure electricity supply. WELL has consistently demonstrated this commitment by undertaking reliability improvement initiatives to further progress the performance of the network, some of which are highlighted below:

- The worst performing feeder improvement programme such as work undertaken to improve the quality of supply experienced for customers in the Akatarawa area supplied by Brown Owl 3 (discussed further in Section 6.5.2).
- Engagements with ultra-fast broadband (UFB) providers which have resulted in a significant reduction of third party fault events caused by the UFB programme (discussed further in Section 6.5.1.6).
- Work undertaken based on 2016/17 reliability performance to improve practices in vegetation management as well as greater engagement with tree owners which has resulted in markedly improved vegetation management performance (discussed further in Section 6.5.1.3).

WELL's network performance is among the best levels of electricity supply in the country. The regulatory regime that applies to WELL sets reliability caps and collars for each year from 2015/16 to 2019/20. The caps and collars are set using historical data at one standard deviation above and below the mean (target). The caps and collars are the maximum and minimum reliability outcomes for which a reward or penalty of \$95,091³ per SAIDI minute and \$6,308,301 per SAIFI unit apply if the company's performance is better than or below the target respectively. In addition, the Commission has retained a compliance test for reliability which is based on meeting the cap in the current year or both of the immediately preceding two years. The target, caps and collar for WELL up to 2020 are presented in Figure 1-5.

Regulatory Period 2016-2020	Annual SAIDI	Annual SAIFI
Target	35.44	0.547
Cap	40.63	0.625
Collar	30.24	0.468

Figure 1-5 WELL Annual Regulatory Reliability Targets and Limits

The SAIDI and SAIFI targets against the historical performance are shown in Figures 1-6 and 1-7. The 2017/18 year includes a forecast to account for the March 2018 month shown in dark blue. The forecasts in SAIDI and SAIFI include an account for the impact of the HSW Act 2015 on the additional amount of de-energised work being undertaken.

³ The rewards and penalties relate to WELL only and are calculated on an EDB by EDB basis.






Figure 1-6 WELL SAIDI Performance




Figure 1-7 WELL SAIFI Performance

The primary drivers for network performance in the 2017/18 regulatory year have been an increase in the number of faults due to third party vehicle contacts and an increase in the amount of de-energised work being undertaken. There was also a major storm which lasted for two consecutive days on 13 and 14 July

2017 which fell under the Major Event Day category. The performance of the overhead network year to date has been better than average, in part reflecting the benefit of the actions implemented following the Strata review of 2015/16 as well as other continual improvement initiatives.

Analysis of the main causes of the network performance and WELL's initiatives to respond in future years is provided in Section 6.

1.5.4 Asset Efficiency

The asset efficiency levels of WELL relate to the effectiveness of its fixed distribution assets⁴.

Figure 1-8 illustrates the levels of asset efficiency.

	Load factor %	Distribution transformer capacity utilisation %	Loss ratio %	Demand density kW/km	Volume density MWh/km	Connection point density ICP/km	Energy density kWh/ICP
Industry average ⁵	60.3	30.08	5.5	42	205.04	13.6	15,029
WELL	47.8	41.92	3.7	123	495	35	13,977
Levels 2017-2027	>50%	>40%	<5%	-	-	-	-

Figure 1-8 WELL Asset Efficiency Levels to 2028

1.6 Network Expenditure

WELL's investment profile for the period through to 2021 is consistent with the expenditure allowances expected to be included in the Commission's 2018 Customised Price-quality Path (CPP) decision. Beyond 2021 there is a shift expected in terms of expenditure allowances in order for WELL to attain an appropriate level of service to address the emergence of new technologies such as Distributed Generation (as indicated in Section 9). This is dependent on current assumptions including expected peak demand profiles. A short overview of the demand forecast is provided below followed by the expenditure forecasts.

1.6.1 Demand Forecast

The consumption of energy supplied through the network has declined at an average rate of 1.1% per annum from 2011 to 2018. For the fifth consecutive year however, the number of residential building consents issued in the Wellington region has risen, driven by the growth in apartments within the Wellington CBD and subdivision growth along the northern belt. Figure 1-9 shows the number of building

⁴ Values taken from the Pricewaterhouse Coopers (PwC) Electricity Line Business 2017 Information Disclosure Compendium.

⁵ Values as per the Pricewaterhouse Coopers (PwC) Electricity Line Business 2017 Information Disclosure Compendium.



consents issued for new houses and apartments over the last seven years, however this is expected to stabilise over time.




Figure 1-9 Number of Building Consents Issued in the Wellington Region

When considering peak demand from a network wide perspective, it is important to note that while step changes in peak demand occur at specific sites within the network, this is offset by declining peak demand in other parts. Hence the overall peak demand across the network is expected to increase by approximately 3% for the 10 year AMP planning horizon. Figure 1-10 illustrates the forecast peak demand (system maximum demand) for the last five years and the forecast for the next 10 years.




Figure 1-10 Network Historic and Forecast Demand



With the change in pricing methodology to adopt cost-reflective pricing where price periods signal more clearly peak demand reduction, new technology investments are more likely to augment the network ahead of the traditional investments.

The evolution of technology supported by different pricing plans and business models will incentivise consumer behaviour and technology choices which will help support decisions for efficient network investment. Therefore the investment profile in future years will continue to change as forecasts are updated.

1.6.2 Network Capital Expenditure

WELL separates the network capital expenditure forecast into five categories:

1. Asset Renewal - includes specific replacement projects identified in the fleet summaries and routine replacements that arise from condition assessment programmes. This is the largest component of the forecast and is driven largely by the replacement of a high quantity of assets such as poles, switchgear and 11 kV/400 kV substations.
2. Regulatory, Safety and Environment - includes expenditure that is not directly the result of asset health drivers, including supply projects targeting the worst performing feeders and the seismic building reinforcement programme as well as other SCPP readiness works (including the data centres⁶).
3. System Growth - driven by system development needs and is dependent on the timing and location of peak demand growth and other areas of growth on the network.
4. Relocation Capital – expenditure required to relocate assets primarily due to roading projects and where the cost is normally shared with NZTA.
5. Customer Connection – includes the costs to deliver customer requested capital projects, such as new subdivisions, customer substations or connections.

The network capital expenditure forecast is shown in Figure 1-11⁷.

⁶ For purposes of clarity, the non-network SCPP expenditure for the data centres have been included into the Regulatory, Safety and Environment category in this chart, but this has been separated out in the rest of the document and the Capex schedules.

⁷ The SCPP expenditure has been included into the Reliability, Safety and Environment Category.






Figure 1-11 Network Capital Expenditure Forecast

The variability of the forecast capital expenditure is driven mainly by System Growth projects required to accommodate localised peak demand growth, and variability in the larger 33 kV cable and power transformer replacement projects in the Asset Renewal category. The increased forecast for the first three years is due to the SPP expenditure and the increases shown in the latter years are due to the forecasted expenditure on emerging technologies. These are discussed in Sections 11 and 9 respectively.

1.6.3 Network Operational Expenditure

WELL separates network operational expenditure forecast into four categories:

1. Service Interruptions and Emergencies – includes work that is undertaken in response to faults or third party incidents, and includes equipment repairs following failure or damage.
2. Vegetation Management – covers planned and reactive vegetation work.
3. Routine and corrective maintenance and inspection. This comprises:
 - Preventative Maintenance works – includes routine inspections and maintenance, condition assessment and servicing work undertaken on the network. The results of planned inspections and maintenance drive corrective maintenance or renewal activities;
 - Corrective Maintenance works - includes work undertaken in response to defects raised from the planned inspection and maintenance activities; and
 - Value Added - covers customer services such as cable mark outs, stand over provisions for third party contractors, and provision of asset plans for the 'B4U Dig' programme, to prevent third party damage to underground assets.

4. Asset Replacement and Renewal - includes repairs and replacements that do not meet the requirements for capitalisation.

The network operational expenditure forecast is shown in Figure 1-12.




Figure 1-12 Network Operational Expenditure Forecast

The increase in 2017/18 Opex was due to the increased expenditure on vegetation management to address reliability concerns identified over the course of 2017, as discussed in Section 6. Other contributors to the Opex expenditure in 2017/18 have been an increase in the number of defect repairs completed, a programme to inspect customer owned poles as a public safety initiative and a high number of force majeure events.

1.7 Capability to Deliver

WELL has the organisational and external service provider structures in place required to implement this AMP. Where new business requirements exist beyond current practice, these will be assessed against the present business capability and, where necessary, further resources will be considered (whether financial, technical, or contractor resource) to achieve any new business requirements.

As WELL is part of the CK Infrastructure group of companies it has access to relevant skills and experience from across the world. This provides WELL with direct access to international best practice systems.

WELL's Board of Directors and senior management team have reviewed this AMP against the business strategy to ensure alignment with business capability and priorities.





Section 2

Introduction

2 Introduction

This Asset Management Plan (AMP) has been prepared in accordance with the Commerce Commission's (the Commission) Information Disclosure (ID) Determination, October 2012 (consolidated in 2015). It describes WELL's long-term investment plans for the planning period from 1 April 2018 to 31 March 2028.

The document was approved for disclosure by the WELL Board of Directors on 23 March 2018.

2.1 Purpose of the AMP

The purpose of this AMP is to:

- Be the primary document for communicating with stakeholders WELL's asset management practices and planning processes;
- Describe how stakeholder interests are considered and integrated into business planning processes to achieve an optimum balance between the levels of service, price / quality positions, and cost effective investment; and
- Illustrate the interaction between this AMP, WELL's mission "*to own and operate a sustainably profitable electricity distribution business which provides a safe, reliable, cost effective and high quality delivery system to our customers*", and its asset management objective to "*optimise the whole-of-life costs and the performance of the distribution assets to deliver a safe, cost effective, high quality service*".

The asset management practices and this AMP inform WELL's business planning processes including its annual Business Plan and Budget.

2.2 Structure of this Document

This AMP has been structured to allow stakeholders and other interested parties to understand WELL's business and the operational environment. The body of the AMP is structured into the following three categories:

- **Overview and Approach** which provides an overview of WELL and the approach taken to asset management;
- **Targets and Levels of Service** which provides an overview of the various safety, customer and reliability targets that WELL is measured against and the achieved performance against those service levels; and
- **10 Year Investment Plan** which describes WELL's assets, associated strategies and investment profile over the planning period to meet the defined service levels.

Figure 2-1 illustrates the structure of this AMP.






Figure 2-1 Structure of the 2018 AMP

2.3 Formats used in this AMP

The following formats are adopted in this AMP:

- Calendar years are referenced as the year e.g. 2018. WELL's planning and financial years are aligned with the calendar year;
- Regulatory years are from 1 April to 31 March and are referenced as 20xx/xx e.g. 2018/19;
- All asset data expressed in figures, tables, and graphs is at 30 September 2017 unless otherwise stated;
- ICP numbers are as at February 2018 and
- All asset quantities or lengths are quoted at the operating voltage rather than at the design voltage. For example, WELL has a number of 33 kV cables operating at 11 kV. The length of these cables is incorporated into the statistics for the 11 kV cable lengths and not the 33 kV cables.

2.4 Investment Projections

The investments described in this AMP underpin WELL's business plan. The expenditure and projects are continually reviewed as new information is incorporated and asset management practices are further refined and optimised. The development of asset management strategies is driven by:

- The need to provide a safe environment for staff, contractors and the public;
- The current understanding of the condition of the network assets and risk management;
- Assessment of load growth and network constraints;
- New and emerging technologies and their role in the future operations of WELL as a Distribution Network/ System Operator to meet changing consumer needs;
- The need to maintain a reliable supply to balance consumer requirements;
- Changes to business strategy driven by internal and external factors; and
- The impact of the regulatory regime.

Accordingly, investment projections within the next two to three years are relatively firm with plans towards the later part of the 10-year period subject to an increasing level of uncertainty.

The investment projections outlined in this AMP as part of the DPP allowances, also include the expenditure identified by WELL to improve its readiness and ability to respond to a major catastrophic event such as an earthquake. These projections form part of a streamlined CPP application that was submitted to the Commission in December 2017. These projections have been included into the Resilience works in Section 11 and the Schedules in Appendix A. Further forecasts have been included into the Section 11 for future works to further enhance the long term resilience of key network assets in preparation for a major catastrophe.

As described above, WELL's financial year and planning cycle are in calendar years. Therefore, project timings in this AMP are expressed in calendar years. However, consistent with information disclosure requirements, expenditure forecasts are based on the regulatory reporting period 1 April to 31 March. Financial values presented in this AMP are in constant price 2018 New Zealand dollars, except where otherwise stated.





Section 3

Overview of WELL

3 Overview of WELL

This section provides an overview of the WELL business, its mission and the how this translates to the asset management framework. It also describes WELL's corporate structure, governance, asset management accountabilities, the area supplied, description of the network, the stakeholders and the changes that are occurring within the wider operating environment that will impact on investment decisions over the short to medium term.

3.1 Strategic Alignment of this Plan

WELL's mission is:

“To own and operate a sustainably profitable electricity distribution business which provides a safe, reliable, cost effective and high quality delivery system to our customers.”

The mission sets the context for all strategic and business planning. To achieve its mission WELL's business and asset management practices and policies must:

- Provide a safe environment for staff, contractors and the public;
- Deliver high quality outcomes for consumers, accounting for the cost/quality trade-off; and
- Operate in the most commercially efficient manner possible within the current regulatory environment.

The mission and these core principles are reflected in WELL's Business Plan. The Business Plan is shaped by both the internal and external business environment and defines the company's actions and outcomes to meet its mission.

This AMP is supported by with WELL's asset fleet strategies and its network development plans and forecasts, and is used to inform its 2018 Business Plan. It also takes into account the interests of consumers, stakeholders, and the changing operating environment (as discussed further in Section 3.6). Figure 3-1 illustrates this flow from WELL's mission to the business plan to the AMP.




Figure 3-1 Interrelationship between WELL's Mission, the Business Plan, the Asset Management Framework and the AMP

The Asset Management Framework utilised by WELL is discussed further in Section 4.



3.2 Organisational Structure

3.2.1 Ownership

CK Infrastructure Limited (CKI) and Power Assets Holdings Limited (Power Assets) together own 100 per cent of WELL. Both shareholding companies are members of the CK Infrastructure Group of companies, which are listed on the Hong Kong Stock Exchange (HKEx).

The CK Infrastructure Group has established a strong global presence with investments in electricity sectors of countries throughout the world. Having the support and backing of such an organisation puts WELL in a strong position to leverage a large amount of intellectual property, resources and access to the latest developments in the electrical services industry.

WELL is part of a colloquium of electrical sector companies within the CK Infrastructure Group (such as Hong Kong Electric, CitiPower/ Powercor and UK Power networks⁸) which meets formally via videoconference every six weeks to discuss the latest developments in new technologies from around the globe.

Further information is available on WELL's website, www.welectricity.co.nz.

3.2.2 Corporate Governance

The WELL Board of Directors (the Board) is responsible for the overall governance of the business. Consolidated business reporting is provided to the Board which includes health and safety reports, capital and operational expenditure against budget, and reliability statistics against targets.

The Board reviews and approves each AMP as well as annual forecasts and budgets.

3.2.3 Executive and Company Organisation Structure

The business activities are overseen by the CEO of WELL. The operation of WELL's business activities involves three groups of companies: WELL, International Infrastructure Services Company (IISC), and other Service Providers that contract to WELL.

IISC is a separate infrastructure services company, part of the CK Infrastructure and Power Assets group, which provides business support services to WELL. IISC provides the in-house financial, regulatory, asset management and planning functions as well as management of service delivery functions.

Safety is supported by the Quality, Safety and Environment (QSE) team, reporting directly to the CEO. This ensures that safety and risk management remain a prime focus and play a central role in all of WELL's activities.

⁸ Further details of electrical sector sister companies that are part of the CK Industries family can be found on the CK Infrastructure website.

WELL operates an outsourced services model for its field services and contact centre operations. These external service providers are contracted directly with WELL, with day to day management of the outsourced contracts provided by IISC. The overall company organisation structure is shown in Figure 3-2.




Figure 3-2 WELL Organisation Structure

3.2.4 Financial Oversight, Capital Expenditure Evaluation and Review

WELL has a Delegated Financial Authorities (DFA) framework, authorised by the Board, which governs the specific approval limits for the various levels of staff within the business.

3.2.4.1 Major Project Financial Approval and Governance

The policies for Authorisation and Payment of Project Expenditure together with the individual DFAs, define the procedure for authorisation of WELL's capital expenditure.

Capital projects above \$400,000 are reviewed and approved by the Capital Investment Committee (CIC), a subcommittee of the Board, who review the project business case and approve the expenditure.

The scope of the CIC is to approve capital expenditure proposals and to ensure that both an appropriate level of diligence has been undertaken and that the investment is in line with WELL's strategic direction. The CIC can approve projects previously included in the budget or customer connection projects up to \$2 million; otherwise the CIC refers their review for Board approval.

3.2.5 Asset Management Accountability

The WELL CEO heads the Executive Management team to implement the company mission. The CEO is accountable to the Board for overall business performance and direction.

The General Manager – Asset Management is accountable for asset engineering, network planning, standards, project approvals, works prioritisation, works integration and the network control room. Responsibilities also include the management and introduction of new technology onto the network.

The General Manager – Service Delivery is accountable for delivery and project management of capital and maintenance works and the associated safety, quality and environmental performance of these works. Responsibilities also include the management of outsourced field services contracts.



The Chief Financial Officer is accountable for all indirect business support functions including finance, customer service, regulatory management, legal and property management, human resources and information technology support.

WELL's staff and its external service providers' personnel are competent to implement this AMP, with appropriate training programmes in place to ensure that competencies and capability remain current with good industry practice.

3.2.5.1 Asset Management Team

The asset management team responsibilities are separated into four areas: asset engineering, network planning, network control & operations and works integration. The responsibilities for each area are described in Figure 3-3.

Asset Management Teams	Asset Management Responsibilities
Asset Engineering	<ul style="list-style-type: none"> • Asset and network management • Condition based risk management • Approval of asset management projects, plans, and budgets • Quality performance management • Network policies and standards • Engineering support
Network Planning	<ul style="list-style-type: none"> • Network load forecasting • Strategic network development and reinforcement planning • Secondary system management • Introduction of new technology onto the network • Engineering support
Network Control Room	<ul style="list-style-type: none"> • Network operations and safety • Outage management • Fault response and management
Works Integration	<ul style="list-style-type: none"> • Development, prioritisation, and budget allocation of the 3-12 month combined capex and opex work plan • Analysis of asset data to inform decision making • WELL's thought leadership on core asset management applications

Figure 3-3 Asset Management Team Responsibilities

3.2.5.2 Service Delivery

The service delivery team responsibilities are separated into two areas: management of delivery of capital and maintenance works on the network, and management of the specialist contracts. The responsibilities for each area are described in Figure 3-4.

Service Delivery Team	Asset Management Responsibilities
Capital Works and Maintenance programme management	<ul style="list-style-type: none"> • Overview of the capital works plan and maintenance delivery • Programme management of field service activities • Project management of contestable works • Safety frameworks for project implementation
Contract Management	<ul style="list-style-type: none"> • Management of specialist contracts – Field Services Agreement, Vegetation Management, Chorus agreement, • Safety performance and corrective actions • Relationship management with stakeholders

Figure 3-4 Service Delivery Responsibilities

WELL outsources the majority of its field services tasks as well as its contact centre. Management of the field service provider contracts is the responsibility of the General Manager – Service Delivery. Management of the contact centre contract falls within the Chief Financial Officer's responsibilities.

The outsourced field operations and approved WELL service providers are summarised below, along with their contractual responsibilities:

- 24x7 fault dispatch and response, maintenance, capital works – Northpower;
- Contestable capital works – Northpower, Downer and Connetics;
- Vegetation management – Treescape; and
- Contact centre – Telnet.

The contracts with outsourced service providers are structured to align with WELL's asset management objectives and to support continuous improvement in the integrity of the asset data held in WELL's information systems.

The roles and service provided by the service providers are explained in further detail in Section 4.3 (Asset Management Delivery).

3.3 Distribution Area

WELL is an electricity distribution business (EDB) that provides infrastructure to support the distribution of electricity to approximately 167,000 consumers in its network area, represented by the yellow-shaded area in Figure 3-5. The area encompasses the Wellington Central Business District (CBD), the large urban residential areas of Wellington City, Porirua, Lower Hutt and Upper Hutt, interspersed with pockets of commercial and light industrial load, and the surrounding rural areas. The area has few large industrial and agricultural loads.

Each local authority in the area (Wellington, Porirua, Hutt and Upper Hutt City Councils) has different requirements relating to permitted activities for an electrical distribution business. For example, differences exist in relation to road corridor access and environmental compliance. In addition to the local authorities, the entire network area comes under the wider control of the Greater Wellington Regional Council.



Prior to deregulation, network development in the region was the responsibility of two separate organisations and consequently in many cases the equipment utilised and the network design standards differed between the two historic network areas. One historic area now supplies the Southern region of WELL's network. The other historic area has been split further into the Northwest and Northeast areas to reflect the natural geographical and electrical split between the areas.

Figure 3-5 shows the network split into these three areas for planning purposes: Southern, defined as the area supplied by Wilton, Central Park and Kaiwharawhara grid exit points (GXPs); Northwestern, defined as the area supplied by Takapu Road and Pauatahanui GXPs; and Northeastern, defined as the area supplied by Upper Hutt, Haywards, Melling and Gracefield GXPs. The network configuration for each of the three areas is described further in Section 3.4.



Figure 3-5 WELL Network Area

3.4 The Network

The total system length of WELL's network (excluding streetlight circuits and traction direct current (DC) cable) is 4,705 km, 63% of which is underground. The network is supplied from Transpower's national transmission grid through nine grid exit points (GXPs). Central Park, Haywards and Melling GXPs supply the network at both 33 kV and 11 kV, and Kaiwharawhara supplies at 11 kV only. The remaining GXPs (Gracefield, Pauatahanui, Takapu Rd, Upper Hutt and Wilton) all supply the network at 33 kV only.

The 33 kV sub transmission system distributes the supply from the Transpower GXPs to 27 zone substations at N-1⁹ security level. The 33 kV system is radial with each circuit supplying its own dedicated power transformer, with the exception of Tawa and Kenepuru where two circuits from Takapu Road are tee-ed to supply four transformers (two at each substation). All 33 kV circuits supplying zone substations in the Southern area are underground while those in the Northwestern and Northeastern areas are a combination of overhead and underground. The total length of the 33 kV system is 195 km, of which 138 km is underground. A single line diagram of the sub transmission network is included in Appendix F¹⁰.

The 27 zone substations incorporate 52 33/11 kV transformers. Each zone substation has a pair of transformers with one supply from each side of a Transpower bus where this is available. The exception to this is Plimmerton and Mana, which each have a single 33 kV supply to a single power transformer. However, the substations are connected by an 11 kV tie cable and as a result they operate as a single N-1 substation with a geographic separation of 1.5 km.

The zone substations in turn supply the 11 kV distribution system which distributes electricity directly to the larger consumers and to 4,344 distribution substations located in commercial buildings, industrial sites, kiosks, berm-side and on overhead poles. The total length of the 11 kV system is approximately 1,767 km, of which 66% is underground. 71% of the 11 kV feeders in the Wellington CBD¹¹ are operated in a closed ring configuration, with the remainder being radial feeders that provide interconnections between neighbouring rings or zone substations.

The majority of consumers are fed from the distribution substations via the low voltage (LV) distribution network. The total LV network length is approximately 2,754 km, of which 61% is underground. An additional 1,900 km of LV lines and cables are dedicated to providing street lighting services.

The Wellington city trolley bus network was historically supplied through WELL owned direct current (DC) assets. These assets were managed in accordance with a network connection and services agreement with NZ Bus Limited (the sole consumer that was supplied by these assets). On midnight of 31 October 2017, the DC supply contract for the Wellington city trolley bus network expired and the DC infrastructure was switched off, bringing an end to this era in Wellington. This has provided the opportunity for WELL to work with Wellington transport stakeholders to embrace newer technologies for public transport in the form of EV buses.

⁹ N-1 = Available capacity in the event of a single component failure. The majority of sites have redundant capacity by design in the form of a second backup component, i.e. two independent subtransmission circuits supply each zone substation with sufficient capacity for the total load at the zone substation.

¹⁰ Further information on the demarcation points between WELL and its stakeholders can be found in the WELL Distribution Code and on the WELL website.

¹¹ The CBD is defined as the commercial areas supplied by Frederick St, Nairn St, University, The Terrace, Moore St and Kaiwharawhara substations.





The Potential Future of Wellington’s Public Transport System

Each of WELL’s three network areas is described in further detail below.

3.4.1 Southern Area

The Southern Area network is supplied from the Central Park, Wilton, and Kaiwharawhara GXPs, which together supply Wellington City, the Eastern Suburbs and the CBD. Figure 3-6 illustrates the Southern Area sub transmission network configuration.




Figure 3-6 Wellington Southern Area Sub transmission Network

3.4.1.1 Central Park

Transpower's Central Park GXP comprises three 110/33 kV transformers - T5 (120 MVA), T3 and T4 (100 MVA units) - supplying their 33 kV indoor bus. There are also two Transpower-owned 33/11 kV (25 MVA) transformers supplying local service and an 11 kV point of supply.

Central Park is supplied at 110 kV by three overhead circuits from Wilton GXP. There is no 110 kV bus at the GXP, so an outage on one circuit will cause an outage on the transformer connected to that circuit.

Central Park GXP supplies seven WELL zone substations at Ira Street, Evans Bay, Hataitai, Palm Grove, Frederick Street, University, and The Terrace each via double circuit 33 kV underground cables. Central Park GXP also supplies the WELL Nairn Street switching station adjacent to Central Park at 11 kV via two underground duplex 11 kV circuits (four cables). The security of supply from Central Park has been identified as a risk and solutions are discussed in Section 11.

3.4.1.2 Wilton

Transpower's Wilton GXP comprises two 220/33 kV transformers (100 MVA units) operating in parallel, supplying their 33 kV indoor bus. Wilton supplies three WELL zone substations at Karori, Moore Street, and Waikowhai Street each via double circuit underground cables.

3.4.1.3 Kaiwharawhara

Kaiwharawhara is supplied by two 110 kV circuits from Wilton GXP, and has two 38 MVA 110/11 kV transformers in service. WELL takes 11 kV supply from Transpower's Kaiwharawhara GXP and distributes this via a WELL owned switchboard (with 14 feeders) located within the GXP.

Kaiwharawhara supplies load in the Thorndon area at the northern end of the Wellington CBD, and also light commercial and residential load around the Ngaio Gorge and Khandallah areas.



3.4.1.4 Southern Area Summary

Supply Point	Connection Voltage (kV)	Sustained Maximum Demand – 2017 (MVA)	Firm Capacity ¹² (MVA)	Energy Injection – 2017 (GWH)	ICP Count
Central Park 33 kV	33	152	228	696	40,413
Central Park 11 kV	11	25	30	95	6,756
Wilton 33 kV	33	52	106	208 ¹³	13,994
Kaiwharawhara 11 kV	11	30	41	151	5,794
Total				917	66,957

Figure 3-7 Summary of Southern Area GXPs

3.4.2 Northwestern Area

The Northwestern Area network is supplied from the Pauatahanui and Takapu Road GXPs, which supply Porirua City and the Tawa, Johnsonville, and Ngauranga areas of Wellington City. Figure 3-8 illustrates the Northwestern Area GXP and sub transmission network configuration.

¹² Firm Capacity is the n-1 transformer capacity.

¹³ This includes 233GWh injected by Mill Creek Generation




Figure 3-8 Wellington Northwestern Area Sub transmission Network

3.4.2.1 Pauatahanui

Transpower's Pauatahanui GXP comprises two parallel 110/33 kV transformers each nominally rated at 20 MVA. Pauatahanui GXP supplies Mana and Plimmerton zone substations each via a single 33 kV overhead circuit connection to each substation. The two zone substations have a dedicated 11 kV interconnection, providing a degree of redundancy when one of the 33 kV circuits is out of service.

3.4.2.2 Takapu Road

Transpower's Takapu Road GXP comprises two parallel 110/33 kV transformers nominally rated at 90 MVA each supplying their 33 kV indoor bus. Takapu Road GXP supplies six WELL zone substations at Waitangirua, Porirua, Tawa, Kenepuru, Ngauranga and Johnsonville each via double 33 kV circuits. These circuits leave the GXP as overhead lines across rural land and become underground lines at the urban boundary.



3.4.2.3 Northwestern Summary

Supply Point	Connection Voltage (kV)	Sustained Maximum Demand – 2017(MVA)	Firm Capacity (MVA)	Energy Injection – 2017 (GWH)	ICP Count
Pauatahanui 33 kV	33	19	24	66	6,705
Takapu Rd 33 kV	33	96	123	398	32,094
Total				464	38,799

Figure 3-9 Summary of Northwestern Area GXP's

3.4.3 Northeastern Area

The Northeastern Area network is supplied from the Upper Hutt, Haywards, Melling and Gracefield GXP's, which supply the Hutt Valley and the surrounding hills. Figure 3-10 illustrates the Northeastern Area sub transmission network configuration.




Figure 3-10 Wellington Northeastern Area Sub transmission Network

3.4.3.1 Upper Hutt

Transpower's Upper Hutt GXP comprises two parallel 110/33 kV transformers each nominally rated at 37 MVA supplying their 33 kV indoor bus. Upper Hutt GXP supplies Maidstone and Brown Owl zone substations each via double circuit 33 kV underground cables.

3.4.3.2 Haywards

Transpower's Haywards GXP has a single 110/11 kV transformer nominally rated at 20 MVA feeding an 11 kV switchboard and a single 110/33 kV transformer nominally rated at 20 MVA. A 5 MVA 33/11 kV transformer links the 33 kV and 11 kV switchboards. WELL takes supply to two 33 kV circuits that supply Trentham zone substation, and eight 11 kV feeders. Haywards is the only GXP that does not currently offer full N-1 security to WELL's connected assets. A plan has been developed in conjunction with Transpower to replace the supply transformers with three winding transformers to provide N-1 security in 2019. Security is currently provided by backfeeds in the WELL 11 kV network.

3.4.3.3 Melling

Transpower's Melling GXP comprises two parallel 110/33 kV transformers each nominally rated at 50 MVA supplying their 33 kV indoor bus. Melling supplies zone substations at Waterloo and Naenae via duplicated 33 kV underground circuits. Melling also includes a Transpower 11 kV switchboard fed by two parallel 110/11 kV transformers each nominally rated at 25 MVA, from which WELL takes supply to ten 11 kV feeders.

3.4.3.4 Gracefield

Transpower's Gracefield GXP comprises two parallel 110/33 kV transformers nominally rated at 85 MVA each supplying their 33 kV indoor bus. Gracefield GXP supplies four WELL zone substations at Seaview, Korokoro, Gracefield and Wainuiomata each via double 33 kV circuits. The line to Wainuiomata is overhead while underground cables supply the other substations. WELL's Gracefield zone substation is located on a separate site adjacent to the GXP with short 33 kV cable sections connecting the GXP to the zone substation.



3.4.3.5 Northeastern Summary

Supply Point	Connection Voltage (kV)	Sustained Maximum Demand – 2017 (MVA)	Firm Capacity (MVA)	Energy Injection – 2017 (GWH)	ICP Count
Gracefield 33 kV	33	62	89	277	16,254
Haywards 33 kV	33	15	20	61	5,413
Melling 33 kV	33	32	52	130	15,111
Upper Hutt 33 kV	33	31	37	126	10,902
Haywards 11 kV	11	19	20	68	6,749
Melling 11 kV	11	25	27	113	7,073
Total				775	61,502

Figure 3-11 Summary of Northeastern Area GXPs

3.4.4 Embedded Generation

There is a wide range of embedded generation connected to the network, including 969 installations of PV with 3,141 kVA capacity and a predicted cumulative net injection of less than 200 kVA. The largest embedded generation site is the 60 MW windfarm at Mill Creek which connects into WELL owned 33 kV circuits from Wilton. There are nine diesel generation sites with an installed capacity of 62.85 MVA, the largest being a 10 MVA installation at Wellington Hospital. The diesel generation serves as a mains fail backup and is not designed for back feed operation. Other embedded generation includes two sites with gas turbines that run on landfill gas, the Brooklyn wind turbine, and small scale hydroelectric generation stations commissioned at some Greater Wellington Regional Council water storage and pumping stations.

A summary of the embedded generation connected to WELL's network is given in Section 9.

3.4.5 Embedded Distribution Networks

Within the WELL network there are a number of embedded networks owned by others, which are typically apartment buildings, commercial buildings, or campuses such as retirement villages.

WELL generally provides a metered bulk supply point. The management of the assets within these networks, and the associated service levels, is not the responsibility of WELL and is excluded from this AMP. Future planning is important to ensure that WELL is in a position to react to changes in emerging technologies. The effect these changes may have on embedded networks as discussed in Section 9.

3.5 Regional Demand and Consumer Mix

In 2017/18 WELL's network is forecast to deliver 2,389 GWh to consumers around the region where the regional sustained maximum demand was 558 MW¹⁴. As illustrated in Figure 3-12, the volume of energy supplied through the network has declined at an average rate of 1.1% per annum from 2011 to 2018.

It should be noted that this trend of decline temporarily paused in 2015/16 with volumes increasing by 0.9% due to an unusually colder winter period. 2017/18 saw a wetter but warmer winter than 2016/17 with overall volumes still forecast to decline by 0.2%.




Figure 3-12 Sustained Maximum Demand and Energy Injected

As set out in Figure 3-13 the overall consumer mix on the Wellington network consists of approximately 90% residential connections.

¹⁴ Winter peak period in 2017/18 has passed

Consumer Type	ICP Count
Residential	149,811
Large Commercial	429
Medium Commercial	619
Small Commercial	15,069
Large Industrial	48
Small Industrial	188
Unmetered	824
Total	166,988

Figure 3-13 WELL's Consumer Mix as at January 2018

While the majority of consumers connected to the network are residential, a number of consumers have significant or strategically-important loads. These include:

- Parliament and government agencies;
- Hospitals, emergency services and civil defence;
- Council infrastructure such as water and wastewater pumping stations and street lighting;
- Major infrastructure providers such as NZTA, Wellington Airport and CentrePort;
- Large education institutions such as Victoria University, Massey University, Whitireia and Weltech;
- Network security sensitive consumers such as the stock exchange, Weta Digital, Datacom, and Department of Corrections.

The number and density of these consumers is atypical for a New Zealand distribution network. Therefore, the importance of WELL providing a reliable and resilient network is critical.

WELL's ten largest consumers (by annual consumption) are:

- Wellington City Council
- Hutt City Council
- Chorus
- Porirua City Council
- Foodstuffs
- New Zealand Transport Agency (NZTA)
- Progressive Enterprises
- Capital and Coast District Health Board
- Vodafone NZ
- Weta Digital

WELL's Customer Services Team is responsible for ensuring that the needs of retailers and consumers are met. Major consumers have specific needs which are managed on a case by case basis. This includes managing the impact of network outages and asset management priorities. Consumers who have significant electricity use, specific electricity requirements, or are suppliers of essential services are contacted prior to planned outages, as well as following any unplanned outages that impact their supply.

Consumers' interests are identified and incorporated into asset management decisions through a number of mechanisms. These are discussed further in Section 3.6.

3.6 WELL's Stakeholders

WELL has identified nine key stakeholder groups whose interests are considered in the approach taken to asset management and its outcomes for consumers. These stakeholder groups are:

- Consumers;
- Retailers;
- Regulators;
- Transpower;
- Central and local government;
- Industry organisations;
- Staff and contractors;
- Debt Capital Market Funders; and
- Shareholders.

The characteristics of these groups are described below including how their interests are identified, what their interests and expectations are and how these are accounted for in WELL's asset management processes. The resulting service levels sought by stakeholders, once their interests have been accounted for, are described in Section 5.

3.6.1 Stakeholder Groups

3.6.1.1 Consumers

Consumers' interests are identified through direct feedback and media enquiries. Their interests include the safety of the public, the reliability of the network, and the price they pay for that reliability. These interests are accounted for in the asset management practices through meeting the regulated quality targets, public safety and consumer engagement initiatives.

WELL continues to operate a web-based outage application to provide information on the location and forecast restoration times for unplanned outages. The application has resulted in positive feedback from customers and a reduction in calls to the Contact Centre. Further work is planned for 2018 where enhancements to this outage application are expected to improve the customer experience further.






Figure 3-14 WELL's Web-based Application

The WELL website is used to socialise safety related messages and provide consumers with network outage information. Over the course of 2017, development has occurred on the online channel to add more content in relation to public safety messages. This content will start to be made available over the course of 2018.

3.6.1.2 Retailers

Retailers (and directly connected large loads) are WELL's direct customers. They rely on the network to deliver energy which they sell to consumers. Retailers ask that WELL assists in providing innovative products and services to benefit their consumers and they expect to access a proposed load control market under a new Electricity Authority Default Distribution Agreement (DDA).

Customer supply quality interests are accounted for through meeting the quality targets and by achieving the customer service levels contained in WELL's Use of Network Agreement with retailers. WELL is working with the Electricity Authority, and other electricity market participants, in the development of more standardised Use of System Agreements or Default Distribution Agreements (DDA).

WELL consults with retailers prior to the implementation of changes to its line charge pricing structure to ensure that any proposed changes take note of retailer feedback. WELL is also currently undertaking collaborative work with a large retailer trialling the use of PV within the region.

3.6.1.3 Regulators

The main regulators for WELL are WorkSafe New Zealand, the Commerce Commission (the Commission) and the Electricity Authority (the Authority).

Work Safe New Zealand is interested in the continuing improvement in workplace safety and effective identification and management of risk to protect the welfare of workers. These interests are accounted for

in the asset management practices through a comprehensive set of health and safety, environmental, and quality policies and procedures. These include reporting requirements as well as the need to consult, cooperate and coordinate with person's conducting a business or undertaking (PCBU's). WELL has an audited Public Safety Management System (PSMS) that covers the management of assets installed in public areas to ensure that they do not pose a risk to public safety.

The Commission and the Authority are interested in ensuring that consumers achieve a supply of electricity at a fair price commensurate with an acceptable level of quality that provides long term benefits to consumers. These interests are accounted for in the asset management practices through planned compliance with reliability targets and price controls, compliance with legislation, engagement in regulatory development process and preparing information disclosures.

3.6.1.4 Transpower

Transpower's interests are identified through the Electricity Industry Participation Code, relationship meetings, direct business communications, annual planning documents, and grid notifications and warnings. Transpower is interested in sustainable revenue earnings from the allocation of connected and interconnected transmission assets, and require assurance that downstream connected distribution and generation will not unduly affect their assets. They have interests in the operation of national grid including rolling outage plans, automatic under frequency load shedding (AUFLS) and demand side management. These interests are accounted for in WELL's asset management practices through implementation of operational standards and procedures; appropriate investment in the network, and regular meetings.

3.6.1.5 Central and Local Government

Central and local government interests are identified through legislation, regulations, regular meetings, direct business communications, and working groups. In addition to being a significant consumer through street lighting, electrified public transport and water management, they are interested in compliance with legislative and regulatory obligations, appropriate lifelines obligations for emergency response and contingency planning to manage a significant civil defence event. These stakeholders want assurance that consumers receive a safe, reliable supply of electricity at a competitive price, no environmental impact from the operation of the network, and appropriate levels of investment in the network to allow for projected growth. These interests are accounted for in WELL's asset management practices through compliance with legislation, engagement and submissions as required, engagement in policy development processes, Emergency Response Plans, and Environmental Management Plans.

The Kaikoura earthquake in November 2016 caused significant disruption in the region and has highlighted the importance of having a resilient electricity network. WELL has had discussion with WCC regarding preliminary approval for the construction of temporary overhead lines along pre-planned routes in the event of a major earthquake resulting in significant cable damage within the network. This work is further described in Chapter 11 as part of the Readiness and Response SCPP application.

3.6.1.6 Industry Organisations

The interests of industry organisations such as Engineering New Zealand, Electricity Engineers Association and Electricity Networks Association are identified through regular contact at executive level, attendance at workshops, and involvement in working groups. Industry organisations expect that good industry practice is followed with a continuous improvement focus. These interests are accounted for in WELL's asset



management practices through training and development of competencies, and alignment of asset strategies with industry frameworks and practices.

3.6.1.7 Staff and Contractors

Staff and contractors' interests are identified through individual and team discussions, regular meetings, direct business communications, contractual agreements and staff culture surveys. They are primarily interested in a safe and enjoyable working environment, job satisfaction, fair reward for effort provided, mitigation of workplace hazards and work continuity. These interests are accounted for in the asset management practices through health and safety policies and initiatives, performance reviews, and forward planning of work.

3.6.1.8 Debt Capital Market Funders

WELL accesses Debt Capital Markets to provide funding support for the investments outlined in this AMP. Banks and investors (through private placement issues) have provided funding to date. Their interests are accounted for in WELL's asset management practices through capital and operational forecasts that enable WELL's risk profile to be understood, and by providing forward looking information.

3.6.1.9 Shareholders

Shareholder interests are identified through governance, Board meetings, Board mandates, the business plan and strategic objectives. Shareholders expect safety to be non-negotiable, a fair return for their investment, compliance with legislation, good working relationships with other key stakeholders through meaningful engagement, and effective management of the network and business. These interests are accounted for in the asset management practices through governance processes, compliance with legislation, service levels and meeting budget.

3.6.2 Managing Potential Conflicts between Stakeholder Interests

Conflicts in stakeholder interests are managed on a case-by-case basis by balancing risks and benefits. This will often involve consultation with the affected stakeholders and the development of innovative "win-win" approaches. However, safety is the priority when managing a potential conflict in stakeholder interests. WELL will not compromise the safety of the public, its staff or service providers.

WELL is a member of the Utility Disputes Limited (UDL) Scheme, which provides a dispute resolution process for resolving consumer complaints. WELL's Use of System Agreements provides a dispute resolution process for managing conflict with retailers.

3.7 Operating Environment

WELL operates within the context of the wider New Zealand business environment and the global economy. This includes the financial, legislative and regulatory environments, and the need for the business to assess changes in technology.

3.7.1 Legislative and Regulatory Environment

WELL is subject to a range of legislative and regulatory obligations. WELL meets these regulatory and legislative obligations by adopting best practice asset management policies and procedures that underpin this AMP. WELL regularly engages with the Authority and the Commission through participation in working

groups, conferences, workshops, submissions on various matters, and regular information disclosures. The legislative and regulatory obligations are detailed below.

3.7.1.1 Health and Safety at Work Act 2015 (HSW Act 2015)

Building on its good safety and environmental record, and consistent with the requirements of the HSW Act 2015 as well as the company's drive for continual improvement, WELL continues to focus on potential safety and environmental risk at the early stages of a project. Rigorous risk assessments are conducted with contractors prior to the project being awarded, with continual monitoring throughout the project lifecycle of potential changes in risk. The cost and time implications of this increased focus are factored into project budgets and schedules.

The main changes introduced by the HSW Act 2015 that form the primary focus for WELL are:

- The concept of the 'person conducting a business or undertaking' (PCBU), including the duty of officers;
- Consultation, cooperation and coordination between PCBUs;
- Extension of hazard management to incorporate risk management at worker level; and
- Worker engagement, participation and representation.

The need to consult, cooperate and coordinate between PCBUs has continued to see improvements in 2017 of the management of the interface boundary with all Principal's that do work with WELL.

A compliance management system has been implemented by WELL that supports business processes relevant to the HSW Act 2015 as well as the NZS 7901 Public Safety Management obligations and timeframes that are reported quarterly to the Board.

3.7.1.2 Price Quality Compliance

WELL is subject to price and quality control contained within Part 4 of the Commerce Act 1986. WELL's maximum weighted average price cap for providing regulated lines services is set out in the 2014 Determination and applies for the regulatory control period from 1 April 2015 to 31 March 2020. WELL must also supply electricity based on the two quality level targets set by the Commission.

3.7.1.3 Information Disclosure

WELL is subject to information disclosures on an annual basis as well as responses to other information requests. To ensure accurate preparation and reporting of information, the business processes and information systems are aligned to the Information Disclosure Determination 2012 to ensure that information is accurate and available in the prescribed form.

3.7.1.4 Model Use of System Agreement (MUoSA)

WELL supports consumers' right to choose how they participate in the load control market. Since 2012 the Authority has continued to indicate that at some point it would consider mandating a model or default agreement through regulation. This approach by the Authority has tended to hinder any negotiations with retailers as they have sought to wait until the Authority regulated the agreements.



The Authority's work to introduce a DDA to set the terms in which retailers and EDBs contract for the supply distribution services is ongoing. The Authority's update on the proposal was delayed during the course of 2017 and is now expected to be released over the course of 2018.

3.7.1.5 Pricing Roadmap

WELL has published a pricing roadmap that outlines the intended developments in distribution pricing over the next 3-5 years including the development of cost reflective pricing options to provide retailers and consumers with clear price signals to help reduce peak demand and prices which support the SSCP adoption. As per the Authority's requirement for EDB's, this has been updated in October 2017 with further updates expected in 2018.

3.7.1.6 Government Policy - Major Infrastructure projects

Major infrastructure projects driven by government policy have an impact upon WELL's network. Ultra-fast Broadband (UFB) is a positive initiative for New Zealand and the rollout is currently being undertaken in Wellington by the telecommunications infrastructure provider Chorus. The rollout is governed by an interface management plan, contained within a pole connection agreement, to meet the safety obligations between the two PCBUs. The NZTA Transmission Gully project is another major project requiring significant work to deviate WELL assets away from the road corridor and to provide new infrastructure to supply street lighting circuits.

3.7.1.7 Requirements Driven by Local Authorities

WELL must comply with local authority requirements. WELL monitors notified resource consent applications and proposed changes to district plans, providing comment and submissions when required.

3.7.1.8 The Electricity (Hazards from Trees) Regulations 2003 (Tree Regulations)

WELL manages vegetation around its network in accordance with the requirements of the Tree Regulations, as vegetation close to network assets has the potential to interfere with the reliable and safe supply of electricity. The Tree Regulations prescribe distances from electrical conductors within which vegetation must not encroach. WELL is required to advise tree owners of their obligations for the safe removal of vegetation. WELL has a Vegetation Management Agreement in place with an external service provider to manage vegetation around the network. WELL's vegetation management programme has resulted in a reduction in the number of tree related faults on the network.

3.7.2 The Changing Technology Environment

There continues to be much interest around smart grids and smart technologies and how these will impact transmission and distribution networks, metering, central generation and retail, as well as at consumer level with markets developing to deliver choices for homes and businesses.

The growth of new technologies in the energy storage and market trading environments have a significant effect on the development of smarter electrical networks, and the ability of WELL to influence energy consumption and energy trading. Greater visibility of energy transfer in the form of real time network monitoring and improved digitalised data is required to enable WELL to adequately manage this space. WELL currently continues to monitor evolving technology trends and the uptake of new technology that is likely to impact on the electricity sector. This includes (but is not limited to) monitoring the uptake of

commercial and residential solar panels (Photovoltaics or PVs), the increasing penetration of EVs in New Zealand's vehicle fleet, and the applicability and use of technology for network monitoring, design and operation. While the rate of uptake is uncertain, technology is likely to have an increasingly significant impact on consumer behaviour as EVs, PVs, and battery storage become more affordable.

As these new technologies become available and gain more penetration with consumers, WELL seeks to utilise its position as part of the CK Infrastructure Group to leverage new technology from other global players, to provide network alternatives to consumers. These options can then be made available for consideration for use in network development plans and asset renewals. The CK Infrastructure Group, of which WELL is a part, has established a strong global presence with investments in the electrical sectors of countries throughout the world. Having the support and backing of such an organisation, puts WELL in a strong position to have access to a large amount of intellectual property and resources which enables the attainment of the latest developments in the Electrical Services Industry from across the globe.

In addition, WELL collaborates with local EDB's to draw on the New Zealand specific experience within the emerging technologies market.

Furthermore, WELL is working on a domestic battery and PV trial in conjunction with a retailer to understand the impacts, benefits and commercial aspects of this technology. A further trial on the usage of EV chargers and the understanding of expected charging rates and profiles is being undertaken with voluntary consumers within the Wellington region.

The availability of affordable EVs has the potential to significantly alter electricity delivery and usage patterns. It is expected that the adoption rate of EVs in New Zealand will increase over the longer term based on:

- New Zealand's high level of renewable energy generation (over 80%) being an ideal match for EVs which are seen as an appealing option for environmentally and cost-conscious consumers;
- Constantly evolving energy storage systems, electric drives and charging technologies that will improve the efficiency and range of EVs; and
- EVs offering lower running costs than traditional internal combustion engines due to the higher cost of fossil fuels and the higher efficiency of energy conversion from battery storage.

Currently the uptake of PVs in Wellington is low compared with other regions but further increases in PV installations may drive investment changes going forward. To ensure consumers make informed choices around new technology, WELL has commenced a programme of price review to identify the best price signals and options that optimise the value delivered by the network for consumers.

Overall, the greatest benefits for consumers in Wellington are most likely to come from low cost off-peak charging of EVs based on developing appropriate pricing signals, in conjunction with retailers. This is likely to continue until battery storage becomes both affordable and effective to provide another option to help consumers enable a reduction in network peaks.

WELL supports the electrification of transport as a significant means of reducing carbon emissions. Following the expiration of the agreement to supply the electric trolley bus network, WELL is working with the regional and city councils on new technology opportunities to continue electric public transport services in Wellington.



By design, the WELL network already has a number of features which allow for “smart” network management including:

- Closed ring feeders with segmented differential protection to isolate faults while leaving healthy sections in service;
- Remote indication and control via SCADA at over 230 sites, which allows for network management from the WELL control room; and
- On demand load management via the existing ripple control system.

The development of these new technologies will require that WELL has access to, and is equipped to, manage the large amounts of information that will be available to enable the dual transfer of energy safely, reliably and cost effectively.

3.7.3 The Financial Environment

WELL’s financial performance is primarily determined by the regulatory price control set by the Commission under the DPP, and the cost of debt funding available from global debt capital markets.

WELL submitted to the Commission as part of its review of the Input Methodologies (IM) that a revenue cap approach, which mitigates the consumption forecasting uncertainty, is a more appropriate form of price control. This was in comparison to the price cap approach, which exposes both electricity distribution businesses and consumers to windfall gains and losses due to forecasting error.

Pleasingly the Commission announced in December 2016 that a revenue cap would be used for the DPP from 2020 and for Customised Price Path (CPP) applications immediately. This brings the New Zealand regulatory regime in line with Australia and the United Kingdom. WELL expects to transition onto a revenue cap from 1 April 2018 as part of the SCPP for readiness expenditure.

WELL is continuing to manage its financial performance in a prudent manner, ensuring expenditure is targeted at the highest priorities and maintaining the quality of supply under the DPP framework.

WELL continues to access global debt capital markets to ensure it has appropriate financing facilities available to meet the investment plans outlined in this AMP.

This page is intentionally blank





Section 4

Asset Management, Safety and Risk Frameworks

4 Asset Management, Safety and Risk Frameworks

This section describes WELL's asset management frameworks and risk management processes and governance. It also sets out WELL's approach to health, safety and quality. In summary the section covers:

- The asset management framework;
- The investment selection process;
- The asset management delivery process;
- Asset management documentation and control;
- The Asset Management Maturity Assessment Tool (AMMAT);
- Quality, safety and the environment (QSE); and
- Risk management.

4.1 Asset Management Framework

The asset management framework which WELL operates to is aligned with the company's vision, mission, corporate strategy and objectives and is reflected in this AMP. The framework reflects the principles of the international standard ISO 55000. The key components of the framework are the asset management policy, asset management strategy, asset fleet strategies, network development plan, support system plans, the investment plans and the delivery phase as shown in Figure 4-1.






Figure 4-1 Asset Management Framework

Each component of the Asset Management Framework is described below.

4.1.1 Asset Management Policy

The asset management policy establishes the formal authority for asset management within WELL.

It aligns with the company's mission to: "own and operate a sustainably profitable electricity distribution business which provides a safe, reliable, cost effective and high quality delivery system to our customers".

The scope of the policy covers all the assets owned and operated by WELL for the purposes of providing electricity distribution services.

The policy has the following objective:

*"that the business will **optimise** the **whole of life costs** and the **performance** of the distribution assets to deliver a **safe, cost effective, high quality service** to our **customers**."*

The policy also states that WELL's electricity network shall be designed, constructed, operated and maintained in a safe and efficient manner which:

- Has a strong safety focus regarding its employees, contractors and members of the public;
- Aligns with corporate objectives and plans;
- Is founded on customer service level expectations and engages stakeholders where appropriate on asset-related activities;
- Stays up to date with national and international asset management standards, trends and best practices;
- Complies with all applicable regulatory and statutory requirements;
- Aligns with the risk management framework;
- Assists with the development of staff capabilities and the engagement of external resources when required to continually improve asset management capability; and
- Provides a suitable long-term return on investment for shareholders.

4.1.2 Asset Management Strategy

The asset management strategy developed by WELL has been established to deliver the service levels described in Sections 5 and 6.

WELL divides its strategies into the following categories:

1. Fleet strategies focusing on operating, maintaining, replacing and disposal of existing network assets, associated with WELL's existing network infrastructure. These are discussed in Section 7;
2. Network development strategies dealing with the changing consumer demand, any new developments, and impact of emerging technologies. These are discussed in Section 8;
3. Emerging Technology strategies as discussed in Section 9;
4. Support System Strategies focusing on the upgrading, maintaining, and operating the IT support systems and other requirements for running WELL's business operations. These are discussed in Section 10; and
5. Resiliency strategy as discussed in Section 11.

4.2 The Investment Selection Process

The investment selection process has five generalised stages as illustrated in Figure 4-2.






Figure 4-2 Investment Selection Process

4.2.1 Need Identification

The identification of investment need arises from multiple sources. For example, fleet strategies for asset replacements arise from asset condition assessment and detailed health indices evaluation, whereas the need for network development expenditure comes from forecasting of peak load growth on the network and developers extending their subdivision or commercial investments.

4.2.1.1 Risk-based Approach

WELL takes a risk-based approach to need identification. Management of risk is fundamental to network development, asset maintenance, refurbishment and replacement programmes described in this AMP. Risks associated with network assets are managed:

- Proactively: Reducing the probability of asset failure through safety-by-design principles, meeting security of supply criteria standards, capital and maintenance work programmes, enhanced working practices and the development of fleet strategies. The development of these strategies includes root cause analysis from the growing database of asset failure information, and predicts future corrective maintenance expenditure over time to identify trends; and
- Reactively: Reducing the impact of a failure through business continuity planning and the development of an efficient fault response capability.

The risk of an asset failure is a combination of the likelihood of failure (largely determined by the condition of the asset) and the consequences of failure (determined by the magnitude of any supply interruptions, the repair or replacement time and the extent of any reduction in network operating security while the asset is being repaired). Assessment of this risk assists the process of deciding whether to phase out an asset through a planned replacement programme or allow it to continue in service, supported if necessary by additional inspection and preventative maintenance activity. The risks associated with each asset fleet and network area are discussed further in Sections 7, 8, 9, 10 and 11.

4.2.1.2 Prioritisation of Projects

The asset management plan represents the view for the next 10 years and is refined on an annual basis. Projects to be included in the expenditure programme for a year are subject to a top down review and prioritised in accordance with the sequence shown below.

- Safety benefits to the public and personnel;
- Non-discretionary projects;
- Quality of supply and stakeholder satisfaction;
- Risk to the network;
- Strategic benefit; and
- Commercial returns and investment recovery.

A subset of non-discretionary projects outside of the prioritisation process includes:

(i) HSE and Legal Compliance

WELL's top priority is to operate a safe and reliable network and thus projects needed to address safety concerns and/or meet legal requirements are given high priority.

(ii) Customer-initiated Projects

Provided WELL has received sufficient advanced notice, it will give appropriate priority to planning, designing and implementing projects required to meet the needs of commercial and industrial customers.

Under this approach, safety, legal compliance, the need to meet customer requirements, and risk mitigation are the critical elements that drive the inclusion of projects in the works programme.

4.2.2 Option Identification

Following need identification, various options are identified and considered to meet the investment need. These include:

- Non-network solutions such as demand-side-management or distributed generation (DG). These could include investment by the consumer in the case of residential/commercial solar PV (or other forms of DG), or by WELL in the case of grid-scale PV and/or battery storage;
- An extension or upgrade of the existing distribution network;
- Repair or refurbishment of existing distribution assets; and
- Replacement with new assets.

These investment needs are considered to ensure that overall service levels sought by stakeholders are achieved within allowances to balance the price/quality trade off. This is to align the reliability with cost the consumers pay over the long term.



4.2.3 Option Selection Process

The option selection process describes the way in which network investments are taken from a high level need through to a preferred investment option that in turn is supported by a business case or project recommendation. It includes consideration of a list of appropriate options, refinement of the list to a short list of practicable options followed by detailed analysis and selection of a preferred option. The Works Plan is the repository for all potential network investments for the year ahead and includes projects funded solely by WELL as well as other customer-funded projects. The Works Plan is consistent with the first year of the AMP. Changes to either plan are required as an input to the other plan (i.e. AMP changes that impact the order of work in the next 10 years will be factored into the next Works Plan prepared).

The process is as follows:

1. Outputs from the option identification process are developed into a project recommendation, justifying the need for investment and recommending the preferred option.
2. Approved recommendations are entered into the Works Plan and prioritised in terms of safety, budget, timelines and network criticality. Customer connection requests are also recorded in the Works Plan.
3. The Works Integration Group develops, prioritises and allocates budget for the annual Work Plan based on a totex approach which combines and integrates capex and opex requirements to gain efficiency and effectiveness from service provisions.
4. Following final prioritisation and budget confirmation, a list of projects for the following year (i.e. the Works Plan) is prepared for management approval and recommendation to the Board for approval as part of the annual budget.

4.2.4 Investment Approval

Investments are approved according to WELL's DFA structure. This was described in Section 3.

4.3 Asset Management Delivery

The Works Plan is the repository for all potential network investments for the year ahead. It is used as the final document for tracking all network capital projects to be delivered for the year. Once approved, the Works Plan is managed by the Service Delivery team, with progress reported to senior management for Board updates.

4.3.1 Field Delivery

WELL utilises an outsourcing model for the delivery of its field and construction work. The service providers used for the core field and network functions are:

- Fault response, maintenance, and minor capital works – Northpower;
- Contestable capital works – Northpower, Downer and Connetics;
- Vegetation management – Treescape; and
- Contact centre – Telnet.

All outsourced agreements are subject to WELL's health and safety policies and management plan. It is the responsibility of the GM – Service Delivery to ensure this and that all field based work is managed to deliver value to the business.

The services provided are described in further detail below.

Fault Response, Maintenance and Minor Capital Works - Northpower

Since 2011, Northpower Ltd has been WELL's primary field service provider responsible for fault response and maintenance. The current FSA with Northpower will expire at the end of 2018. A new FSA will be tendered out to deliver a robust open-market tested agreement.

The FSA delivers a number of strategic outcomes for WELL. It is structured to ensure alignment with WELL's asset management objectives and to improve the integrity of the asset data held in WELL's information systems. The FSA covers the following services:

- Fault management – 24/7 response for fault restoration;
- Preventative maintenance – asset inspection and condition monitoring including the capture and storage of asset condition data and reporting this information;
- Corrective maintenance – remedial maintenance on defective assets;
- Value added services – safety disconnects and reconnects, on site cable mark-outs, sub transmission standovers and provision of buried asset plans provided to third parties;
- Minor connection services and livening; and
- Management services – management of the low voltage network, network spares, updating of geographical information systems (GIS) and other supplementary services as required.

The FSA includes key result areas (KRAs) and performance targets that Northpower is required to meet, with incentives for high levels of achievement. The cost of work undertaken is based on commercially tendered unit rates. The FSA is managed with a series of monthly meetings to cover off key functional areas between WELL and Northpower.

Contestable Capital Works Projects (Northpower, Downer and Connetics)

Contestable capital works include:

- Customer initiated works – new connections, subdivisions and substations, undergrounding and relocations; and
- Network initiated works – asset replacement projects and cable/line reinforcements.

Contestable capital works projects are generally competitively tendered. They are delivered under either independent contractor agreements (ICA's) or the FSA if Northpower is the successful tenderer. These agreements outline the terms and performance requirements the work is to be completed under such as KPIs or KRAs, defects liability periods, and insurance and liability provisions to manage the exposure of WELL. The agreements have been updated to reflect the requirements of the HSW Act 2015. All contracts



are managed on an individual basis, and include structured reporting and close out processes including field auditing during the course of the works.

In some instances, low value works or in circumstances where only one supplier can provide the required service, projects are sole sourced. In the case of sole source supply, pricing is benchmarked against comparable market data. Under the project management framework, work scopes are defined and there are stringent controls in place for variations to fixed price work.

Vegetation Management (Treescape)

This outsourced contract with for vegetation management is in the process of being re-tendered. The contract provides for vegetation management as per the Tree Regulations, as well as improved landowner awareness of tree hazards.

Management of this contract is handled in a similar manner to the Northpower FSA with monthly meetings and performance incentives in place.

Contact Centre (Telnet)

The Contact Centre provides management of consumer and retailer service requests, outage notification to retailers and handling general enquiries. Management of this contract is the responsibility of the Chief Financial Officer.

4.4 Asset Management Documentation and Control

WELL has a range of documents relating to asset management. These documents include:

- High level policy documents – which define how the company will approach the management of its assets;
- Asset fleet strategies - asset maintenance, lifecycle management and renewal strategies for a range of asset groups, from sub transmission cables and power transformers to the various pole types and LV installations;
- Network development and reinforcement plans - providing a 15 year plan of forecasted load growth, potential constraints and strategies to mitigate in conjunction with asset renewal and reliability improvement programmes;
- Technical standards for procurement, construction, maintenance and operation of network assets;
- Network guidelines - provide directions and procedures on the construction, maintenance and operation of network assets and processes to achieve a desired outcome; and
- Network instructions - provide further instructions on the construction, maintenance and operation of network assets and processes.

All documents such as policies, standards and guidelines follow the structure of the Controlled Document Process adopted by WELL, with a formalised review and approval process for new and substantially revised documents. Intranets and extranets make the documents available to both internal users and external contractors and consultants. Generally, documents are intended to be reviewed every three years; however some documents, due to their nature or criticality to business function, are subject to more frequent reviews.

4.4.1 Controlled Document Process

Standards relating to network materials, construction (including standard drawings) and operations and maintenance standards are managed through the Controlled Document Process.

The Controlled Document Process ensures that new or altered documents are released to staff and contractors in a controlled manner. Contractors have access to the WELL extranet to obtain the latest copies of controlled documents. Policy documents are used internally within WELL to deliver strategy and as a guide to the development of standards, guidelines and network instructions. Where contractors are required to undertake certain tasks or follow procedures, these are provided to them in the form of a controlled document, either as a standard, guideline or network instruction.

4.5 Asset Management Maturity Assessment Tool (AMMAT)

The Asset Management Maturity Assessment Tool (AMMAT) is provided in Appendix C, with a final average score of 2.9 across the six categories. The graph in Figure 4-3, extracted from the AMMAT, gives a summary of the results. As indicated below, minor inconsistencies or gaps identified were in the areas of Asset Strategy and Delivery, and Documentation and Controls.






Figure 4-3 Summary of the AMMAT Assessment 2018

Development of areas beyond Maturity Level 3 for individual aspects of the AMMAT will be considered by WELL where the need is clear, cost effective and justifiable. Figure 4-4 shows the improvements made over the years to the AMMAT. The areas identified in the AMMAT to be lower than Maturity Level 3, and a brief description of the development strategy to get from the present maturity level to Level 3 is provided in Figure 4-5.




Figure 4-4 Yearly Improvements to the AMMAT

No	Function	Question	Maturity Level Comment	Development Strategy
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders?	WELL is developing detailed asset fleet strategies for all the main asset categories. A number of these have been developed, but more work is required to complete all. Development of these strategies takes into account the alignment with other appropriate organisational strategies and stakeholder needs.	Development of long-term asset fleet strategies for all remaining asset categories will continue during 2018.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	Lifecycle strategies have been developed and introduced for the five asset classes, but remains incomplete for all asset classes.	As per question 10 above, development of lifecycle asset fleet management strategies will continue during 2018.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	WELL is in the process of putting in place comprehensive, documented asset management plans that cover all life cycle activities, and are clearly aligned to asset management objectives and the asset management strategy.	As per question 10 above, development of lifecycle asset fleet management strategies will continue during 2018.
105	Audit	What has the organisation done to establish procedure(s) for the audit of its asset management system (process(es))?	WELL is establishing its audit procedures but they do not yet cover all the appropriate asset-related activities.	Extend audit regime to cover identified areas of the asset management process which are not presently covered.

Figure 4-5 Strategies for Improving Asset Management Maturity

4.6 Quality, Safety and the Environment (QSE)

WELL is committed to providing excellence in QSE outcomes through application of the following principles:

- All employees and contractors undertake their work in a safe environment using safe work practices;
- Members of the public are not harmed by the operation, maintenance and improvement of WELL's assets;
- Controls are effective for minimising impacts to the environment;
- Processes are in place to ensure high quality outcomes are consistently achieved; and
- Continuous improvement is a key goal.

To support these principles, WELL maintains a comprehensive set of health and safety, environmental, and quality policies and procedures which, together with the wider business policies and standards, are regularly reviewed and updated.



In accordance with WELL's mission, health and safety is given top priority and is a core business value. A Board Health and Safety Committee meets quarterly to review issues requiring Board governance or guidance. As illustrated in Figure 4-6, a formalised Safety Leadership Structure is in place to help ensure that health and safety leadership is provided throughout the business.




Figure 4-6 WELL's Safety Leadership Structure

WELL holds a monthly Safety Leadership Committee (QSE Leadership Team) meeting to monitor performance, discuss emerging trends or new issues and progress on key improvement areas. The CEO and General Managers are part of the QSE Leadership team. WELL employees and contractors are required to manage their own and other people's safety by adhering to safe work practices, making appropriate use of plant and equipment (including protective clothing and equipment), promptly managing controls for assessed risks and reporting of incidents, near misses and hazard observations.

In a similar manner, quality and environmental outcomes are managed by WELL via consultation, co-operation and co-ordination, with employees and contractors who are required to:

- Take all reasonable steps to ensure that business activities provide an outcome, which minimises environmental impacts and promotes a sustainable environment for future generations; and
- Take all reasonable steps to ensure the delivery of goods, products and services are to an acceptable standard and meet the quality expectations of the business.

- Identify and report any defects or non-conformances to enable improvement in the systems or performance to maintain quality outcomes.

WELL's QSE outcomes and processes are discussed in more detail below. The associated performance objectives and measures are described in Section 5.

4.6.1 Regulatory Requirements

WorkSafe New Zealand (WorkSafe) is the work health and safety regulator.

Worksafe's functions include:

- Monitoring and enforcing compliance with work health and safety legislation;
- Providing guidance, advice and information on work health and safety; and
- Implementation of the Health and Safety at Work Act 2015.

The Health and Safety at Work Act 2015 (HSW Act 2015) came into effect on 04 April 2016. This repealed the previous legislation, the Health and Safety in Employment Act 1992. It's the key work health and safety law, and sets out the health and safety duties that must be complied with.

Consistent with the HSW Act 2015, WELL continues to develop closer relationships with other organisations and stakeholders where an interface with network assets exists. The HSW Act 2015 requires a greater level of consultation, co-operation and co-ordination in relation to health and safety duties and issues. This brings about a number of changes in the way WELL conducts its outsourced field activities. These changes include the ongoing requirement for due diligence and governance from Board level down and across all parties involved in the supply continuum. All personnel including contractors and volunteers become workers for the purposes of the HSW Act 2015. The fundamental obligation to protect workers, the public, and property from harm, remains the core consideration with effective planning and solid communication being paramount to safe and effective work management.

4.6.2 Public Safety Management Systems (PSMS)

WELL has a Public Safety Management System (PSMS) framework policy document, built on policies, procedures and guidelines relevant to the safe design and management of the assets. The PSMS includes assets that are installed in public areas and the management of these assets to ensure they do not pose a risk to public safety. The PSMS meets the compliance requirement for electricity distributors to implement and maintain a safety management system for public safety set out in Regulations 47 and 48 of the Electricity (Safety) Regulations 2010.

The PSMS also meets the requirements of NZS 7901:2008 Electricity and gas industries - Safety management systems for public safety. In 2016 the certification body Telarc reassessed WELL against the requirements of NZS 7901 and confirmed that WELL was compliant with regulatory requirements.

WELL continues to invest significant resources to raise awareness in the community of the potential risk of living and working near electricity assets.

WELL provides public safety information and advice on its website www.welectricity.co.nz. The purpose of the website is to help the community stay safe around electricity. It provides information on electrical



shocks, electrical fires, electromagnetic fields, appliance safety, power line safety and fault reporting details. The website also links to other safety sites and government safety agencies.

4.6.2.1 BePowerwise

BePowerwise is an initiative being developed by WELL to provide important information to the public relating to the electricity distribution network. A number of programmes are currently under development in this regard with the first programme on engagement around vegetation management to be released in 2018.

4.6.2.2 School Safety Programme

WELL runs an education programme for schools which educates children about electrical safety. The Stay Safe programme is aimed at primary school aged children and offered for delivery in schools around the Wellington region. The programme involves showing a DVD, an electrical safety discussion aided by visual props and the presentation of the “stay safe around electricity” workbook to each child. The workbook invites children to visit the *Electricity Safety World* website, which contains interactive safety games and information targeted at young children and parents regarding network safety and electrical safety around the home. There is also a link to the website in the School Safety Programme section of WELL’s website.

4.6.2.3 Media Advertising

WELL actively raises public awareness about the dangers of living and working around network assets. WELL undertakes radio safety campaigns which cover issues such as trees in proximity to overhead lines, cable identification and mark out, safety disconnects and advice on protecting sensitive appliances with surge protectors. Radio safety campaigns were conducted in 2017 relating to vegetation management, excavation safety and safety disconnections for maintenance around the home.

4.6.2.4 Safety Seminars and Mail Outs

In order to help prevent third party contact with the network, WELL works closely with civil contracting companies (third party contractors working around WELL assets) and other organisations that, through the nature of their work, need to get closer to the network than normally allowed. This may be in the form of a planning discussion or on-site safety seminars which raise awareness of safe working practices when working around the network and particularly when excavating in the vicinity of existing underground infrastructure.

From time to time WELL mails out letters to various contracting sectors focusing on infringements impacting safety around the network.

WELL also works with Energy Safety to ensure interactions with the network are conducted safely and investigated where appropriate.

4.6.2.5 Contractors’ Safety Booklet

WELL has produced a safety publication targeted at civil contractors and those working near, but not accessing, the WELL network. This booklet “WE* all need to work safely” is handed to those attending safety workshops and in mail outs to various contracting sectors that interface with the network.

4.6.2.6 Information and Value Add Services

WELL provides an information service to reduce the risk of public safety and incidences of damage to assets or property. The service is available through a 24 hour freephone number.

This includes services such as:

- Service Map requests
- Cable Locations
- Close Approach
- Standovers
- High Load Permits
- High Load Escorts

Since 2012 there has been a significant increase in calls relating to service map requests. The increase is attributed primarily to the commencement of the UFB rollout in the Wellington region.

The additional risk created by the extra work around WELL poles is being carefully managed in terms of the HSW Act 2015 by formal contractual conditions and consultation, co-operation and co-ordination between all parties involved in the UFB installation work.

4.6.3 Workplace Safety and Initiatives

WELL has the following workplace safety initiatives in place:

4.6.3.1 Staff Health and Safety Committee (H&S Committee)

The H&S Committee represents WELL's employees and meets bi-monthly to address issues raised by Workgroup Representatives or reported through WELL's Health and Safety Management System (1FiCS). The H&S Committee is made up of 10 volunteers and deals with concerns ranging from Emergency Preparedness & Response to faulty appliances that need repair or replacement.

4.6.3.2 Safety Breakfasts

WELL regularly arranges safety breakfasts for all its external contractors. The aim of these breakfasts is to highlight key safety messages and areas for improvement. The breakfasts are also used to publicly recognise and celebrate examples of good safety behaviour and practice. On average 300 people are catered for at these sessions.

4.6.3.3 Annual Worker Safety Workshop

WELL arranges a half day safety seminar for all its workers and closely associated PCBUs and their key workers on an annual basis. The aim of these seminars is to reinforce WELL's desired behaviours through direct interface with the WELL CEO, keynote speakers and other subject matter experts. In 2017 the safety seminars included:

- A presentation by the New Zealand Police Serious Crash Unit which was listed as one of the highlights of the workshop;



- A presentation by Sir Graham Henry on the key aspects introduced to the All Blacks leadership structure which stimulated a significant culture change and transformed the team into a high performance team striving for continual improvement;
- A presentation by a Northpower worker on his experiences in an organisation which had a series of serious harm incidents in a small rural community and how the lack of support post incident had personally affected him; and
- Presentation of contractor safety achievement awards to publicly recognise workers who demonstrate a positive approach to safety throughout the year.

4.6.3.4 Site Safety Visits

WELL ensures its directly employed workers undertake familiarisation visits to sites where contractors are working on the network. The Site Safety Visits are used to confirm understanding and implementation of corrective actions and to discuss safety systems and opportunities for improvement.

4.6.3.5 Workplace Safety Training and Competence

WELL operates a Work Type Competency (WTC) process which categorises different types of activities on the network and sets minimum requirements in terms of qualifications, knowledge and experience. All operational personnel working in the field are required to hold the appropriate competency authorisation for the work being conducted.

WELL ensures its personnel are trained and competent in safety matters through providing, for example:

- CPR / First Aid refresher sessions every six months;
- Restricted area access training;
- Defensive driving training for all employees who drive a company vehicle; and
- Basic Traffic Control management.

4.6.3.6 Incident Review Meetings

WELL holds weekly internal meetings and monthly meetings involving the outsourced service providers to review and address reported hazard observations, near misses and incidents. A key objective of these meetings is to prevent incidents occurring or recurring, and to use lessons learnt for continuous improvement.

4.6.3.7 Safety Alerts

When the need arises, WELL issues Safety Alerts to all its service providers highlighting a safety concern and listing any actions required to reduce the concern.

4.7 Risk Management

WELL aligns its risk approach with that of its parent company by adopting the *Enterprise Risk Management (ERM) – Integrated Framework Risk management – Principles and Guidelines* standard. This provides a structured and robust framework to managing risk, which is applied to all business activities, including

policy development and business planning. WELL's risk management framework is discussed in Section 4.7.2.

Risk management is an integral part of good asset management practice. WELL's approach to managing asset specific risks is discussed in Section 7.

4.7.1 Risk Management Accountabilities

WELL's Board has overall responsibility for the governance of the business, including approval of the risk management framework. Board oversight of the risk management process is delegated to the Audit and Risk Committee, a sub-committee of the Board. This Committee is updated bi-annually by the CEO as part of the regular management reporting functions in line with the risk management framework.

The CEO is accountable for the performance of the business and as such the effectiveness of the controls being employed to manage the risk from occurring. While the CEO is held accountable by the Board, the management team have assigned responsibilities for ensuring controls are implemented and well managed so that risks are reduced to an acceptable level. The responsibility of controls are assigned to managers and bi-annually reviewed to ensure they remain relevant and that the risk environment has been assessed for new risks or changes to the risk profile. Some of the key controls are listed in Section 4.7.3.



4.7.2 Risk Management Framework

WELL's approach to risk management is illustrated in Figure 4-8.




Figure 4-8 WELL's Risk Management Process

The risk management process as illustrated above covers the following five process steps:

Establish Context. This takes into account company objectives, the operating environment (discussed in Section 3.7), and risk criteria.

Risk Identification. Risks are identified through operational and managerial processes. WELL has grouped its risk into seven categories. Section 4.7.3 describes the controls used to mitigate the risks. The seven categories of risks are:

- Health and safety (employees, public and service providers);
- Environment (land, vegetation, waterways and atmosphere);
- Financial (cash and earnings losses);
- Reputation (media coverage and stakeholders);
- Compliance (legislation, regulation and industry codes);
- Customer service/reliability (quality and satisfaction); and
- Employee satisfaction (engagement, motivation and morale).

Risk Analysis. Analysis is undertaken using both qualitative and quantitative measures and assessed in terms of likelihood (chance of the event occurring) and consequence (impact of the event occurring). Consequence and likelihood tables have been established considering WELL's asset planning objectives. Consequence scales reflect levels of consequence for each criteria ranging from extreme (the level that would constitute a complete failure and threaten the survival of the business), to minimal (a level that would attract minimum attention or resources). Likelihood scales have been developed depending on the chance

or the likelihood of the event occurring. The risk rating is plotted on a risk chart with its likelihood score on the y-axis and overall consequence on the x-axis.




Figure 4-9 Risk Likelihood Consequence Matrix

The risk profiling matrices shown in Figure 4-10 and Figure 4-11 are used to determine the level of the risk or risk rating.

LIKELIHOOD	CONSEQUENCE				
	Minimal	Minor	Moderate	Major	Extreme
Almost Certain	Medium	High	High	High	High
Likely	Medium	Medium	High	High	High
Possible	Low	Medium	Medium	High	High
Unlikely	Low	Low	Medium	Medium	High
Almost Never	Low	Low	Low	Medium	Medium

Figure 4-10 Qualitative Risk Matrix

LIKELIHOOD	CONSEQUENCE				
	Minimal 1	Minor 2	Moderate 3	Major 4	Extreme 5
Almost Certain 5	5	10	15	20	25
Likely 4	4	8	12	16	20
Possible 3	3	6	9	12	15
Unlikely 2	2	4	6	8	10
Rare 1	1	2	3	4	5

Figure 4-11 Semi-Quantitative Risk Matrix



Risk Evaluation. Requires the evaluation of risk likelihood and consequence by appraising the results of a risk analysis. This evaluation of risk is used to identify controls that could be put in place to mitigate the risks identified and the priorities of each risk mitigation strategy.

Risk Mitigation. Risk mitigation utilises controls to mitigate the risk. Controls can include procedures and processes that eliminate or isolate the risk source, changing the likelihood and consequence of the risk occurring, sharing the risk with another party or parties (e.g. contracts and insurance), and/or accepting the risk by informed decision. Controls mitigate the likelihood or consequence of the risk which reduces the inherent risk score to give a residual risk rating.

4.7.3 Key Business Risks and Controls

Rankings of risk events and control effectiveness were updated in December 2017, identifying no current extreme residual risks and only one high residual risk.

In total, 44 business risks were assessed by WELL. Figure 4-12 shows the 10 highest risks ranked according to their residual ratings, and then by their inherent risk ratings.

	Event	Inherent Rating	Residual Rating
1	Catastrophic earthquake and/or Tsunami that causes significant damage to Company assets.	High	High
2	Non-optimum starting price adjustment.	High	Medium
3	A health and safety incident that affects one or more employees, contractors or visitors while performing work or visiting the Business' properties, assets or worksites.	High	Medium
4	Taxation authorities dispute Business' position on tax treatments.	High	Medium
5	Injury or Damage caused or loss suffered to third parties.	High	Medium
6	Sub-optimal performance or failure of network assets.	High	Medium
7	Non-compliance with relevant laws, regulations and reporting requirements.	High	Medium
8	Exploitation of IT security.	High	Medium
9	Inadequate management and/or supervision of contracted (i.e. outsourced) activities (including contractor resources).	High	Medium
10	Mismanagement of a crisis and emergency affecting the Network.	High	Medium

Figure 4-12 Summary of 10 Highest Business Risks

The business identified 190 unique controls that aim to mitigate the causes and consequences across the identified risks. The 10 most frequently used controls for managing risk across the business are:

- Insurance process including engagement of qualified brokers;
- Site Specific Risk Plans;
- Contractor Management System and Processes
- Auditing and Compliance (external and internal);
- Work Type Competency;
- Purchasing and Procurement Policy and Processes;
- Contract Management and Documentation;
- Education, Training and Development Policies and Programs;
- Delegations of Financial Authority; and
- Incident reporting and Investigation processes and standards.

4.7.3.1 Insurable Risks and Insurance Premiums

WELL insures around 15% of the estimated asset replacement cost of network assets, therefore covering only key strategic assets. The level of insurance cover purchased is based on estimates by specialists to determine maximum foreseeable loss for assets that can reasonably be insured.

The balance (85% by replacement value) of WELL's network is not insured, because insurance cover is not available or economically viable. As such, the business retains the risk on the uninsured portion of the network even though the regulated line charges do not include an allowance for the recovery of the cost of retaining the risk. WELL does not insure its sub transmission and distribution assets as insurance cover for these types of assets (poles, cables, wires etc.) is currently only available from a small number of global reinsurers, is very expensive, has high deductibles, and typically excludes damage from windstorm events.

Illustrating this by way of example, if WELL were to insure poles, cables and wire assets with a policy limit of \$500 million, it would need to pay a 10% deductible of \$50 million before any insurance payments would be provided. In addition, the annual insurance premium for such cover would be in the range of \$40 million to \$50 million. This additional cost would be passed onto consumers via line charges and is not considered economic.

Ex post recovery of the full costs is therefore the regulatory recovery mechanism for managing this risk.

4.7.3.2 Insurance Cover

WELL renews its insurances in two tranches:

1. Industrial Special Risks (ISR) Insurance, which includes Material Damage and Business Interruption cover and is renewed annually as at 30 June; and
2. General Products and Liability Insurance, includes general, products, pollution, electro-magnetic radiation, financial loss (failure to supply), and professional indemnity and is renewed annually as at 30 September.





Section 5

Service Levels

5 Service Levels

WELL is committed to providing consumers with a safe, reliable, cost effective and high quality energy delivery system. This section describes WELL's targeted service levels to achieve this objective. The measures and targets presented flow directly from the mission and Business Plan. This section also explains the basis for measuring the service level performance and how WELL has performed historically. There are four areas where services levels have been established:

- Safety Performance;
- Reliability Performance;
- Asset Efficiency; and
- Customer Experience.

The Reliability Performance Service Levels are discussed in Section 6 separately to the rest of the other Service Levels due to the complexity and detailed discussions included.

The service levels also incorporate feedback received from the stakeholder groups discussed in Section 3.6.

5.1 Safety Performance Service Levels

WELL has continued to build on the foundation set by past health and safety performance. It is a member of the Electricity Engineers Association (EEA) and supports initiatives the EEA undertakes in providing leadership, expertise and information on technical, engineering and safety issues across the New Zealand electricity industry.

Continual improvement in managing health and safety is core to WELL and involves ongoing review of health and safety practices, systems and documentation.

WELL welcomes the change in Worksafe New Zealand legislation as an ongoing approach of continual improvement to workplace safety and a focus on effective identification and management of risk to protect the welfare of workers engaged in delivering services, and the safety of the public.

Within this context of continuous improvement, four primary measures have been adopted:

- Incident, near miss and hazard observation reporting;
- Corrective actions from site visits closed;
- Lost Time Injury Frequency Rate (LTIFR); and
- Total Notifiable Event Frequency Rate (TNEFR).

LTIFR and TNEFR are lagging indicators of safety performance, while hazard observation reporting and site visits to engage and consult with the workforce are leading indicators that help build a supportive safety culture and reinforce positive safety behaviours. Past performance and targets for the planning period for each measure are set out below.



5.1.1 Lost Time Injury Frequency Rate

WELL’s staff and contractors recorded zero Lost Time Injuries (LTI) incidents in 2017. This resulted in a 2017 LTIFR of 0.00 per million hours worked and a two year rolling average of 2.00.




Figure 5-1 Lost Time Injury Frequency Rate

The two LTIs in 2016 were a relatively minor back sprain and a more serious fall from a pole. The fall resulted in contractor training and implementation of a new ladder-securing process being adopted.

5.1.1.1 Planning Period Target

WELL’s target for the 10-year planning period is to achieve a zero LTIFR over the whole period.

5.1.2 Total Notifiable Event Frequency Rate

The HSW Act 2015 introduced “notifiable events” which comprise notifiable injuries, notifiable illness, notifiable incidents and fatalities. The reference to “serious harm” within Section 16 of the Electricity Act 1992 was replaced with Section 23 of the HSW Act 2015 with reference to “notifiable injury, illness or incident”.

This is a lagging performance measure that commenced in 2016 and is being included into all service provider performance indicators.

5.1.2.1 Planning Period Target

WELL’s target for the 10 year planning period is to achieve a zero TNEFR over the whole period.

5.1.3 Incident and Near Miss Reporting

During 2017 WELL continued to implement initiatives aimed at increasing reporting rates of hazard observations and near miss events. Increased reporting is a measure of a mature safety culture and allows for continuous improvement from small incidents which in turn reduces the likelihood of serious events.

Total event reporting is slightly reduced in 2017 to a total of 600 events, at the time of writing. Approximately 80% of all reported events were classified as minor, 19% were classified as moderate, whilst less than 1% were of a serious nature. The total number of proactive reports received during 2017 was 206, an improvement on the previous year's near miss reports. These 206 are further broken down to 46 near miss events and 160 hazard observation reports.

5.1.3.1 Planning Period Target

WELL's current expectation for the 10 year planning period is to maintain the number of addressed hazard observation events reported per annum to approximately 300.

5.1.4 Corrective Actions from Site Visits

The WELL Field Assessment Standard provides for the categorisation of corrective actions resulting from field compliance assessments of worksites by severity and monitoring of close-out times.

There has been a decrease in the ratio of corrective actions identified per assessment against 2012 levels, as shown in Figure 5-2. Monitoring will continue to help ensure that this trend is continued. A focus in 2017 was compliance with Temporary Traffic Management requirements, with a particular focus on public safety around worksites.




Figure 5-2 Corrective Actions arising from Assessments 2012-2017

5.1.4.1 Planning Period Target

WELL's target for the 10 year planning period is to maintain the current level of field compliance assessments of approximately 600 assessments per year while reducing all three types of corrective actions.

5.1.5 Health and Safety Initiatives

During 2018 focus will be placed on the following areas to further improve performance:

- Increase the timeliness of close-out of assessments;
- Review the application of the risk management framework and expand the risk assessment process with clear focus on critical risk and control management and principal/contractor communications;
- Maintain site visits to further engage and consult workers on safety culture and supportive behaviours;
- Continue to expand the consultation, coordination and cooperation where work involves overlapping PCBU duties; and
- Increase strategic risk collaboration with contracted Field Service Providers in development of practical and effective risk controls.

5.2 Asset Efficiency Service Levels

The load factor or utilisation of an asset reflects consumer demand profiles, the geography of the region and historic network design and configuration decisions. WELL's predominantly urban network results in a higher than average utilisation and load density. The asset performance levels relate to the effectiveness of WELL's fixed distribution assets.

5.2.1 Planning Period Levels

Figure 5-3 illustrates the level of performance for each measure over the planning period together with key measures of network density.

WELL aims to maintain the high level of utilisation of asset at current levels, and in line with other networks that display similar characteristics. WELL has a very high customer density but below average energy density per ICP. The utilisation levels are shown in Figure 5-3.

	Load factor %	Distribution transformer capacity utilisation %	Loss ratio %	Demand density kW/km	Volume density MWh/km	Connection point density ICP/km	Energy density kWh/ICP
Industry average ¹⁵	60.3	30.08	5.5	42	205.04	13.6	15,029
WELL	47.8	41.92	3.7	123	495	35	13,977

¹⁵ Values as per the Pricewaterhouse Coopers (PwC) Electricity Line Business 2017 Information Disclosure Compendium.


Levels 2017-2027	>50%	>40%	<5%	-	-	-	-
---------------------	------	------	-----	---	---	---	---

Figure 5-3 WELL Asset Efficiency Levels to 2028


WELL is expected to remain at the current levels over the planning period.

5.3 Customer Experience Service Levels

It is important that WELL balances services that customers require, and what value they place on these, now and into the future. WELL has used the insights received from customer engagements to test the service levels provided and to inform investment plans for the planning period. In addition to good reliability and appropriate prices, customers increasingly expect good, timely information on their service and its status. Most customers accept occasional power cuts, and the ability to keep them informed when these events occur is most important. Ensuring good customer service and reliable, effective information flow is therefore a priority. To continue providing effective information to customers, WELL sets and tracks a set of performance targets for the contact centre. WELL conducts regular surveys with those who have recently had an outage to understand whether the price-quality trade-off they receive is appropriately balanced. Customers who have recently had an outage are more engaged on the issue and are better positioned to provide a considered response to queries. The charts below set out the most recent results (November 2017) for two core questions that focussed on the reliability of WELL’s service and the cost to customers.



Would you be prepared to pay a bit more for your power if it meant fewer power cuts?



Would you be prepared to have slightly more power cuts if it meant your electricity bill was a bit lower?

These results suggest that customers are broadly satisfied with their current level of reliability and the price of delivering that service. This view is supported by WELL’s position (yellow diamond) in the low SAIDI / low price¹⁶ quadrant of the benchmarking analysis in Figure 5-4.

¹⁶ WELL uses revenue per ICP as a proxy for price given the availability of data this information disclosure.




Figure 5-4 Quality – Price Comparison

This surveying and stakeholder engagement will continue and be expanded in 2018. Further customer segmentation of the surveys is also underway to ensure the price-quality balance is appropriate for individual customer groups.

In addition to monitoring customer's preferences, WELL has two customer related performance measures. These are:

- Power restoration service level targets; and
- Contact Centre performance.

Each is described below.

5.3.1 Power Restoration Service Levels

WELL's published 'Electricity Network Pricing Schedule' provides standard service levels for the restoration of power to three different categories of consumers: CBD/Industrial, Urban and Rural. These service levels reflect previous feedback from consumers and are agreed between WELL and all retailers.

The geographical region by customer category is shown in Figure 5-5.




Figure 5-5 Location of Customer Category Areas

5.3.1.1 Planning Period Targets

The targets for the power restoration service levels remain consistent over the planning period 2018-2028, as set out in Figure 5-6.



	CBD / Industrial	Urban	Rural
Maximum time to restore power	3 hours	3 hours	6 hours

Figure 5-6 Standard Power Restoration Service Level Targets 2018-2028

5.3.2 Contact Centre Service Levels

WELL has developed a set of key performance indicators (KPIs) and financial incentives that provide service level targets for the Contact Centre (Telnet). These service levels have been in place since 2013. Due to the high level of consumer satisfaction with Contact Centre performance (90% to 94%), it is expected the targets and performance measures will remain broadly the same for the planning period from 2018 to 2028. As consumer engagement initiatives progress and the contractual arrangements with the Contact Centre have been renewed, improvements continue to be made in service levels and measures of key performance by Telnet.

Examples of changes that have been made to Contact Centre processes include:

- More rigour around how the WELL/Telnet information knowledge base is managed;
- The introduction of measured outage communications KPIs between the contact centre and primary field service contractors;
- Improved Contact Centre performance reporting and review; and
- Clearer work flow prioritisation.

5.3.2.1 Contact Centre Service Levels

There are currently eight service level performance measures for the Contact Centre. These are:

1. Overall Service Level (A1) - This is the measure of call quality. Each month between 10 and 20 random call recordings are monitored by the Contact Centre and WELL against 16 quality criteria. The respective scores are compared and discussed. The current target is an overall quality score of 80% or better.
2. Call response (A2) - This is a measure of the average call response waiting time. The target is 20 seconds average wait. This target is an international standard for utility call centres and is continually being updated within the call centre industry by customer survey results.
3. Missed calls (A3) - This is a measure of abandoned calls, where the caller hangs up prior to the call being answered. The target is 4% of calls, or fewer. This target is also an international standard for utility call centres, which recognises that calls may be abandoned for a variety of reasons, including some not related to call centre performance. However an abandonment rate above 4% may be indicative of an issue with the call centre service.
4. Outage Communications (B1): This is a measure of the time taken to initially notify of an outage. Retailers will be notified, and the WELL website updated, within five minutes of Telnet receiving notice of an outage affecting 10 or more customers. Note that this initial notification, and all subsequent updates, also update the WELL website and OutageCheck smartphone app.

5. Outage Communications (B2): This is a measure of ongoing outage updates. Retailers and the WELL website/outage app will be updated with changes (if any) to affected customer numbers and Estimated Time of Restoration (ETR) at least every 30 minutes (+/- 5 minutes) during the outage.
6. Outage Communications (B3): This KPI measures that more accurate ETR information is provided within a reasonable time. Within 90 minutes of Telnet receiving notice of an outage affecting 10 or more customers, Telnet will contact the Network Control Room (NCR) or Northpower (as appropriate) to get an accurate updated ETR. Retailers and the WELL website/OutageCheck app will be updated.
7. Outage Communications (B4): This is a measure of ongoing outage updates for more prolonged outages. Retailers and the WELL website/OutageCheck app will be updated with changes (if any) to affected customer numbers and ETR at least every 120 minutes (+/- 5 minutes) during the outage.
8. Outage Communications (B5): This is a measure of the time taken to notify outage restoration. Retailers will be notified, and the WELL website/OutageCheck app updated, within five minutes of Telnet receiving notice of outage restoration.

Figure 5-7 sets out the results for the A1 to A3 measures for the 2017 year.

SL	Service Element	Measure	KPI	2017 Actual
A1	Overall service level	Average service level across all categories	>80%	88.6%
A2	Call response	Average wait time across all categories	<20 seconds	13.8 seconds
A3	Missed calls	Total missed/abandoned calls across all categories	<4%	2.36%

Figure 5-7 Contact Centre Service Level Performance

5.3.2.2 Planning Period Targets

The Contact Centre service level targets are to provide consistent performance over the planning period 2018-2028. These are shown in Figure 5-8.



SL	Service Element	Measure	Target
A1	Overall service level	Average service level across all categories	>80%
A2	Call response	Average wait time across all categories	<20 seconds
A3	Missed calls	Total missed/abandoned calls across all categories	<4%
B1	Initial Outage Notification	Energy retailers notified and the WELL website updated within the time threshold	<5 minutes
B2	Ongoing Outage Updates	Regular outage status updates provided	every 30 minutes
B3	Estimated Time of Restoration (ETR) Accuracy	Accurate ETR provided within the time threshold from initial outage notification	<1.5 hours
B4	Ongoing ETR Updates	Regular status updates to prolonged outages provided within the time threshold	within 2 hours
B5	Restoration Notification	Energy retailers notified and the WELL website updated within the time threshold from the time of restoration	<5 minutes

Figure 5-8 Customer Satisfaction Service Level Targets 2018-2028

This page is intentionally blank





Section 6

Reliability Performance

6 Reliability Performance

Electricity is an essential service for the community; it is the lifeblood for society's welfare and essential to a thriving economy. Losing it for a prolonged period of time has a devastating impact on people's quality of life, particularly if they are unable to seek alternatives. Wellington's electricity network, although strong due to its underground cabling, can be vulnerable to damage from external events. Society depends on continuity of power supply and it is quite hard to imagine life without it. While large disruptions can occur, and some interruption is expected, customers also reasonably expect to have supply returned without undue delay, as their welfare and the region's economy will quickly suffer if the power stays off.

For this reason, WELL is committed to providing customers with a reliable and secure electricity supply. WELL has consistently demonstrated this commitment by undertaking several reliability improvement initiatives to further progress the performance of the network, some of which are detailed below:

- The worst performing feeder improvement programme such as work undertaken to improve the quality of supply experienced for customers in the Akatarawa area supplied by Brown Owl 3 (discussed further in Section 6.5.2).
- Engagements with UFB providers which have resulted in a significant reduction of third party fault events caused by the UFB programme (discussed further in Section 6.5.1.6).
- Work undertaken based on 2016/17 reliability performance to improve practices in vegetation management as well as greater engagement with tree owners which has resulted in markedly improved vegetation management performance (discussed further in Section 6.5.1.3).

This section outlines how WELL has performed against this objective and explains how network reliability is managed within the price quality trade off provided to its consumers as discussed in Section 5. The SAIDI and SAIFI targets were both exceeded over the 2016/17 & 2017/18 regulatory years, but this has not been due to any deterioration of the network assets and has not resulted in any significant negative impact to consumers.

This section discusses the performance across the 2016-2017 and 2017-2018 years, along with the strategy that WELL is undertaking to address identified reliability issues. The structure of the section is:

- How reliability is measured;
- Comparison of performance with industry peers;
- A summary of the overall reliability performance;
- Discussion on event types and controls;
- Worst performing feeder programme; and
- Regional performance.



6.1 Reliability Measures

Network reliability is measured using two internationally recognised performance indicators, SAIDI and SAIFI. When taken together SAIDI and SAIFI indicate the availability of electricity supply to the average customer connected to the network.

- SAIDI¹⁷ is a measure of the total time, in minutes, electricity supply is not available to the average consumer connected to the network in the measurement period; and
- SAIFI¹⁸ is a measure of the total number of supply interruptions that the average consumer experiences in the measurement period. It is measured in number of interruptions¹⁹.

In accordance with the methodology established by the Commission, planned outages are weighted by 50% and the following supply interruptions are not included in the measured performance indicators:

- Interruptions caused by the unavailability of supply at a GXP, as a result of automatic or manual load shedding directed by the transmission grid operator²⁰, or as a result of some other event external to the WELL network;
- Interruptions lasting less than one minute. In these cases restoration is usually automatic and the interruption will not be recorded for performance measurement purposes. However these interruptions are recorded by WELL for planning and operational purposes; and
- Interruptions resulting from an outage of the low voltage network or a single phase outage of the 11kV distribution network. In practice such interruptions do not have a material impact on measured system reliability.

6.1.1 Reliability Performance Targets

The regulatory regime that applies to WELL sets reliability caps and collars for each year from 2015/16 to 2019/20. The caps and collars are set using historical data at one standard deviation above and below the mean (target). The caps and collars are the maximum and minimum reliability outcomes for which a reward or penalty of \$95,091²¹ per SAIDI minute and \$6,308,301 per SAIFI unit apply if the company's performance is better than or exceeds the target respectively. In addition, a compliance test applies for reliability which is based on not exceeding either cap in any two of three consecutive years. The targets, caps and collars for WELL are presented in Figure 6-1.

Regulatory Period 2016-2020	Annual SAIDI	Annual SAIFI
Target	35.44	0.547

¹⁷ System Average Interruption Duration Index

¹⁸ System Average Interruption Frequency Index

¹⁹ Due to the effect of averaging, SAIFI is reported as a non-integer number.

²⁰ The transmission grid operator has the authority to direct electricity distributors to shed load. This is necessary during emergencies to ensure that the power system continues to operate in a secure and stable state.

²¹ The rewards and penalties relate to WELL only and are calculated on an EDB by EDB basis.

Regulatory Period 2016-2020	Annual SAIDI	Annual SAIFI
Cap	40.63	0.625
Collar	30.24	0.468

Figure 6-1 WELL Annual Regulatory Reliability Targets and Limits

The data set used to establish these performance targets is based on the 10 years from 1 April 2004 to 31 March 2014, known as the reference period. The first five years of the reference period experienced benign weather relative to the second five years. Consequently, the targets represent a performance level that is better than what would be expected given recent weather trends.

Furthermore, changes to the HSW Act 2015 caused many EDB's, including WELL, to review their live versus de-energised work policies and procedures. This has resulted in a material impact to planned outages due to the increase in de-energised work compared to the reference period. This increase, as seen in 2017/18, is not representative of the historic contribution of planned outages used to determine the regulatory targets. It is anticipated that this will add significant pressure on WELL's ability to meet the targets set during a period of low levels of planned outages for de-energised work.

The targets for SAIDI and SAIFI are shown in Figure 6-2 and reflect WELL's view that it is adequately funded to maintain network reliability at current levels, subject to the paragraph above discussing planned work. There is uncertainty around the calculation of targets from 2020/21 onwards, with the final determination not due until the 2020 DPP reset decision. Figure 6-2 assumes that the SAIDI and SAIFI targets beyond 2020 account for the impact of the HSW Act 2015.



Regulatory Year	Reference Period ²²	2017/18	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27
SAIDI target		35.44	35.44	35.44	40.86	40.86	40.86	40.86	40.86	40.86	40.86
SAIFI target		0.547	0.547	0.547	0.583	0.583	0.583	0.583	0.583	0.583	0.583
SAIDI planned target	0.58	5.3	5.3	5.3	6.0	6.0	6.0	6.0	6.0	6.0	6.0
SAIDI unplanned target	34.86	34.86	34.86	34.86	34.86	34.86	34.86	34.86	34.86	34.86	34.86
SAIFI planned target ²³	0.004	0.004	0.004	0.004	0.04	0.04	0.04	0.04	0.04	0.04	0.04
SAIFI unplanned target	0.543	0.543	0.543	0.543	0.543	0.543	0.543	0.543	0.543	0.543	0.543

Figure 6-2 Network Reliability Performance Targets

The SAIDI and SAIFI targets against the historical performance are shown in Figure 6-3 and Figure 6-4. The 2017/18 year includes a forecast to account for the March 2018 month shown in dark blue. The forecasts in SAIDI and SAIFI include an account for the impact of the HSW Act 2015 on the additional amount of de-energised work being undertaken.

²² This includes the 50% weighting on planned work that is applied when the reference data set was converted to the target.




Figure 6-3 WELL SAIDI Performance




Figure 6-4 WELL SAIFI Performance

6.2 Industry Comparison

WELL was one the most reliable EDBs in New Zealand in 2016/17 as shown in Figure 6-5 and Figure 6-6. The data source is the annual Information Disclosures made by Lines Businesses and made publicly available in August 2017. The benchmarking analysis shows that WELL's system reliability indices (i.e. SAIDI, SAIFI) are currently performing well against comparable networks in New Zealand (shaded in green).




Figure 6-5 National SAIDI by EDB for 2016/17




Figure 6-6 National SAIFI by EDB for 2016/17

6.3 Reliability Performance in 2016/17 and 2017/18

The total year-end SAIDI for 2016/17 was 49.732 minutes which was above the year end cap of 40.630 minutes. The total year-end SAIFI for 2016/17 was 0.711 interruptions and above the year-end cap of 0.625. WELL's network performance for the 2017/18 regulatory year as at 28 February 2018 exceeded the annual cap of 40.630 minutes for SAIDI but is currently under the yearly cap of 0.625 for SAIFI.

There were four major event days (as opposed to the 2.3 accounted for in the target) experienced over 2016/17 which resulted in a SAIDI contribution of 8.412 minutes and a SAIFI contribution of 0.093. These were a result of major storms in May and September 2016, February 2017 and the November 2016 earthquake.

Overall the most significant contributions to SAIDI and SAIFI for the period 2016/17 were outages caused by vegetation outside the cut zone and other overhead faults.

Contributing factors to the increase in SAIDI and SAIFI from vegetation-related and overhead faults was the increase in the number of days with maximum wind speed gusts greater than 100 km/hr and the number of major event days experienced in 2016/17 compared to 2015/16. These are summarised in Figure 6-7.



Contributing Factors	2015/16	2016/17
Number of days with wind speeds exceeding 100 km/hr ²⁴	7	12
Number of major event days	0	4

Figure 6-7 Contributing Factors to Increased SAIDI and SAIFI

A high level NIWA analysis has confirmed that the 2016/17 year was significantly windier (using a turbulence intensity measure) than the reference period. This increase in significant wind exposure brought about changes to WELL's vegetation management processes whereby certain overhead feeders are now placed on a reduced cycle vegetation cutting programme. To immediately address the vegetation issues identified in 2016/17, WELL sent vegetation management contracting teams back into areas that had previously been in to re-look at the potential impact of trees and to undertake additional trimming. In addition to this, WELL began increasing its engagement with tree owners and also undertook covered conductor projects which are further discussed in Section 6.5.1.3. This has resulted in a significant reduction in the occurrences of vegetation related faults on the network in 2017/18.

In order to combat the occurrence of overhead related faults, WELL has begun to develop leading indicators for overhead components including poles and conductors which are detailed in the overhead network fleet strategies and are also discussed in Section 8 of this AMP.

The primary drivers for performance in 2017/18 has been an increase in the contribution from planned outages, vehicle contacts, and 11kV cable faults. A cable test condition monitoring programme is underway to address the increase in 11 kV cable faults has been developed by focussing on high risk cable sections. The risk posed by a cable section is determined by asset health and criticality matrices. The performance of the overhead network year to date has been better than average. This reflects the benefits from the actions implemented following the Strata review of 2015/16 (discussed in Section 6.4) as well as the plans put into place after last year's exceedance of targets which was driven by the overhead network.

6.4 Previous Exceedance of Quality Limits

A period of extreme weather events led to WELL's non-compliance with the Quality Path in both 2012/13 and 2013/14. This non-compliance prompted the Commission to engage Strata consulting to review WELL's asset management practices. A key finding from the review report was:

"Taking the 2016 AMP information into account with other findings in this review, Strata concludes that WELL has the capability and has forecast sufficient expenditure levels to enable it to manage the network in a manner that will prevent or mitigate quality standard non-compliance in the future"

²⁴ Wind speed data taken from Wellington Airport and vetted by the National Institute of Water and Atmospheric Research (NIWA).

Strata included recommendations from the review that it considered, if applied by WELL, would be likely to improve the probability of achieving and sustaining reliability performance within the quality standards in the future. These recommendations, along with WELL's responses are shown in the table below.

Strata Consulting Recommendation	WELL Response
Increase use of predictive analysis of failure rates for fleet strategies as part of the condition based risk management approach to asset management.	Predictive analysis has been expanded from a focus on sub transmission and substation assets to include overhead fleet strategies in 2017 and 11 kV underground cable strategies will occur in 2018.
Review and simplify the fault cause descriptors used for reliability reporting to simplify the analysis and avoid incorrect reporting. Avoid the use of 'storms' fault category, and following investigations of major events such as storms, apply the results of the investigation to reclassify fault causes with known information.	Completed. All outages are now classified according to fault cause. Reclassification of historical events has been completed where possible.
Proceed with analysis of insulated cable technologies as a source of potential reliability improvements to overhead line network, with a view to implementing the selected option in a field trial.	Insulated cable technologies have been evaluated, with three trials completed for 2017.
Consider reporting SAIDI and SAIFI by CBD/Urban/Rural classifications to improve understanding of the contribution of these areas to the overall reliability performance. Strata understands that WELL already classify these areas for other purposes in the Business.	A summary of performance by region is incorporated into this plan.
Consideration of the optimal location of protection and sectionalising equipment with SCADA is undertaken in reliability planning to minimise the impact of outages to customers, and that this is considered alongside a review of safety risk.	Worst performing feeders analysis has been expanded with additional targeted line sectionalisers installed in 2017.
Undertake a further review of the asset risk management framework, specifically of asset risks arising from network events (such as earthquakes) experienced by other electricity transmission and distribution businesses.	In 2016 analysis was completed on resilience of the network to major earthquakes. This was based on the experiences of Orion New Zealand in the 2011 Christchurch earthquake. Funding for risk mitigation solutions have been determined and are under review with the Commission in the SCPP application with further applications expected in future years.

Figure 6-8 Strata Recommendations

6.5 Reliability Event Types and Controls

WELL continuously reviews and updates its asset management practices and plans against the performance of the assets. In 2015 these practices were further supported by the external review undertaken by Strata Consulting. Another example of this has been the internal review of WELL's



vegetation management programme after the performance of 2016/17 which resulted in a change in practices and a significant improvement in the number of vegetation related faults. The waterfall graphs (Figures 6-9 to 6-12) below show the changing contributions of the major categories that have influenced reliability from 2014/15 to 2017/18. The major categories are:

- Overhead Network faults;
- Underground Network faults;
- Substation faults;
- Car vs. Pole faults;
- Other Third Party faults;
- Planned work; and
- Major Event Days.

Each of these categories is shown as either performing better (coloured in green) or worse (coloured in red) than their contribution to the target, which was based on the reference period. Also shown is the standard deviation for each category across the reference period to highlight the significance of any changes in performance.

The Overhead Network was challenged in 2016/17 by vegetation related faults and overhead faults during high winds. This was addressed by increasing the engagement with tree owners and improving the processes used to undertake vegetation management which has since resulted in a significant improvement in performance for this fault type. Planned work has shown a steady increase since the establishment of the HSW Act 2015 and changes to undertake more de-energised work. Car vs. Pole faults in 2017/18 are also significantly higher than what was witnessed during the reference period.

Comparing the four years shows that the exceedances are driven by different fault categories in each year, and there is no discernible trend other than an increase in planned outages.



Figure 6-9 2014/15 SAIDI Performance by Outage Type




Figure 6-10 2015/16 SAIDI Performance by Outage Type




Figure 6-11 2016/17 SAIDI Performance by Outage Type




Figure 6-12 Extrapolated 2017/18 SAIDI Performance by Outage Type



6.5.1 Performance by Category and Controls

The network SAIDI performance by fault type from 2015/16 to 2017/18 year to date (YTD) is shown in Figure 6-13. Major Event days are not included in this chart.




Figure 6-13 SAIDI Performance by Fault Type 2015/16 – 2017/18 (YTD)

Figure 6-13 shows the increase in SAIDI caused by planned outages, third party incidents and underground equipment but also shows improvements in performance in the overhead network since last year. A discussion on each of the categories and associated controls follows.

6.5.1.1 Planned Outages

The increase in planned outages is being driven by the amount of planned work being completed de-energised. WELL's view is that the regulatory limits should be adjusted to reflect the changes from the review of safe work practices and the material increase in planned outages that has resulted. The following specific controls for planned work were put in place in 2017:

- Extending the approval process for outages to improve the planning of outages by providing more time to determine how best to reduce the impact to consumers and to also allow for a greater notification period for consumers; and
- Introducing a risk assessment process on live work to ensure the decision whether to do work live or de-energised follows a consistent process considering both safety and network impact.

Even with the above controls in place, it is anticipated that the impact of de-energised work as planned outages will not be reduced to that included into the current SAIDI and SAIFI targets set by the reference period. This will continue to be a point of concern for WELL in meeting reliability targets in the future.



6.5.1.2 Overhead Equipment

The SAIDI from overhead equipment outages has reduced in 2017/18 relative to previous years. These events generally occur during days of strong winds or stormy weather and the resultant overhead equipment failures are often due to failed connectors. The worst performing feeder program has been successful in addressing degradation in equipment due to asset replacement.

The relative SAIDI impact of different overhead equipment failure fault causes is shown in Figure 6-14.




Figure 6-14 SAIDI Impact of Overhead Equipment Failure as the Fault Cause

Specific controls for overhead related events are:

- Targeting the worst performing feeders. This has historically produced a programme which delivers consistently good results in terms of improving feeder performance. Line rebuilds were increased in 2017/18 by \$1.3m and provision has been made in the AMP for this to continue;
- Undertaking pole, cross-arm and insulator replacement programmes. These programmes are reducing the average age of these assets by 0.5 years each year; and
- The introduction of leading indicators such as pole and conductor degradation rates based on actual sampling and testing programmes as discussed in Section 7. An example of this is shown in Figure 6-15.




Figure 6-15 Preliminary Data on the Degradation Rates of Overhead Conductor

6.5.1.3 Vegetation

Some vegetation issues continue to eventuate as a result of branches and vegetation being blown into lines during storm conditions from outside of the zones controlled by vegetation management as prescribed by the Electricity (Hazards from Trees) Regulations 2003. The high wind exposure experienced in 2016/17 resulted in a review of vegetation management processes and as such a more risk-based approach is now undertaken by WELL and its vegetation management contractor, Treescape. This means that worst performing feeders where tree growth rates are high are placed on a reduced cycle trimming programme to reduce the chances of vegetation related faults being experienced by customers. There are still significant issues in managing vegetation as the current regulations do not permit WELL to manage vegetation that poses a risk to the network outside of the Notice Zone.

WELL is surveying customers impacted by large vegetation events in order to raise community awareness and to understand the localised cost versus the quality trade off of these events.

Effective vegetation management is a more efficient means of controlling vegetation related outages when compared to alternative network options such as undergrounding circuits.





Bark Blown onto Overhead Conductors

Specific controls for vegetation events are:

- Increased vegetation contract to \$1.6m in 2017 which has helped reduce vegetation faults in 2017/18;
- Introduction of a risk-based approach to tree trimming in 2017 considering location of the tree along the feeder and proximity and type of tree which allows vegetation spend to be focussed on high priority areas;
- Installation of covered conductors in three trial locations to assess their effectiveness at reducing risk from vegetation. It is expected this trial could result in a reduction of up to 1.9 minutes per year (based on results in 2016/17) by preventing vegetation related faults in these areas; and
- WELL has identified and implemented improvements in the way vegetation related outages are recorded and since 2014 has been recording instances where trees causing outages originate from within the growth limit zone, notice zone, fall zone, or from blown debris.



Covered Conductor Trial Installation

6.5.1.4 No Fault Found

Most of the incidents which are listed as ‘no fault found’ occur during stormy weather and therefore were most likely the result of vegetation or line clash short-time events.

After a ‘no fault found’ event, the affected feeder is re-patrolled during daylight hours to identify possible causes that may not have been apparent during the fault. However there will always be instances where the cause of the interruption cannot be identified with any certainty.

6.5.1.5 Underground Equipment

Failures in underground equipment are generally due to cable joint or termination failures. Cable systems themselves generally have a long life and high reliability as they are subject to fewer environmental hazards than overhead assets.

Underground equipment faults have shown an increase in 2017/18 as shown in Figure 6-16. The ultimate cause of the increase in cable faults cannot be proven at this stage, however it is possibly due to delayed damage caused by the November 2016 earthquake, progressing to failure during the wet winter. The earthquake may have caused damage to lead sheaths on PILC cables which would have resulted in moisture ingress during the excessively wet 2017 winter period ultimately leading to failures. This delayed damage follows a similar trend to that experienced by Orion following the 2010/2011 Christchurch earthquakes where there were elevated cable outages in the years following the earthquakes. There is a correlation in the location of ground shaking during the November 2016 earthquake and the location of cable faults during 2017/18. By way of example, Lower Hutt experienced significant ground shaking resulting in 26 overhead 11kV line outages and this is where most cable faults have since occurred.






Figure 6-16 SAIDI Impact of Underground Equipment Failure as the Fault cause

Specific controls for underground events are:

- A cable test programme focussing on high risk cable sections including Lower Hutt area with elevated fault numbers in 2017/18;
- Cost Benefit analysis used to determine whether to replace or repair cables following faults; and
- Asset health and criticality analysis used to assess the risk of 33kV cables.

6.5.1.6 Third Party Incidents

Third party incidents contributed 19.72% or 8.51 minutes of the total SAIDI incurred in 2017/18 YTD. This is a significant increase compared to the average previous contributions of 3.81 minutes and the allowance in the target based on the reference period of 4.8 minutes. This has significantly increased from the previous years. The primary contributor to third party incidents was car versus pole events.

The UFB network project, which had a significant impact on the number of third party strikes in 2015/16 and 2016/17, has reduced significantly. This is primarily due to the intensive engagement that WELL undertook with UFB contractors to ensure that workers are deemed competent to work in proximity to the network. Similarly, third party incidents due to landowners felling trees have decreased. The breakdown of the number of events and SAIDI impact are shown in Figures 6-15 and 6-16. It is not cost-effective to remove all the risk of car versus pole events, especially with many poles located directly next to the kerb. Undergrounding the assets is not an effective solution from a cost/quality perspective.




Figure 6-17 Outage Count of Third Party Incidents as the Fault cause




Figure 6-18 SAIDI impact of Third Party Incidents as the Fault cause



Specific controls for car versus pole events are:

- Increasing the visibility of poles in identified higher risk areas. Existing poles near intersections have reflectors and white paint at the bottom of the pole, and all new poles installed beside roads are fitted with reflectors. This control is currently under review for its effectiveness as the reflectors may actually attract more vehicle strikes; and
- Considering relocation of poles when they are being replaced. There are often restrictions due to underground services and service lines which limit the ability to move poles without causing aerial trespass.



Fault Cause – Car versus Pole

While the number of vehicle collisions will always vary from year to year, WELL has deployed a number of safety campaigns targeting third party contractors working around the network assets. These include:

- Engaging those involved with the UFB roll out programme which has led to a reduction in the number of third party cable strikes; and
- Continuing to participate in the 'Before U Dig' programme which provides free plans and cable mark-outs to third parties during the planning process and prior to field excavation. WELL is considering extending this programme to include the overhead system assets.

6.5.1.7 Lightning and Animal Fault Causes

Outages due to lightning on 11kV assets are usually the result of failure of overhead transformers caused by the strike. Extreme lightning events do not occur often in the Wellington region.

Outages due to animals are caused by birds and possums contacting the 11kV overhead lines. To reduce the risk of possums WELL uses possum guards (a 600 mm tall metal sheet wrapped around the mid-section of the pole) in rural areas.

6.5.1.8 Substation Equipment

Substation equipment related outages remain well controlled by WELL's switchgear replacement programme (described further in Chapter 8).

6.5.1.9 Other Significant Controls

WELL also has implemented a number of other generic controls that apply across all categories:

- Mitigating, where practicable, the impact of severe storms by using line sectionalisers and reclosers, and by employing well-practiced emergency restoration plans;
- Analysing all significant outages (over 0.45 SAIDI minutes or 0.02 SAIDI interruptions) to identify root causes and recommendations to prevent recurrence;
- Monitoring trends in outages causes and other asset failures to identify changes in maintenance practices and to confirm assets to be upgraded;
- Monitoring of field response and repair times for major faults to identify causes of prolonged outages and develop strategies to improve restoration times;
- Further refinement of the targets to reflect consumer segments (for example, Wellington CBD requires a higher level of security than rural consumers);
- Extending risk based analysis in asset strategies to cover conductors and underground cables;
- Extending the Corrective Maintenance programme by \$1m from 2017 which has reduced the number of medium risk defects on the network.
- The Strata Consulting Ltd performance improvement recommendations have been completed.

6.6 Worst Performing Feeder Programme

WELL undertakes line refurbishment on sections of network due to condition or performance. These projects are determined from the analysis of the worst performing feeders.



Identification of worst performing feeders is based on five factors:

- SAIDI – if the feeder has had an annual SAIDI greater than or equal to 0.50 minutes;
- SAIFI – if the feeder has had an annual SAIFI greater than or equal to 0.01;
- Number of interruptions – if the feeder has greater than or equal to 2 interruptions;
- If the feeder outages have accumulated an annual reliability cost of over \$100k; and
- If the feeder performance has deteriorated significantly since the previous period in any of the above four factors.

Reliability improvements are carried out on the worst performing feeders. The benefits are shown in the graphs below of the general improvement of the worst performing feeders from 2015/16.




Figure 6-19 Improvement of the 2015/16 Worst Performing Feeders by SAIDI






Figure 6-20 Improvement of the 2015/16 Worst Performing Feeders by SAIIFI




Figure 6-21 Improvement of the 2015/16 Worst Performing Feeders by Number of Interruptions

Faults on these worst performing feeders are reviewed to determine whether there is a common root cause that could cost effectively be addressed. Remedial actions identified by this review are fed back into the

work programme, where the resulting activities are carried out either under corrective maintenance or as a network project, depending on the scope of the work required.

6.7 Reliability Contribution by Area

Figures 6-22 and 6-23 show the SAIDI and SAIFI contributions from each network area to the overall WELL regional performance figures. One noticeable fact has been the increase in SAIDI and SAIFI, particularly in the Lower Hutt area, due mainly to the larger amounts of de-energised work as a result of the HSW Act 2015 (discussed in Section 6.1).




Figure 6-22 SAIDI Contribution by Area (as at 01 February 2018)




Figure 6-23 SAIFI Contribution by Area (as at 01 February 2018)

Figures 6-24 and 6-25 show the SAIDI and SAIFI figures that have been normalised to each network area based on ICP numbers.




Figure 6-24 SAIDI Contribution by ICP (as at February 2017)






Figure 6-25 SAIPI Contribution by ICP (as at February 2017)

This page is intentionally blank





Section 7

Asset Lifecycle Management

7 Asset Lifecycle Management

This section provides an overview of WELL's assets, and their maintenance, refurbishment and replacement strategies over the planning period. The objective of these strategies is to optimise operational, replacement and renewal capital expenditure on network assets, whilst ensuring that the network is capable of meeting the service level targets and mitigating risks inherent in running an electricity distribution network.

In summary, the section covers:

- Asset fleet summary;
- Risk-based asset lifecycle planning;
- Stage-of-life and asset health analysis;
- Maintenance practices;
- Asset maintenance and renewal programmes; and
- Asset replacement and renewal summary.

7.1 Asset Fleet Summary

A summary of the population for each of the Information Disclosure Requirements (IDR) categories and asset class is shown in Figure 7-1.

IDR Category	Asset Class	Section	Measurement Unit	Quantity
Sub Transmission	Sub transmission Cables	7.5.1	km	138
	Sub transmission Lines	7.5.3.2	km	57
Zone Substations	Zone Substation Transformers	7.5.2.1	number	52
	Zone Substation Circuit Breakers	7.5.2.3	number	368
	Zone Substation Buildings	7.5.2.5	number	27
Distribution and LV Lines	Distribution and LV Lines	7.5.3.3	km	1,676
	Streetlight Lines	7.5.3.3	km	809
	Distribution and LV Poles	7.5.3.1	number	39,238
Distribution and LV Cables	Distribution and LV Cables	7.5.4	km	2,834
	Streetlight Cables	7.5.4	km	1,091
Distribution	Distribution Transformers	7.5.5.1	number	4,367



IDR Category	Asset Class	Section	Measurement Unit	Quantity
Substations and Transformers	Distribution Substations	7.5.5	number	3,662
Distribution Switchgear	Distribution Circuit Breakers	7.5.6	number	1,252
	Distribution Reclosers	7.5.7.1	number	17
	Distribution Switchgear - Overhead	7.5.7.2	number	2,588
	Distribution Switchgear - Ground Mounted/Ring Main Units	7.5.6	number	2,413
Other Network Assets	Low Voltage Pits, Pillars and Cabinets	7.5.6.1	number	11,510
	Protection Relays	7.5.8.2	number	1,415
	Load Control Plant	7.5.8.3	number	23

Figure 7-1 Asset Population Summary

7.2 Risk-Based Asset Lifecycle Planning

Risk-based asset lifecycle planning consists of the following:

- Design, construction and commissioning according to network standards, including the use of standardised designs and equipment where appropriate;
- Condition-based risk assessments;
- Routine asset inspections, condition assessments and servicing of in-service assets;
- Evaluation of the inspection results in terms of meeting customer service levels, performance expectations and control of risks;
- Maintenance requirements and equipment specifications to address known issues; and
- Repair, refurbishment or replacement of assets when required.

Throughout all of these stages, ensuring the safety of the public and workers is the highest priority.

WELL takes a risk-based approach to asset lifecycle planning. The preventative maintenance programme is mainly time-based, with each maintenance task having a set cycle based on a known reliability history and is also influenced by any trended degradation of condition that may occur across a fleet. Corrective maintenance tasks identified as a result of preventative maintenance are prioritised for repair according to severity and consequential risk to safety and network performance.

Standardised designs are used for high volume assets, including overhead and underground construction at 11 kV and 400 V, distribution substations, and distribution switchgear. This approach ensures:

- Familiarity for contractors, increasing the safety and efficiency of construction and operation;
- Procurement benefits, through reduced lead times and increased stock availability; and
- Economic benefits, as standard products generally have lower cost than customised or non-standard ones.

High value asset replacements such as sub transmission cables and zone substation assets are designed to meet the specific needs of the project, however must still meet the requirements of relevant network standards.

Electricity distribution assets have a long but finite life expectancy and eventually require replacement. Premature asset replacement is costly as the service potential of the replaced asset is not fully utilised. Equally, replacing assets too late can increase the risk of safety incidences and service interruptions for consumers. Asset replacement planning therefore requires the costs of premature replacement to be balanced against the risks of asset failure, public or contractor safety and the deterioration of supply reliability that will occur if critical assets are allowed to fail in service. Hence, there is a balance to be found between the cost of maintaining an asset in service and the cost to replace it.

This section focuses on the different asset classes and provides an insight into the condition and maintenance of each class with an overview of maintenance programmes and renewal and refurbishment programmes.

7.3 Asset Health Analysis

WELL makes use of the EEA Asset Health Indicator Guide - 2016. This methodology specifies a number of health indices for each asset class, which are rated on a scale of H5 (new) to H1 (end of life). The overall Asset Health Indicator (AHI) is determined by its worst health index, further reduced by any indices scoring less than H4.

Asset Health Analysis does not rely on factors having subjective weightings and does not take into account asset criticality or consequence of failure. WELL has developed an Asset Criticality Indicator (ACI) using the same methodology as Asset Health Analysis, incorporating factors such as number of consumers affected, load type and firm capacity. Asset criticality is scored on a scale of I5 (very low impact) to I1 (major impact).

The result of this analysis is a health-criticality matrix for each major asset class, with the asset location on the matrix giving an indication of risk. As an example, the health-criticality matrix for power transformers on the WELL network is shown in Figure 7-2 and further discussed in Section 7.5.2.






Figure 7-2 Health-Criticality Matrix (Power Transformers example)

Each number in the matrix gives the number of assets, be they units or circuits, falling into that particular combination of health and criticality. The highest priority is to address assets in the red area of the matrix. These require work to move them to a lower priority colour. Orange assets are the next priority, and should have work undertaken to move them to a lower priority. Yellow assets are candidates for additional monitoring, maintenance or contingency planning, due to either their health being marginal or their criticality being high. Green assets can continue operating with normal routine maintenance as identified in WELL's maintenance practices.

Projects are identified to either improve the health of an asset, or reduce its criticality. The impact of potential changes to health and/or criticality, whether the result of a project or deterioration in condition, can be clearly shown by the movement of the asset within the matrix.

Accordingly, WELL is progressively moving the assessment of asset fleets to the risk based asset health-criticality framework to provide an objective and prioritised list of needs to be addressed within the planning period. To date the asset classes that have been addressed are:

- Sub transmission cables;
- Zone substation power transformers and tap changers;
- Zone substation switchboards and circuit breakers;
- Poles;
- Distribution transformers,
- Ground-mounted distribution switchgear, and
- Distribution overhead lines.

7.4 Maintenance Practices

7.4.1 Maintenance Standards

WELL currently contracts Northpower as its Field Services Provider to undertake the network maintenance programme under a Field Services Agreement. Maintenance of all assets is undertaken according to standards that have been developed by WELL.

Condition-based risk management of assets is achieved through a well-defined condition assessment and defect identification process that is applied during planned inspection and maintenance activities. The condition information is then fed into the SAP PM maintenance management system by the Field Services Provider and analysed alongside other key network information. This enables WELL to prioritise field data to make efficient and optimised asset replacement decisions and maintain visibility and tracking of maintenance tasks in the field.

Vegetation management is provided by Treescape and is carried out in accordance with WELL policies and the Electricity (Hazards from Trees) Regulations 2003. Under the regulations, tree owners are responsible for maintaining their vegetation to a safe clearance distance. There is a risk that this maintenance does not occur and vegetation related outages may start to increase if tree owners neglect their obligations under the Regulations.

7.4.2 Maintenance Categories

Maintenance is categorised into the following areas:

1. **Service Interruptions and Emergencies.** Work that is undertaken in response to faults or third party incidents and includes equipment repairs following failure or damage, and the contractor management overhead involved in holding resources to ensure appropriate response to faults.
2. **Vegetation Management.** Planned and reactive vegetation work.
3. **Routine and Corrective Maintenance and Inspection.** This comprises:
 - a. **Preventative Maintenance works.** Routine inspections and maintenance, condition assessment and servicing work undertaken on the network. The results of planned inspections, and maintenance, drive corrective maintenance or renewal activities.
 - b. **Corrective Maintenance works.** Work undertaken in response to defects raised from the planned inspection and maintenance activities.
 - c. **Value Added.** Customer services such as cable mark outs, stand over provisions for third party contractors, and provision of asset plans for the 'B4U Dig' programme, to prevent third party damage to underground assets.
4. **Asset Replacement and Renewal.** Reactive repairs and replacements that do not meet the requirements for capitalisation.

The forecast maintenance expenditure for 2018-2028 is summarised by asset class throughout this section.



7.5 Asset Maintenance and Renewal Programmes

This section describes WELL's approach to preventative maintenance and inspections. It also sets out the maintenance activities undertaken for each asset class and commentary is provided on renewal and refurbishment policies or criteria plus known systematic issues. The IDR categories (with their associated asset classes) covered are:

- Sub transmission (Cables);
- Zone Substations;
- Distribution and LV Lines;
- Distribution and LV Cables;
- Distribution Substations and Transformers;
- Distribution Switchgear; and
- Other Network Assets.

The description for each asset class is structured in the following manner:

- A summary of the fleet;
- Maintenance activities relevant to the asset class;
- The condition of the assets;
- The approach to renewals for the class including life extension activities and innovations; and
- The health indices, where these are used.

7.5.1 Sub transmission (Cables)

Fleet Overview

WELL owns approximately 138 km of sub transmission cables operating at 33 kV. These comprise 50 circuits connecting Transpower GXPs to WELL's zone substations. Approximately 32 km of sub transmission cable is of XLPE construction and requires little maintenance. The remainder is of paper-insulated construction, with a significant portion of these cables being relatively old pressurised gas or oil-filled, with either an aluminium or lead sheath. A section of the sub transmission circuits supplying Ira Street zone substation are oil-filled PIAS (paper insulated aluminium sheath) cables rated for 110 kV but operating at 33 kV. The lengths and age profile of this asset class are shown in Figures 7-3 and 7-4.

Construction	Design voltage	Percentage	Quantity
Paper Insulated, Oil Pressurised	33 kV	30%	42km
Paper Insulated, Gas Pressurised	33 kV	33%	46km
Paper Insulated	33 kV	7%	9km
XLPE Insulated	33 kV	23%	32km
Paper Insulated, Oil Pressurised	110 kV	7%	9km
Total			138km

Figure 7-3 Summary of Sub transmission Cables

Note: the 33 kV rated cables that are run at 11 kV are not included in the sub transmission circuit length.




Figure 7-4 Age Profile of Sub transmission Cables

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on sub transmission cables:

Activity	Description	Frequency
Cable sheath tests	Testing of cable sheath and outer servings, continuity of sheath, cross bonding links and sheath voltage limiters.	2 yearly
Sub transmission - cable gas / oil injection equipment inspection	Inspection and minor maintenance of equipment in substations, kiosks and underground chambers.	6 monthly
Sub transmission - regular patrol	Patrol of cable route; replace missing or damaged cable markers.	Weekly

Figure 7-5 Inspection and Routine Maintenance Schedule for Sub transmission Cables

In conjunction with the above routine maintenance schedule, all oil filled and pressurised gas cables have pressure continuously monitored via the centralised SCADA system, with managerial oversight through a monthly reporting process. This monitoring provides information that identifies cables where pressure is reducing and allows the situation to be promptly investigated.

When fluid-filled cables develop a leak, they can usually be dug up and repaired without having to cut the cable. However, when a more serious electrical fault occurs, a new section of cable will be necessary. On some occasions transition joints are made to join the pressurised cables to sections of XLPE cable. These joints are relatively expensive at around \$100,000 each, meaning that to replace even short sections of cable will cost a minimum of \$250,000, making it uneconomic to have a large number of such joints in a single cable. The outcome of this is that where a cable is located in an environment where damage is likely to occur, it is more economical to install a long length of replacement XLPE cable than several short lengths.

One of the key tests is the sheath test, which indicates whether there is damage to the outer sheath and gives an early indication of situations where corrosion or further damage (leading to leaks) may occur, as well as proving the integrity of the earth return path. During 2017, a list of sheath faults were identified by the Field Service Provider for the Gracefield to Korokoro 33 kV cable A and brought to the attention of WELL. These sheath faults have all been programmed for location and repair.

Objective condition assessment on cables with oil or gas pressurisation is difficult and quite limited, as a number of assessment techniques, including partial discharge testing, are not applicable to these types of cables. The main mode of failure of these cables is stress on the joints and resulting failure, as well as sheath failures allowing gas leaks and areas of low pressurisation along the length of the cable. Accordingly, the leaks and the cable can be repaired before the electrical insulation properties are compromised.

The historic fault information for each cable, where known, is used to assess and prioritise the need for cable replacement, as well as determining the strategic spares to be held. Strategic spares for sub transmission cables are outlined in Figure 7-6.

Strategic Spares	
Medium lengths of cable	Medium lengths of oil and gas cable are held in store to allow replacement of short sections following damage, to allow repairs without requiring termination and transition to XLPE cable.
Standard joint fittings	Stock is held to repair standard oil and gas joints. A minimum stock level is maintained.
Termination/transition joints	Two gas to XLPE cable transition joints are held in storage to allow the replacement of damaged sections of gas filled cables with non-pressurised XLPE cables where necessary.

Figure 7-6 Spares for Sub transmission Cables²⁵

Cable Condition and Failure Modes

Gas-filled cables

Gas-filled HV cables have been in use internationally since the 1940s and are still in service in many utilities in New Zealand and Australia. They have proven to perform well when they are installed in benign environments that are not prone to disturbance or damage. WELL, however, has many of its gas-filled cables installed under busy roads in urban environments and through structures such as bridges. Vibration from traffic has been identified as a contributing factor to some mechanical failures. This requires close monitoring of cable performance to manage any deterioration and consequent reduction in levels of service. Some of these cables in particular have been repaired numerous times as a result of third party damage or after gas leaks have been found.

Figure 7-7 shows the monthly gas leakage of the various gas-filled cables in service for 2017. As can be seen, the Evans Bay cable 1 was being regularly topped up with gas throughout the year. A maintenance task has been created for the location, identification and repair of the gas leak on this cable which will be done in 2018. The Nairn St 1 and 2 gas top-up facilities supply a number of cables and thus show a gas usage that is not in line with the actual usage of the two Nairn St cables. The graph also shows the rate of leakage on gas cables in WELL throughout 2017 has remained constant with no significant trends of increasing leakage identified.

²⁵ Section 11 describes additional spare equipment that will be procured under the SPP application which includes 33kV XLPE cable and joint kits.



Monthly Gas Filled Cable Leakage




Figure 7-7 Monthly Gas-filled Cable Leakage (as at January 2018)

Fluid-Filled Cables

Fluid-filled cables were installed in the WELL network from the mid-1960s until 1991. Some circuits, for example Johnsonville in 2012 and Korokoro in 2013, have experienced fluid leaks but in general the condition of the cables remains good for their age. The environmental impacts of leaks have been mitigated through the use of biodegradable cable fluid.

Figure 7-8 depicts the monthly fluid usage of the various fluid-filled cables throughout 2017. As can be seen, most cables which developed fluid leaks have been resolved, including the Johnsonville A cable which required regular topping up with fluid. As noted in Section 7.5.1.5, the leak was identified as occurring at a transition joint and was repaired in early 2018. The joint will be monitored and a complete cable replacement undertaken if required.

Monthly Oil-Filled Cable Fluid Usage




Figure 7-8 Monthly Oil-filled Cable Fluid Usage (as at January 2018)

Paper and Polymeric Cables

Approximately 30% of WELL's sub transmission cable has solid insulation of either oil-impregnated paper or XLPE. These cables are relatively new compared to the fluid-filled installations.

A 33 kV XLPE cable termination failed at Moore Street zone substation in 2014, causing a short outage to key consumers in the Wellington CBD. This termination was subsequently found to be of a particular model that has a reputation in the New Zealand industry for premature failure and is no longer sold. The failed termination was replaced, as were the other 33 kV terminations at the substation and identical terminations at The Terrace zone substation.

During 2015, faults occurred on each of the University circuits. One was the failure of a standard XLPE through joint, while the other was the failure of a gas-to-XLPE transition joint. Dissection of the failed joints, laboratory analysis of the cable insulation, and computer modelling, suggested that the cables have prematurely aged due to heating caused by high currents circulating in the cable screens. The data gathered has been used to provide a conservative estimate of the remaining life in the cable, indicating that the XLPE cable can remain in service until the gas cables become due for replacement, which is expected to be in 2024. To minimise the risk of future failures, a number of additional XLPE joints on the circuits were also proactively replaced.

With the exception of these incidents, the XLPE and paper insulated cables are performing well, and no further renewal is expected to be required during the period covered by this AMP.

Cable Strikes

WELL, like most lines businesses and other utilities, experiences a number of third party strikes on its underground assets each year. These pose a serious risk to health and safety, impact network

performance, and incur a large cost to repair. Unfortunately not all of these third party incidents are identified and reported at the time of the incident, which may lead to future safety and network reliability problems.

To minimise the number of third party strikes, WELL uses the B4U-DIG programme to facilitate the provision of plans to contractors working in the area, with Northpower providing cable mark outs and stand-overs where appropriate. WELL has a focused education campaign for contractors working for large utility companies and local authorities with presentations educating them on the importance of cable location and excavation practices.

In addition, cable maintenance staff patrol the routes of all sub transmission circuits on a weekly basis and note any activities that may impact upon underground services. Where necessary, third party contractors are reminded of the risks associated with working around underground cables.

The B4U-DIG programme has shown positive results by reducing the number of cable strikes experienced per annum as shown in Figure 7-9.




Figure 7-9 Cable Strikes

Renewal and Refurbishment

There are few options for refurbishment or extension of life of sub transmission cables once major leaks, discharge or electrical insulation breakdown has occurred. In most cases the most cost-effective solution is replacement of sections, or the entire length, of cable. Due to the cost of transition joints, it is likely to be more economical to replace sections end to end in their entirety.

Sub transmission Asset Health and Criticality Analysis

The Asset Health Analysis considers the attributes of each sub transmission cable circuit for both health and criticality categories, as shown in Figure 7-10.

Category	Attribute
Health	Sheath Integrity
Health	Leakage History (fluid-filled cables only)
Health	Known Type Issues
Health	Thermal Degradation and Loading History
Health	Partial Discharge (solid insulation only)
Health	Water Trees (XLPE insulation only)
Health	Availability of Parts
Health	Orphan Asset
Health	Repeat Failures
Health	Workforce Skills
Criticality	Primary Load Type (CBD, Industrial, Residential)
Criticality	Number of Consumers Served
Criticality	Bus Configuration at Zone Substation
Criticality	Availability of 11 kV back feeds

Figure 7-10 Categories and Attributes for Sub transmission Cable Circuits

Considering the above attributes for each circuit gives the health-criticality matrix shown in Figure 7-11, with individual circuit scores and ratings being presented in Figure 7-12. Where a circuit comprises multiple cable types, for example a predominantly gas-filled cable that includes a section of XLPE cable, the health indices are calculated independently for each cable type, with the lowest health index governing the AHI of the circuit as a whole.






Figure 7-11 Sub transmission Cable Circuit Health-Criticality Matrix

Sub transmission Circuit	Primary Type	AHI	ACI	Rating
University 1 & 2	Gas/XLPE	1.9	1.7	
Evans Bay 1	Gas	1.1	2.8	
Johnsonville A	Oil	1.6	2.9	
Frederick Street 1 & 2	Gas	2.8	1.3	
Moore Street 1 & 2	XLPE	4.0	1.8	
Terrace 1 & 2	XLPE	5.0	1.8	
Palm Grove 1 & 2	XLPE	5.0	1.6	
Evans Bay 2	Gas	2.5	2.8	
Johnsonville B	Oil	2.6	2.9	
Maidstone A	Gas	2.6	2.9	
Tawa A	Oil	2.7	2.9	
Hataitai 1 & 2	Gas	2.8	2.8	
Ira Street 1 & 2	Gas	2.8	2.9	
Karori 1 & 2	Gas	2.8	2.9	
Kenepuru A & B	Oil	2.8	2.9	
Korokoro A & B	Oil	2.7	2.9	
Porirua A & B	Oil	2.7	2.9	
Tawa B	Oil	2.8	2.9	
Waterloo A & B	Oil	2.8	2.9	
Maidstone B	Gas	2.7	2.9	
Waikowhai A & B	Gas	2.8	2.9	
Brown Owl A & B	Oil	2.8	3.0	
Naenae A & B	Oil	2.8	3.0	
Trentham A & B	Oil	2.7	3.0	
Waitangirua A & B	Oil	2.8	3.0	
Mana	XLPE	4.0	2.9	
Plimmerton	XLPE	4.0	2.9	
Ngauranga A & B	XLPE	4.0	2.8	

Sub transmission Circuit	Primary Type	AHI	ACI	Rating
Gracefield A & B	PILC	4.0	2.9	
Seaview A & B	PILC	4.0	2.9	
Wainuiomata A & B	PILC	4.0	3.0	

Figure 7-12 Health Criticality Scores for Sub transmission Cable Circuits

Outcome of the Asset Health Analysis

The Asset Health Analysis shows that fluid-filled cables rate lower than modern cables on a number of categories, primarily driven by the cost and availability of parts and workforce skills. The highest possible health index for a fluid-filled cable under the AHI method is 2.8, even if it is in perfect physical condition. Accordingly, fluid-filled cables have the highest health based priority for replacement.

The highest priority sub transmission cable circuits, and significant changes since the 2017 AMP, are discussed below.

University

The gas-filled University cables were largely replaced, however approximately 500 metres of gas cable remains in each circuit. These cables have a high criticality due to University Zone Substation supplying a portion of the Wellington CBD.

As discussed earlier, both circuits experienced faults on their XLPE sections during 2015, and analysis of the faults revealed issues around premature ageing of the cable insulation. Full replacement of both the gas-filled and XLPE cables are expected to be required within the next 10 years, and is provisionally planned to occur in 2024.

Korokoro

As previously stated, the Gracefield to Korokoro A cable was reported to have sheath faults in 2017 and has been programmed for location, identification and repair in 2018.

Evans Bay

The Evans Bay sub transmission circuits are old and have low AHI scores but are sufficiently lightly loaded that the Evans Bay load can be temporarily back-fed from neighbouring zone substations through the 11 kV network. Evans Bay zone substation does not appear likely to increase in criticality. There is also uncertainty around the future development of the Mt Victoria road tunnel where the cables presently run.

Analysis during 2015 has shown that the issues at Evans Bay are specifically related to Circuit 1. This circuit has a much higher rate of gas leakage than Circuit 2, resulting in a reassessment of the Circuit 2 AHI. A maintenance task has been created for the location, identification and repair of the gas leak on this cable which will be done in 2018.

Johnsonville

Analysis during 2015 showed that the oil-filled cables on the Johnsonville A circuit were demonstrating a small but consistent rate of fluid leakage. In 2016 this leak was identified as occurring within an area immediately outside the substation at a transition joint which was fixed in 2017. The joint will be monitored after fixing and pending the results, a complete cable replacement may be undertaken.



Tawa

Condition monitoring during 2017 showed that the oil-filled cable on the Tawa A circuit started leaking in August. This leak was identified as occurring within a stop joint in Morgan Place. The joint was excavated in November 2017 and repairs undertaken. The performance of this joint and cable will continue to be monitored.

Titahi Bay

In early 2018 it was identified that an oil-filled cable on the Titahi Bay circuit was demonstrating fluid leakage. A maintenance task has been created for the location, identification and repair of the gas leak on this cable which will be done in 2018.

Frederick Street

The gas-filled Frederick Street cables are in reasonable condition; however their location in the Wellington CBD and capacity constraints as identified in Section 7 gives them a high criticality score. Their health will continue to be monitored through routine maintenance to watch for any deterioration in condition until they are replaced by 2020 for capacity reasons.

Expenditure Summary for Sub transmission Cables

Figure 7-13 details the expected expenditure on sub transmission cables by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Cable Replacement	-	-	-	-	-	875	2,625	-	-	-
Reactive Capital Expenditure	250	250	350	350	300	300	300	300	300	300
Capital Expenditure Total	250	250	350	350	300	1,175	2,925	300	300	300
Preventative Maintenance	116	116	116	116	116	116	114	114	114	114
Asset Renewal and Replacement Opex	308	323	345	366	390	413	432	443	307	400
Operational Expenditure Total	424	439	461	482	506	529	546	557	421	514

Figure 7-13 Expenditure on Sub transmission Cables
(\$K in constant prices)

7.5.2 Zone Substations

7.5.2.1 Zone Substation Transformers and Tap Changers

Fleet Overview

WELL has 52 33/11 kV power transformers in service on the network, and one spare unit. The age profile for zone substation transformers is shown in Figure 7-14.




Figure 7-14 Age Profile of Zone Substation Transformers

The mean age of the transformer fleet is 48 years.

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on zone substation power transformers:

Activity	Description	Frequency
Transformer main tank oil test	Dissolved gas analysis (DGA) testing of transformer main tank oil.	Annually
Transformer tap changer oil test	Dissolved gas analysis (DGA) testing of transformer tap changer oil.	Bi-annually
Transformer oil furan test	Furan analysis of transformer main tank oil.	Annually
Transformer maintenance, protection and AVR test	De-energised transformer maintenance, inspection and testing of transformer, replacement of silica crystals, diagnostic tests as required. Gas injection for testing of Buchholz. Testing of temperature gauge and probe. Confirmation of correct alarms. Test AVR and ensure correct operation and indications.	4 yearly
OLTC maintenance	Programmed maintenance of OLTC ²⁶ .	4 yearly

Figure 7-15 Inspection and Routine Maintenance Schedule for Zone Substation Transformers

Strategic Spares

WELL holds critical spares for the power transformers and tap changers as detailed in Figure 7-16.

²⁶ The frequency of time-based maintenance on tap changers is influenced by the results of the tap changer oil DGA results.

Strategic Spares	
Tap changer fittings	WELL holds a number of critical and maintenance spares for the tap changers on zone substation transformers, typically contacts and related components. These components have high wear and are eroded by arcing during operation. Where excessive wear is noted during maintenance, spares are ordered and held in stock for that model of tap changer. Spares are still available for most models on the network, and if necessary spares can be re-manufactured by third party suppliers.
Transformer misc. fittings	Various other transformer fittings have been identified and held for sites where having a transformer out of service for a prolonged period is unacceptable. Fittings include Buchholz relays, high voltage bushings etc. If major repairs are needed, a unit will be swapped out.
Spare transformers	<p>Historically, WELL has held two spare power transformers. After the earthquake in November of 2016, both spare power transformers were subjected to a number of tests to determine if any damage had been caused. The tests showed that one of the spare units (stored at Wainuiomata Substation) had suffered a core to frame fault which resulted in low insulation levels. The costs to repair this unit have been deemed to be uneconomical and so the unit will be scrapped.</p> <p>Should additional spare transformers be required, one could be taken from any of a number of substations that are lightly loaded with sufficient distribution network back-feed options. These include Gracefield, Tawa and Kenepuru.²⁷</p>

Figure 7-16 Spares Held for Zone Substation Transformers

²⁷ This strategy is to cover normal events and is not able to cater sufficiently for a major earthquake event where transportation links are severed. This is further discussed in Section 11.





Tawa Zone Substation Power Transformer

Transformer Condition

All zone substation transformers are operated within their ratings, are regularly tested, and have had condition assessments undertaken. Where evidence of heating is present, corrective maintenance such as tightening or renewing internal connections outside of the core or tap changer maintenance is undertaken, if economic. The most common issue is mechanical deterioration. Examples include tap changer mechanism wear, contact wear, and similar problems associated with moving machinery. External condition issues include leaking gaskets, fan and cooling system problems and, for outdoor installations, corrosion and weathering of the transformer tanks, especially the tops where water can sometimes pool.

A recent discovery has been the deterioration of barrier boards on Fuller tap changers which has started to manifest on some of the older units in service. This leads to oil migration between tap changer and the main tank. The levels of migration are being monitored via ongoing oil sampling and DGA analysis whilst alternate retrofit and repair options are being investigated.

Oil analysis can provide an estimated Degree of Polymerisation (DP) value for the paper insulation which provides an initial overview of the transformer condition. Furan analysis undertaken with the DGA oil tests in 2009 show the DP of the majority of transformers to be above 450 indicating at least 25 years of remaining life in the insulation. Once a transformer DP reaches 300, a paper sample will be taken to confirm the accuracy of the furan analysis.

In 2016, the tap changer of Frederick Street transformer T1 malfunctioned after tap changer maintenance causing the buchholz relay to trip. This was initially thought to have been caused by a broken mercury switch. A second fault later revealed this was caused by a loosened bolt in the diverter arm resulting in misalignment between the diverter arm and tap contacts. A new diverter arm was provided by the manufacturer and the transformer was put back in service. Diverter arms and bolts and contacts are now

checked in addition to the normal tap changer maintenance. In 2017 the tap changer maintenance approach was reviewed and this has now been updated into the new transformer maintenance standard.

Also in 2017 it was identified that the Wanuiomata T2 had started to show signs of corrosion on the radiators. Fortunately a spare set of radiators had been purchased when the Petone Zone Substation transformers were decommissioned and these radiators are now being investigated as a retrofit option for the Wanuiomata transformer.

Renewal and Refurbishment

Where a transformer is identified for relocation, refurbishment is generally performed if it is economic to do so based on the condition and residual life of the transformer. A non-invasive test to determine the moisture content of the winding insulation is used to inform the assessment of whether a major transformer refurbishment would be economic.

The following projects have been provided for in the asset maintenance and replacement forecasts for the planning period:

- Ongoing preventative maintenance including testing and inspections;
- Transformer replacements at four²⁸ zone substations; and
- Ongoing transformer refurbishment costs.

Based on asset health and criticality, three zone substation transformers can be expected to require replacement during the period 2018 to 2028. All factors considered in the replacement decision-making process are covered in the Asset Health Analysis described below.

In some instances, where a power transformer is approaching, or at, its service half-life, subject to condition assessment results, a refurbishment including mechanical repairs, drying and tightening of the core and associated electrical repairs can be justified. For power transformers in the WELL network the testing and inspection programme will aid in getting the best life from the transformer and also ensure optimal timing for unit replacement.

²⁸ There are 2 transformers catered for at Evans Bay substation for asset health reasons.

There is 1 transformer catered for at Mana substation for asset health reasons.

There are 2 transformers catered for at Palm Grove for capacity reasons (See Section 8).

There are 2 transformers catered for at Ngauranga substation for capacity reasons (See Section 8).



Transformer Asset Health and Criticality Analysis

The Asset Health Analysis considers the attributes of each power transformer for both health and criticality categories, as shown in Figure 7-17.

Category	Attributes
Health	Degree of Polymerisation
Health	Bushing Condition
Health	Mechanical Integrity (i.e. SFRA testing) ²⁹
Health	Insulation System Condition
Health	Known Type or Design Issues
Health	Safety Features
Health	Availability of Parts for OLTC Maintenance
Health	Noise
Health	Workforce Skills
Criticality	Primary Load Type (CBD, Industrial, Residential)
Criticality	Number of Customers Served
Criticality	Bus Configuration at Zone Substation
Criticality	Availability of 11 kV Back feeds
Criticality	Installation Issues, e.g. access restrictions

Figure 7-17 Categories and Attributes for Power Transformers

Applying the above factors to each transformer gives the health-criticality matrix shown in Figure 7-18, with individual transformer scores and ratings being presented in Figure 7-19.

²⁹ Transformer SFRA testing is not currently undertaken by WELL, but will be included in future maintenance activities.




Figure 7-18 Power Transformer Health-Criticality Matrix

Transformer	Substation	AHI	ACI	Rating
Evans Bay T1	Evans Bay	1.2	2.8	
Evans Bay T2	Evans Bay	1.6	2.8	
Mana	Mana-Plimmerton	1.9	2.9	
Frederick Street T1	Frederick Street	2.9	1.3	
Frederick Street T2	Frederick Street	3.0	1.3	
Palm Grove T1 & T2	Palm Grove	3.0	1.6	
University T1	University	3.0	1.7	
Moore Street T2	Moore Street	3.0	1.8	
Terrace T1 & T2	Terrace	4.0	1.3	
University T2	University	4.0	1.7	
Moore Street T1	Moore Street	4.0	1.8	
Brown Owl A	Brown Owl	2.9	3.0	
Brown Owl B	Brown Owl	2.9	3.0	
Gracefield A	Gracefield	2.8	2.9	
Gracefield B	Gracefield	2.9	2.9	
Hataitai T1 & T2	Hataitai	2.9	2.8	
Ira Street T1	Ira Street	3.0	2.9	
Ira Street T2	Ira Street	4.0	2.9	
Johnsonville A & B	Johnsonville	2.8	2.9	
Karori T1	Karori	2.8	2.9	
Karori T2	Karori	2.9	2.9	
Kenepuru A	Kenepuru	4.0	2.9	
Kenepuru B	Kenepuru	3.0	2.9	
Korokoro A	Korokoro	2.9	2.9	
Korokoro B	Korokoro	3.0	2.9	
Maidstone A	Maidstone	3.0	2.9	
Maidstone B	Maidstone	2.9	2.9	
Naenae T1 & T2	Naenae	3.0	3.0	

Transformer	Substation	AHI	ACI	Rating
Ngauranga A	Ngauranga	2.9	2.8	
Ngauranga B	Ngauranga	3.0	2.8	
Plimmerton	Mana-Plimmerton	2.8	2.9	
Porirua A & B	Porirua	2.9	2.9	
Seaview A	Seaview	2.7	2.9	
Seaview B	Seaview	2.9	2.9	
Tawa A	Tawa	2.7	2.9	
Tawa B	Tawa	2.6	2.9	
Trentham A & B	Trentham	2.8	3.0	
Waikowhai T1	Waikowhai	2.8	2.9	
Waikowhai T2	Waikowhai	2.8	2.9	
Wainuiomata A	Wainuiomata	3.0	3.0	
Wainuiomata B	Wainuiomata	4.0	3.0	
Waitangirua A	Waitangirua	3.0	3.0	
Waitangirua B	Waitangirua	2.9	3.0	
Waterloo A & B	Waterloo	3.0	2.9	

Figure 7-19 Health-Criticality Scores for Power Transformers

Outcome of Asset Health and Criticality Analysis

Figure 7-20 shows the health of the power transformer fleet by unit age, against the theoretical trend in health over time. This shows that a large number of units are in better health than would be expected for their age. This is due to a number of factors, particularly the proportion of units located indoors and therefore less vulnerable to corrosion, and loading on transformers being kept below 50% for security reasons. Exceptions to this are noted below.




Figure 7-20 Asset Health vs Age for Power Transformers

Evans Bay

The transformers at Evans Bay were installed in 1959 and have the lowest health indices in the network, as shown in the above graph. These transformers have experienced an increasing number of problems in recent years, mostly relating to the mechanical performance of the tap changer and excessive leaks due to deterioration of valves, flanges, gaskets and radiators. Fortunately to date corrective works have been possible and the transformers returned to service.

The poor mechanical condition of these transformers indicates they are near the end of their life and major repairs to address the issues are not economic. A business case for the replacement of these transformers was approved at the Investment Committee and Board Meetings in 2017 for replacement of these transformers by 2021.

Mana

The Mana transformer is a South Wales unit that was manufactured in 1963 and has exhibited a low estimated DP value based on Furan Analysis of 450. The DGA's on this unit show no concerning signs in terms of combustible gasses, carbon monoxide or carbon dioxide, however acidic content has been on a steady increase over the past years. The unit will be programmed for a paper sample to be removed for a detailed evaluation of remaining life and based on the results the unit will be programmed either for replacement or upgrade. Allowance for this replacement has been made in 2022/23 of this AMP.

Palm Grove

The Palm Grove transformers are in good condition, but have high criticality due to the peak loading and number of consumers supplied by the substation. Their asset health is marked down slightly due to the noise created by their forced cooling and the proximity of residential neighbours. The proposed



development path outlined in Section 8 indicates that most cost effective option to manage the transformer health in the short term is to deload the transformers on the 11 kV system during the 3 days a year that the load exceeds the transformer rating. Section 7 also makes allowance for the transformers to be replaced in 2025. An acoustic wall design will be investigated when the units are upgraded to deal with the noise levels at the substation.

Ngauranga

Ngauranga has two of the oldest power transformers installed in WELL's network. These transformers are generally reliable but have experienced problems with the tap changer diverter switches in the past. These issues will be monitored and corrective repairs undertaken as required. It is expected that replacement due to condition will be required at the end of the planning period, however as identified in Section 8, replacement of the transformers is planned for 2020 due to capacity constraints.

Frederick Street

Frederick Street has a high criticality index due to its location in Wellington CBD and the number of consumers it supplies. The transformers are in good condition, however in early 2014 the DGA results on T1 and T2 indicated elevated levels of ethylene and moisture respectively. In both cases, the absence of other key gases suggested there were no major problems with either unit so the oil was filtered and routine monitoring has continued. Since then moisture has remained at steady levels, but ethylene has started to steadily ramp up again. The tap changers within these units are Ferranti D55's and so are not expected to have the same barrier board degeneration issues as the Fuller ones mentioned previously. The units will be investigated in 2018 to determine the reasons for elevated ethylene levels.

Waikowhai Street

The transformers at Waikowhai Street substation are in good condition. They are fitted with vertical Reinhausen tap changers which are the only two of this kind on the network. These are more difficult to maintain and are refurbished on a 6-8 yearly cycle. The tap changers were last refurbished in 2011 by a Reinhausen technician. In 2017 the tap changers on these units were discovered to have worn switching star contact rollers during their four-year tap changer maintenance. These contact rollers were ordered from Australia and replaced by a Reinhausen technician in late 2017.

University 1

The University transformers are only 29 years old; however University 1 is showing a much lower degree of polymerisation than University 2. This is attributed to a historic loading imbalance which has since been resolved. While the DP result is low it is still indicating an estimated remaining life of 25 years so replacement is not expected to be required within the planning period. The condition of both units will continue to be monitored through the routine maintenance programme.

Expenditure Summary for Power Transformers

Figure 7-21 details the expected expenditure on power transformers by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Evans Bay & Mana Transformer Replacements	-	500	1,500	1,000	1,000	-	-	-	-	-
Capital Expenditure Total	-	500	1,500	1,000	1,000	-	-	-	-	-
Preventative Maintenance	125	105	95	105	100	105	95	105	125	100
Corrective Maintenance	22	24	25	27	29	31	32	35	30	30
Operational Expenditure Total	147	129	120	132	129	136	127	140	155	130

Figure 7-21 Expenditure on Power Transformers (\$K in constant prices)

7.5.2.2 Zone Substation Switchboards and Circuit Breakers

Fleet Overview

11 kV circuit breakers are used in zone substations to control the power injected in to the 11 kV distribution network. The most common single type is Reyrolle Pacific type LMT circuit breakers. There are 368 circuit breakers located at zone substations on the WELL network. An age profile of these circuit breakers is shown in Figure 7-22.




Figure 7-22 Age Profile for Zone Substation Circuit Breakers

The average age of zone substation circuit breakers in the Wellington Network is around 40 years, with the age of individual breakers ranging from relatively new to more than 50 years. The mix of circuit breaker technologies reflects the age of the equipment. Older circuit breakers are oil-filled while newer units have vacuum or SF₆ interrupters. The majority of circuit breakers are still oil-filled and require relatively intensive maintenance regimes.

The use of transformer feeders avoids the need for 33 kV circuit breakers at zone substations. However, there are two 33 kV Nissin KOR oil circuit breakers at Ngauranga which have been in service at this site for approximately 24 years. Originally manufactured in the 1960s, installation was in 1993 when the substation was constructed. There are plans for the decommissioning and removal of these breakers once the communications systems from Takapu Road have been upgraded (as discussed in Chapter 8). Until then, a spare unit has been obtained from Transpower's Upper Hutt Substation when the outdoor breakers were removed as part of the outdoor/ indoor conversion project in 2017.

Category	Quantity
33 kV Circuit Breakers	2
11 kV Circuit Breakers	366

Figure 7-23 Summary of Zone Substation Circuit Breakers

Manufacturer	Breaker Type	Quantity
Nissin	Oil (33 kV)	2
Reyrolle (RPS)	Oil	275
	Vacuum	75
Siemens	SF ₆	16
Total		368

Figure 7-24 Summary of Zone Substation Circuit Breakers by Manufacturer

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on metal clad switchboards and circuit breakers at zone substations:

Activity	Description	Frequency
General Inspection of 33 kV Circuit Breaker	Visual inspection of equipment and condition assessment based upon visible defects. Thermal image of accessible connections. Handheld PD and Ultrasonic scan.	Annually
General Inspection of 11 kV Circuit Breaker	Visual inspection of equipment and condition assessment based upon visible defects. Thermal image of accessible connections. Handheld PD and Ultrasonic scan.	Annually
33 kV Circuit Breaker Maintenance (Oil)	Maintenance of OCB, drain oil, ensure correct mechanical operation, dress or replace contacts as required, undertake minor repairs, refill with clean oil, return to service. Trip timing test before and after service.	4 yearly
11 kV Circuit Breaker Maintenance (Oil)	Withdraw and drain OCB, ensure correct mechanical operation, dress or replace contacts as required, undertake minor repairs, refill with clean oil, return to service. Trip timing test before and after service.	4 yearly
11 kV Circuit Breaker Maintenance (Vacuum or Gas)	Withdraw CB and maintain carriage and mechanisms as required, record condition of interrupter bottles where possible, clean and return to service. Trip timing test before and after service.	4 yearly
11 kV Switchboard Major Maintenance	Full or bus section shutdown, removal of all busbar and chamber access panels, clean and inspect all switchboard fixed portion components, undertake condition and diagnostic tests as required. Maintain VTs and CTs. Return to service.	8 yearly
11 kV Circuit Breaker - Annual Operational Check	Back-feed supply, arrange remote and local operation in conjunction with NCR to ensure correct operation and indication.	Annually
PD Location by External Specialist	External specialist to undertake partial discharge location service.	Annually

Figure 7-25 Inspection and Routine Maintenance Schedule for Zone Substation Circuit Breakers

Strategic Spares

Given the high number of circuit breakers in service on the WELL network, it is important to keep adequate quantities of spares to enable fast repair of defects. The largest quantity of circuit breakers on the network is the Reyrolle type LMT, which is used predominantly at zone substations, and WELL holds large numbers of spares for these circuit breakers. Furthermore, the RPS (formerly Reyrolle Pacific) switchgear factory is located in Petone which means that spares are available within short timeframes if required for LMT type switchgear. An overview of strategic spares held for circuit breakers is shown in Figure 7-26.



Strategic Spares	
Circuit breaker trucks	At least one circuit breaker truck of each rating (or the maximum rating where it is universal fitment) is held for each type of withdrawable circuit breaker on the network.
Trip/Close coils	Spare coils held for each type of circuit breaker and all operating voltages.
Spring charge motors	Spare spring charge motors held for each voltage for the major types of switchgear in service.
Current transformers and primary bars	Where available, spare current transformers and primary bars are held to replace defective units. In particular, 400 A current transformers for Reyrolle LMT are held, as this type of equipment has a known issue with partial discharge.

Figure 7-26 Spare Parts Held for Circuit Breakers

Switchgear Condition

The switchgear installed on the WELL network is generally in very good condition although there is some deterioration of older units. The equipment is installed indoors, has not been exposed to extreme operating conditions and has been well maintained. In some locations, the type of load served, or the known risks with the type of switchgear, means that an enhanced maintenance programme is required whilst a replacement programme has been in place for some older switchgear types, for example Reyrolle Type C.

Examples of poor condition include: partial discharge (particularly around cast resin components), corrosion and compound leaks that are visible externally, slow or worn mechanisms and unacceptable contact wear. The majority of these defects can be easily remedied under corrective maintenance programmes.

The condition of zone substation switchboards is discussed in detail in the circuit breaker health-criticality analysis below.

Renewal and Refurbishment

Based on the condition assessment carried out as part of the preventative maintenance routine, assets are identified for replacement, or targeted inspection and maintenance programmes are put in place to manage risks until replacement is possible. A large number of older circuit breakers are still in service and are in excellent condition due to regular maintenance over their service life. However other older units are showing their age with pitch leaks and failing mechanisms.

Condition, performance, ratings and operational history across the industry are considered when determining when a circuit breaker is replaced. Other drivers that influence the replacement decision include safety, criticality, operability and co-ordination with modern equipment.

The following replacement programmes are in place for the planning period:

Reyrolle Type C

Reyrolle Type C circuit breakers were installed between 1938 and the late 1960s and the majority of units have reached the end of their effective service life. There are 13 units remaining in service at Gracefield zone substation and these are to be replaced by the end of 2018. The replacement Reyrolle LMVP switchgear has been ordered in 2017.

Reyrolle LMT - Partial Discharge (PD)

Reyrolle LMT circuit breakers were installed on the network from late 1960s onwards. There are over 600 units in service on the WELL network.

In the latter part of 2012, a Reyrolle LMT circuit breaker at Waitangirua zone substation was found to have high levels of partial discharge emanating from the CT chamber. This prompted a replacement of the CTs, bushings and pitch-filled cable termination using a specially developed retrofit kit, which lowered the PD to normal levels. Circuit breakers are refurbished using this kit when they are identified as having unacceptable partial discharge levels.

All circuit breakers are surveyed with a handheld partial discharge meter as part of their routine annual general inspection, with zone substation circuit breakers receiving a full partial discharge survey annually from an external specialist. Corrective maintenance is undertaken when high levels of PD are detected. At this stage there do not appear to be any other type issues with LMT.

Circuit Breaker Asset Health and Criticality Analysis

The Asset Health Analysis considers the attributes of each zone substation switchboard for both health and criticality categories, as shown in Figure 7-27.

Category	Attribute
Health	External Condition
Health	Interrupter Life and Operation Count
Health	Insulation Properties
Health	Partial Discharge
Health	Gas/Oil Leaks
Health	Type or Design Issues
Health	Operating History
Health	Availability of Parts and Tools
Health	Orphan Asset
Health	Uncertified Modifications
Health	Workforce Skills
Health	Failure Containment and Operator Safety
Criticality	Primary Load Type (CBD, Industrial, Residential)
Criticality	Number of Customers Served
Criticality	Bus Configuration at Zone Substation
Criticality	Availability of 11 kV Back feeds

Figure 7-27 Categories and Attributes for Zone Substation Switchboards



Considering the above attributes for each zone substation switchboard gives the health-criticality matrix shown in Figure 7-28, with individual switchboard scores and ratings being presented in Figure 7-29.




Figure 7-28 Zone Substation Switchboard Health-Criticality Matrix



11 kV Switchboard	Model	AHI	ACI	Rating
Frederick Street	LM23T	2.0	1.3	
University	LMT	1.9	1.7	
Kaiwharawhara	LMVP	2.0	1.8	
Gracefield	C	1.2	2.9	
Mana	LM23T	1.8	2.9	
Moore Street	LM23T	2.9	1.8	
Nairn Street	LMT	2.9	1.8	
Johnsonville	LM23T	1.8	2.9	
Palm Grove	LMVP	5.0	1.6	
Terrace	NX-PLUS	5.0	1.8	
Brown Owl	LM23T	2.8	3.0	
Evans Bay	LMVP	3.0	2.8	
Hataitai	LM23T	2.9	2.8	
Ira Street	LM23T	2.9	2.9	
Karori	LMVP	5.0	2.9	
Kenepuru	LM23T	2.8	2.9	
Korokoro	LM23T	2.8	2.9	
Maidstone	LM23T	2.8	2.9	
Naenae	LM23T	2.9	3.0	
Ngauranga	LMT	2.9	2.8	
Petone	LM23T	2.9	2.9	
Plimmerton	LM23T	2.8	2.9	
Porirua	LM23T	2.9	2.9	
Seaview	LM23T	2.9	2.9	
Tawa	LM23T	2.9	2.9	
Titahi Bay	LMT	2.9	3.0	
Trentham	LM23T	2.9	3.0	
Waikowhai	LMT	4.0	2.9	
Wainuiomata	LMT	2.9	3.0	
Waitangirua	LM23T	2.9	3.0	
Waterloo	LMT	2.8	2.9	

Figure 7-29 Health-Criticality Scores for Zone Substation Switchboards

Outcome of the Asset Health Analysis

Frederick Street

The Reyrolle LMT switchboard at Frederick Street had PD mitigation work during 2015 and 2016. Initial Transient Earth Voltage (TEV) testing indicated that this work had been successful and though the full PD retesting in 2016 confirmed this, it also showed adjacent circuit breakers with high PD levels that have been masked previously. These are now revealed after mitigation of the higher PD level circuit breakers and further PD mitigation works are planned for these adjacent circuit breakers in early 2018. Apart from the partial discharge issue, the switchboards are in good health but have high criticality due to their location in the Wellington CBD.



University

The Reyrolle LMT switchboard at University had PD mitigation work done in 2016. Similarly to Frederick Street, after full PD retesting adjacent circuit breakers are revealed to also have high PD levels. PD mitigation works are planned for these adjacent circuit breakers in early 2018.

Kaiwharawhara

The Reyrolle LMVP switchboard at Kaiwharawhara has previously given unusual readings during PD testing. It seemed to show intermittent PD that moved around the board. Rather than the annual PD snapshot, continuous monitoring was undertaken to locate the cause. The result of the continuous monitoring in 2017 showed that the PD is originating from the Transpower switchyard and not from the board itself. The switchboard was retested in late 2017 which again showed up PD activity within the CB17 compartment. These results are being evaluated in conjunction with a PD specialist to develop plans to address the circuit breaker in 2018.

Johnsonville

PD testing at this substation in 2017 identified potential issues with CB10 as well as a VT compartment. A maintenance task will be undertaken in 2018 to open, rack out, inspect and test both compartments to determine if the source of PD can be identified.

Gracefield

The Gracefield switchboard is Reyrolle Type C which has multiple design issues and, as noted earlier, is being phased out of the network. Replacement of the Gracefield switchboard commenced in 2017 and is planned for completion in 2018.

Partial Discharge Mitigation

Six other Reyrolle LMT switchboards have circuit breakers with continued plans for PD mitigation during 2018. These are a combination of zone and distribution substations being:

- Zone Substations
 - Mana zone substation.
- Distribution Substations
 - Beehive;
 - Majoribanks Street;
 - 37 Mersey Street;
 - 2 The Terrace; and
 - Wadestown.

Further PD mitigation work will be determined by results of ongoing PD testing. Funding allocation for the associated PD mitigation will be included in future editions of the AMP.

Other Comments

WELL's fleet of zone substation circuit breakers is generally in good condition. Apart from the replacement of the remaining Reyrolle Type C switchboard, and assuming that the partial discharge mitigation refurbishments continue to be successful, no zone substation circuit breakers are expected to require replacement for health reasons during the next five years. During the period 2021-2025, three zone substation switchboards will exceed 60 years of age. There is no indication that replacement of these

switchboards needs to be driven purely by age, however their condition will continue to be monitored through routine inspections and maintenance.

Previously, WELL had planned to conduct switchboard refurbishments which would include PD mitigation works as well as installation of arc fault containment measures on LMT switchboards. A review of the switchboard fleet strategy has led to a change in this approach, due to the availability of leakage to frame protection and the ongoing PD mitigation works of zone sub switchboards which has negated the need for these refurbishments.

Recent switchboard replacements such as Karori, Palm Grove, and Evans Bay zone substations already have internal arc containment built into the switchboard design.

Expenditure Summary for Zone Substation Circuit Breakers

Figure 7-30 details the expected expenditure on zone substation circuit breakers by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Partial Discharge Mitigation	650	250	250	-	-	-	-	-	-	-
Switchboard Replacement	1,250	-	-	-	-	-	-	-	-	-
Reactive Capital Expenditure	50	50	50	50	50	50	50	50	50	50
Capital Expenditure Total	1,950	300	300	50	50	50	50	50	50	50
Preventative Maintenance	138	137	136	136	136	136	136	136	136	136
Corrective Maintenance	21	21	21	21	21	22	22	22	22	22
Operational Expenditure Total	159	158	157	157	157	158	158	158	158	158

Figure 7-30 Expenditure on Zone Substation Switchboards
(\$K in constant prices)





11 kV Circuit Breakers at The Terrace Zone Substation

7.5.2.3 Zone Substation Buildings and Equipment

Fleet Overview

There are 27 zone substation buildings, and three major 11 kV switching station buildings. The buildings are typically standalone, although some in the CBD are close to adjacent buildings or, in the case of The Terrace, located inside a larger customer-owned building.

The age profile of the major substation buildings is shown in Figure 7-31. The average age of the buildings is 46 years. There are five locations where WELL does not own the land under the zone substation and has a long-term lease with the landowner.






Figure 7-31 Age Profile of Major Substation Buildings

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on zone substation buildings and related equipment:

Activity	Description	Frequency
Zone Substation - Routine Inspection	Routine visual inspection of zone substation to ensure asset integrity, safety and security. Record and report defects, undertake minor repairs as required. Thermal inspection of all equipment, handheld PD and Ultrasonic scan. Inspect and maintain oil containment systems, inspect and test transformer pumps and fans.	3 monthly
Grounds maintenance - Lump sum	General programme of grounds and building maintenance for zone substations.	Ongoing
Fire Suppression System Inspection and Maintenance	Inspect, test and maintain fire suppression system (Inergen / gas flood).	3 monthly
Fire Alarm Test	Inspect and test passive fire alarm system.	3 monthly
Fire Extinguisher Check	Inspect and change fire extinguishers as required.	Annually
Test Zone Substation Earthing system	Test zone substation earthing systems.	5 yearly

Figure 7-32 Inspection and Routine Maintenance Schedule for Zone Substations and Equipment



Routine zone substation inspections are undertaken quarterly and include the building and other assets such as lighting, fire systems, security systems, fans, heaters and safety equipment. The grounds and ripple injection spaces are also maintained to ensure access, security, condition and safety. Where appropriate, annual building warrant of fitness inspections are carried out and any defects rectified. Building maintenance varies depending upon the site and minor defects are corrected as they are identified.

Renewal and Refurbishment

The substation building refurbishment programme includes tasks such as roof replacement, exterior and interior painting, security and fencing improvements to maintain the assets in good condition on an as-needed basis.

Given the average age of substation buildings, WELL is approaching a period of increased spend to replace doors, roofs and other building components. Deterioration from the natural elements has resulted in maintenance being uneconomic to address weather tightness issues and these components are replaced in their entirety. This work is critical to ensure ongoing reliability of electrical plant. WELL also considers environmental effects such as heating, cooling and ventilation to ensure network assets are operated within acceptable temperature and humidity levels. Where necessary improvements at substations are undertaken to control the environment in which the plant operates.

WELL completes seismic investigations prior to undertaking any major substation work and this may lead to additional seismic strengthening works. The seismic reinforcing of substation buildings and how this risk is managed is discussed in Section 11.

Expenditure Summary for Zone Substation Buildings

Figure 7-33 details the expected capex expenditure funded via the DPP allowances on zone substation buildings by regulatory year. These are detailed further in Section 11.



Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Seismic Strengthening ³⁰	300	370	-	-	-	-	-	-	-	-
Reactive Capital Expenditure	100	100	200	200	200	200	200	200	200	200
Capital Expenditure Total	400	470	200	200	200	200	200	200	200	200
Preventative Maintenance	30	30	30	30	30	30	30	30	30	30
Corrective Maintenance	120	120	120	120	120	120	120	120	120	120
Operational Expenditure Total	150	150	150	150	150	150	150	150	150	150

Figure 7-33 Expenditure on Zone Substation Buildings
(\$K in constant prices)

7.5.3 Overhead Lines

7.5.3.1 Poles

The total number of poles owned by WELL, including sub transmission distribution lines and low voltage lines, is 39,238. Of this number, 24% are wooden poles and 75.5% are concrete poles. The remaining 0.5% of poles are fibreglass and steel. Another 16,877 poles are owned by other parties but have WELL assets such as crossarms and conductors attached, for example telecommunication poles owned by Chorus, or the poles for the trolley bus network (owned by Wellington Cable Car Limited). A summary of the poles either owned by WELL, or with WELL assets attached, is shown in Figure 7-34.

Pole Owner	Wood	Concrete/Other	Total
WELL	9,457	29,781	39,238
Customer	7,925	1,042	8,967
Chorus	5,586	238	5,824
Wellington Cable Car Limited	1,299	787 ³¹	2,086
Total	24,267	31,848	56,115

Figure 7-34 Summary of Poles

The average age of concrete/ other poles is 27 years. Although the standard asset life for concrete poles is 60 years there are a number of concrete poles that have been in service for longer than this. The average

³⁰ Refer to Figure 6-82 for details of expenditure on seismic strengthening of distribution substations.

³¹ Wellington Cable Car Limited has been using steel poles in their network.



age of wooden poles is around 39 years and nearly 45% of all wooden poles are older than 45 years (the standard asset life of wooden poles). Crossarms are predominantly hardwood.

An age profile of poles owned by WELL is shown in Figure 7-35.




Figure 7-35 Age Profile of Poles

As WELL does not own customer service lines or poles, there is on-going work required to advise consumers of their responsibilities relating to these privately owned lines. Owners are notified of any identified defects or when hazards are identified on consumer owned poles or service lines.

WELL has an interest in customer poles that are considered as works as defined in the Electricity Act 1992. An example is for a pole supplying multiple consumers along a private right of way. Over the course of 2017, WELL has undertaken the inspection of approximately 3,000 privately owned poles at its own cost and is currently undertaking a further review of approximately 3,000 customer owned service poles.

In addition to electricity distribution services, Chorus, Vodafone and CityLink utilise WELL's poles for telephone, cable TV and UFB services.

7.5.3.2 Sub transmission Lines

WELL's 57km of 33 kV sub transmission overhead lines are predominantly AAC conductor on both wood and concrete poles. Overhead line was used for sub transmission in the Hutt Valley and Porirua areas, converting to underground cable at the urban boundary. Sub transmission overhead lines are typically located on rural or sparsely developed land, although they are also in some other locations where difficult access would have made underground cable installation problematic. A summary and age profile of the sub transmission lines are shown in Figure 7-36 and Figure 7-37.

Category	Quantity
33 kV Overhead Line	57km

Figure 7-36 Summary of Sub transmission Lines




Figure 7-37 Age Profile of Sub transmission Line Conductors

7.5.3.3 Distribution and Low Voltage Conductors

Overhead conductors are predominantly aluminium conductor (AAC), with older lines being copper. In some areas aluminium conductor steel reinforced (ACSR) conductors have been used, with these having aluminised steel cores due to the high salt presence in the WELL network area. New line reconstruction utilises all aluminium alloy conductor (AAAC). By early 2018, three projects had been completed to put in sections of covered conductor to mitigate against vegetation encroachment. Most low voltage conductors are PVC covered, and low voltage aerial bundled conductor (LV ABC) has been used in a small number of tree encroachment areas, subject to District Plan allowances. Figure 7-39 shows the age profile of overhead line conductors.

Category	Quantity
11 kV Line	591km
Low Voltage Line	1,085km
Streetlight Conductor	809km

Figure 7-38 Summary of Distribution Overhead Lines




Figure 7-39 Age Profile of Distribution Overhead Line Conductors

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on poles and overhead lines:

Activity	Description	Frequency
Inspection and condition assessment overhead lines by zone/feeder	Visual inspection of all overhead equipment including poles, stay wires, crossarms, insulators, jumpers and connectors, switchgear and transformers. Recording and reporting, and minor repairs as required.	Annually
Concrete, steel pole and composite inspections and testing	Visual inspection of pole, tagging and reporting of results.	5 yearly
Wooden pole inspections and testing (Deuar)	Visual inspection of pole, testing and analysis of pole using Deuar MPT40 test, tagging and reporting of results.	5 yearly
LFI inspections	Visual inspection of line fault passage indicator, testing in accordance with manufacturer recommendation.	Annually
LFI battery replacement	Removal of unit, assessment of condition and replacement of on-board battery, replacement onto live line using hot stick.	8 yearly

Figure 7-40 Inspection and Routine Maintenance Schedule for Poles and Overhead Lines

All overhead lines are programmed for an annual visual inspection to determine any immediately obvious issues with the lines, condition of components such as crossarms and insulators, and to note any prospective vegetation or safety issues. In addition, all connectors in the current carrying path get a thermal scan to identify any high resistance joints which could potentially fail due to heating. These inspections drive a large part of the overhead corrective maintenance works and also contribute to asset replacement programmes for insulators and crossarms.

The replacement of conductor is determined on the lengths of conductor identified as having deteriorated to the agreed criteria for replacement, as a result of annual inspections and analyses. This has historically used visual based criteria and historical failure rates as a starting point. Assessment is moving to using a condition-based replacement profile as more destructive testing results become available and can be used to better assess the actual condition and estimate the remaining life of in-service conductor. A programme of destructive testing of conductor samples taken off the network has been put in place from 2018 onwards to determine the remaining life based on tensile strength, ductility and level of corrosion. Initial work from destructive testing indicates that expected maximum practical life of conductor (both copper and aluminium) is in the order of 92 years, as shown in Figure 7-42.




Figure 7-41 Historical Failure Rates of Connectors and Conductor on Overhead Lines






Figure 7-42 Preliminary Data on the Degradation Rates of Overhead Conductor

Pole Condition

WELL has been using the Deuar MPT40 to test its wooden pole population since 2011. The testing programme ensures the detection of structural issues along the length of the pole, including below ground level, and also provides useful remaining life indicators. Approximately 2,000 poles are Deuar tested every year.

The majority of poles on the WELL network are in good condition as the result of a large scale testing and replacement programme, which occurred between 2004 and 2006. Over two thirds of the poles installed in the Wellington area are concrete, which are durable and in good condition. The remainder are timber poles, which are tested and replaced in accordance with their Deuar serviceability index results or where there are visible structural defects.

Common condition issues with timber poles are deterioration of pole strength due to internal or external decay. Poles which are leaning, have head splits or incur third party damage, which may necessitate pole remediation or replacement.

Common condition issues with concrete poles include cracks, spalling (loss of concrete mass due to corrosion of the reinforcing steel), leaning poles and third party damage.

A significant contributor to leaning poles on the Wellington network is third party attachments. There are existing agreements to support telecommunications cables from Vodafone and Chorus on network poles. WELL has a standard that governs third party attachments to network poles. This standard will ensure future connections to poles for telecommunications infrastructure meet WELL's requirements and do not have an injurious effect on the network or the safety of contractors and members of the public. Third party network operators are required to contribute to the upgrade of network poles where there will be an

adverse impact on pole service life or safe working load as the result of additional infrastructure connections.

Typically the degradation rates for an asset fleet are derived from the historical evidence showing the rate at which assets trend from 100% health when new to 0% at end of life. The health curves for poles, utilised for forecasting future replacement quantities, have been based on the information available from testing already completed (including estimated remaining lives) and rates of tagged poles by age group. The results of this analysis are shown in Figure 7-43 showing the probability of a wood pole being tagged by age group.




Figure 7-43 Probability of a Wood Pole Being Tagged by Age

Figure 7-45 shows the health-criticality matrix of WELL's fleet of poles. Pole asset health is determined solely by the unit's condition ranking, while asset criticality is determined by the voltage of the lines connected to the pole and the number of consumers that they supply.



		Asset Criticality							
		Lowest Impact					Highest Impact		
		5.0	4.0	3.0	2.5	2.0	1.5	1.0	
Asset Health	Worst Health	1.0	18	6	10	7	-	-	-
	1.5	-	-	-	-	-	-	-	
	2.0	538	151	130	62	1	1	-	
	2.5	-	-	-	-	-	-	-	
	3.0	10,306	2,289	2,589	736	22	48	-	
	4.0	5,592	780	1,156	426	2	16	-	
	Best Health	5.0	4,931	1,003	1,174	450	-	4	-

Figure 7-45 Pole Health-Criticality Matrix

Overhead Line Condition

Pin type insulators are no longer used for new 33 kV or 11 kV line construction as they develop reliability issues later in life such as split insulators due to pin corrosion, or leaning on crossarms due to the bending moment on the pin causing the cross arm hole to wear. There is no programme to proactively replace existing pin type insulators but replacement occurs when defects are identified or when crossarms require replacement. All new insulators are of the solid core post type as these do not suffer the same modes of failure as pin insulators, and provide a higher level of reliability in polluted environments and lightning prone areas.

High wind loadings can sometimes result in fatigue failures around line hardware such as binders, compression sleeves, line guards and armour rods on the older AAC lines that have historically been used on the Wellington network. A number of Fargo sleeve type automatic line splices have failed in service. These sleeves were only suitable for a temporary repair. The failure mode for Fargo sleeves is likely to be vibration related and can cause feeder faults (when exposed to high vibrations). Fargo sleeves are no longer used on the network and are replaced with full tension compression sleeves. Alternatively the span will be re-conducted if the joints are not suitably located for replacement.

Failure modes and effect analysis undertaken in 2016 and 2017 have shown that most of the failures classified as conductor failures were actually connector failures. This has resulted in an extensive review of the connector fleet installed on the overhead network. The result of this review is a deeper understanding of the rate of ageing that has occurred on connectors within the WELL network. The increased rate of ageing due to the proximity of overhead circuits to marine salt pollutants has resulted in a planned programme of connector replacements.

Renewal and Refurbishment - Poles

Wooden poles that are Deuar tested and fail the serviceability test are categorised as red tagged or yellow tagged. Red tagged poles have a serviceability index of less than 0.5 (to allow for a design safety factor of two), or have a major structural defect, and are programmed for replacement within three months. Yellow tagged poles have a serviceability index of 0.5 to 1.0, or have moderate structural defects, and are programmed for replacement within 12 months. Blue tags are used to identify poles that have a reduced

ability to support design loads but a serviceability index greater than 1.0 with these poles to have further engineering investigation within three months. For all pole tag colours the climbing of tagged poles by contractors is prohibited.

Concrete poles are replaced following an unsatisfactory visual inspection. The main replacement criteria are poles with large cracks, structural defects, spalling or loss of concrete mass. The severity of the defects determines whether the pole is given a red or yellow tag for replacement within three and 12 months respectively.

All replacement poles are concrete except where the location requires the use of timber for weight, access constraints or loading design. Poles on walkways and hard to reach areas are normally replaced with light softwood poles because they can be carried in by hand. Cranes are used where practicable but have limited reach in some areas of Wellington. WELL does not normally favour the use of helicopters in erecting poles due to the cost and the need to evacuate residents around the pole location. Composite poles are currently being trialled as a possible alternative to softwood poles in hand-carry situations.

Renewal and Refurbishment – Lines

Since 2009, WELL has invested in renewal of overhead lines in areas that have particularly high SAIDI and SAIFI or to address public safety concerns. Areas of Newlands, Johnsonville, Wainuiomata and Korokoro have been progressively reconductored, and have had all the line hardware, crossarms and poor condition poles replaced. These feeders have had a significant improvement in performance since this work was completed.

A general programme of conductor replacement, targeting conductors based on age, type and location, will be required from 2019 onwards.



Expenditure Summary for Overhead Lines

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Reliability Improvement Projects	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Pole Replacement Programme	6,500	6,100	5,900	5,900	5,900	5,900	5,900	5,900	5,900	5,900
Conductor Replacement Programme	-	109	310	122	131	25	675	2,217	1,101	1,847
Area Rebuild Projects	-	-	-	-	500	900	900	1,800	1,800	1,800
Reactive Capital Expenditure	500	500	500	500	1,000	1,000	1,000	1,000	1,000	1,000
Capital Expenditure Total	9,610	8,219	8,735	8,052	9,181	9,183	9,438	11,886	10,770	11,516
Preventative Maintenance	441	439	437	434	433	431	429	428	427	428
Corrective Maintenance	832	824	763	764	858	866	874	880	880	880
Operational Expenditure Total	1,273	1,263	1,200	1,198	1,291	1,297	1,303	1,308	1,307	1,308

Figure 7-46 Expenditure on Overhead Lines
(\$K in constant prices)

7.5.4 Distribution and LV Cables

Fleet Overview

WELL's network has a high percentage of underground cables, which has contributed to a historically high level of reliability during weather-related events but does increase the risk of third party strikes during underground construction work.

Wellington CBD is operated in a closed primary ring configuration with short, normally open radial feeders interconnecting neighbouring rings or zone substations. This part of the network uses automatically operating circuit breakers, with differential protection on cables between distribution substations, rather than manually operated ring main switches between switching zones. This results in higher reliability as smaller sections of network are affected by cable faults. However due to the nature of the CBD, any repairs required to the distribution system take considerably longer than standard replacement times. CBD repairs also incur considerable costs for traffic management and road surface or pavement reinstatement.

Outside the Wellington CBD, the 11 kV underground distribution system has normally open interconnections between radial feeders, and feeders are segmented into small switching zones using locally operated ring main switches. In the event of a cable fault, the faulted cable section can be isolated and supply to downstream consumers can be switched to neighbouring feeders.

Category	Quantity
11 kV cable (incl. risers)	1,165km
Low Voltage cable (incl. risers)	1,669km
Streetlight cable	1,091km

Figure 7-47 Summary of Distribution Cables

Approximately 89% of the underground 11 kV cables are PILC and PIAS and the remaining 11% are newer XLPE insulated cables. The majority of low voltage cables are PILC or PVC insulated and a much smaller number are newer XLPE insulated cables.

An age profile of distribution cables of both voltages is shown in Figure 7-48.




Figure 7-48 Age Profile of Distribution Cables

Maintenance Activities

Maintenance of the underground distribution cable network is limited to visual inspection and thermal imaging of cable terminations. Cables are operated to failure and then either repaired or sections replaced. A proactive maintenance regime has not been considered cost effective, given the network is generally designed so that supply can be maintained while cable repairs are undertaken. Cables are replaced when their condition has deteriorated to the point where repair is not considered economic.

Research in 2017 has resulted in a condition monitoring programme being scheduled from 2018 onwards. Allowance has been made in this AMP to begin a preventative maintenance programme using partial

discharge testing. These test results will be used to develop a condition profile of the cable fleet with approximately 400 cable segments scheduled to be done annually.

Distribution Cable Condition

Underground cables usually have a long life and high reliability as they are not subjected to environmental hazards however, as these cables age, performance is seen to decrease. External influences such as third party strikes, inadvertent overloading, or even rapid increases in load within normal ratings can reduce the service life of a cable. Some instances of failure are due to workmanship on newer joints and terminations (which can be addressed through training and education), whilst others are due to age, environment or external strikes (which are less controllable).

In 2017/2018 there has been a noticeable increase in the number of cable related failures. The ultimate cause of the increase in cable faults cannot be proven, however it is likely to be due to damage caused by the November 2016 earthquake, progressing to failure during the wet winter in 2017. This follows a similar trend to that experienced by Orion following the 2010/2011 Christchurch earthquakes.

Renewal and Refurbishment

The decision to replace rather than repair a cable is based on a combination of fault history and frequency, together with the results of tests undertaken after earlier cable fault repairs. An annual budget allowance is made for cable replacement, targeted at cables exhibiting high fault rates or showing poor test results following a repair. Recent issues highlight the effect of fault stresses on older joints and the need to overlay sections of cables due to repeat joint failures. The small numbers of natural polyurethane insulated cables show high failure rates and this type of cable is therefore more likely to be replaced following a cable fault. A further allowance is made in the CAPEX programme for cable replacement based upon historic trends and known defects and this allowance is expected to ramp up towards the end of the planning period.

Cable termination replacement is driven by visual inspection when signs of discharge or significant compound leaks are found as well as analysis of fault rates. The exception to this is 11 kV cast metal pothead terminations where analysis of fault rates, together with a risk assessment, has resulted in a decision to replace them with heat shrink terminations.

Expenditure Summary for Distribution and LV Cable

Figure 7-49 details the expected expenditure on distribution and LV cable by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Asset Replacement and Renewal Capex	-	-	-	-	2,500	2,500	3,000	3,500	4,500	6,000
Reactive Capital Expenditure	200	200	250	250	250	250	250	250	250	250
Capital Expenditure Total	200	200	250	250	2,750	2,750	3,250	3,750	4,750	6,250
Preventative Maintenance (PD Testing)	200	200	200	200	200	200	200	200	200	200
ARR Opex	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Corrective Maintenance	169	175	181	187	194	200	207	215	222	222
Operational Expenditure Total	1,369	1,375	1,381	1,387	1,394	1,400	1,407	1,415	1,422	1,422

Figure 7-49 Expenditure on Distribution and LV Cable
(\$K in constant prices)

7.5.5 Distribution Substations

7.5.5.1 Distribution Transformers

Fleet Overview

Of the distribution transformer population, 58% are ground mounted and the remaining 42% are pole mounted. The pole mounted units are installed on single and double pole structures and are predominantly three phase units rated between 10 and 200 kVA. The ground-mounted units are three phase units rated between 100 and 1,500 kVA. WELL holds a variety of spare distribution transformers to allow for quick replacement following an in-service failure. The design life of a distribution transformer is 45 years although in indoor environments a longer life may be achieved. In some outdoor environments, particularly where exposed to sea salt spray, a transformer may not reach this age due to corrosion. The age profile of distribution transformers is shown in Figure 7-50.






Figure 7-50 Age Profile of Distribution Transformers

In addition to pole and integral pad mount berm substations, WELL owns 509 indoor substation kiosks and occupies a further 677 sites that are customer owned (typically of masonry or block construction or outdoor enclosures). A summary of WELL’s distribution transformers and substations is shown in Figure 7-51.

Category	Quantity
Distribution transformers	4,367
WELL owned substations	3,662
Customer owned substations	677
Distribution substations – Total	4,339

Figure 7-51 Summary of Distribution Transformers and Substations

Maintenance Activities

The following routine planned inspection and maintenance activities are undertaken on distribution substations and associated equipment:

Activity	Description	Frequency
Inspection of Distribution Substations	Routine inspection of distribution substations to ensure asset integrity, security and safety. Record and report defects, undertake minor repairs as required. Record MDIs where fitted.	Annually
Grounds maintenance	General programme of ground and building maintenance for distribution substations.	Ongoing
Fire Alarm Test	Inspect and test passive fire alarm systems.	3 monthly
Visual Inspection and Thermal Image (Ground Mount Transformer)	Visual inspection of equipment, and condition assessment based upon visible defects. Thermal image of accessible connections. Handheld PD and Ultrasonic scan.	Annual
Visual Inspection and Thermal Image (Pole Transformer)	Visual inspection of equipment, and condition assessment based upon visible defects. Thermal image of accessible connections.	Annual
Inspection and Testing of Earthing	Visual inspection of earthing system installation and mechanical protection, testing of individual and combined earth bank resistance.	5 yearly

Figure 7-52 Inspection and Routine Maintenance Schedule for Distribution Transformers

Distribution Transformer Condition

Figure 7-53 shows the health-criticality matrix of WELL's fleet of distribution transformers, including both pole-mounted and ground-mounted units. Distribution transformer asset health is comprised of type issues and the unit's condition ranking, while asset criticality is determined by the number and type of consumers connected to the transformer.

		Asset Criticality						
		Lowest Impact				Highest Impact		
		5.0	4.0	3.0	2.5	2.0	1.5	1.0
Worst Health	1.0							
	2.0	2	7	15	5	2	2	
	3.0	275	598	1,243	325	301	222	
	4.0	232	294	463	154	64	32	
Best Health	5.0							

Figure 7-53 Distribution Transformer Health-Criticality Matrix

Type issues that have been identified with the fleet of distribution transformers are as follows.

Internal Bushing Transformers

Ground-mounted transformers manufactured by Bonar Long, Bryce and ASEA were installed between 1946 and 1980, with 50 such units currently in service. Many of these transformers have internal 11 kV



bushings, with cambric cables being terminated inside the transformer tank. This does not pose a problem during normal operation, however if the switchgear at the site requires replacement, then the cables and hence the transformer will also need to be replaced.

Pole-mounted Transformers

Analysis of transformer faults indicate that transformers between 25 and 40 years old have been failing at a greater rate than those between 40 and 60 years. It is suspected that these premature failures may be potentially due to modern transformers having more optimised designs than older units. Given the low cost of pole-mounted transformers and the small area impacted by a single failure, no further action is planned at this stage to address the issue.

Renewal and Refurbishment

If a distribution transformer is found to be in an unsatisfactory condition during its regular inspection, it is programmed for corrective maintenance or replacement. In-service transformer failure is rare and is investigated to determine the cause. This assessment determines if the unit is repaired, refurbished, or scraped depending on cost and residual life of the unit. Typical condition issues include rust, heavy oil leaks, integrity and security of the unit. Some minor issues such as paint, spot rust and small leaks are repaired and the unit will be returned to service on the network. The refurbishment and replacement of transformers is an ongoing programme, which is provided for in the asset maintenance and replacement forecast, driven by condition.

In addition to the transformer unit itself, the substation structures and associated fittings are inspected and replaced as needed. Examples include distribution earthing, substation canopies and kiosk building components (such as weather tightness improvements). Some renewals may be costly and time consuming as a large number of berm substations in the Hutt Valley area are an integral substation unit manufactured during the 1970s and 1980s by the likes of Tolley Industries. Replacement of these units requires complete foundation replacement and extensive cable works. Consideration was given to developing a compatible replacement, and a prototype unit installed, however it was found that the reduced civil cost was offset by the additional cost for purchasing a specialised transformer rather than a standard design.

WELL uses canopy type substations with independent components (LV switchgear, HV switchgear and transformer under an arc-fault rated metal canopy) for new installations where practicable, however cost and space constraints often mean integral substations are still used. The benefit of a canopy type substation is that it allows for component replacement or upgrade, or canopy replacement without affecting the entire installation.



Expenditure Summary for Distribution Substations

Figure 7-54 details the expected expenditure on distribution substations by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Seismic Strengthening	1,020	1,760	1,010	470	600	-	-	-	-	-
Earthing Upgrades	300	300	300	300	300	300	300	300	300	300
Lock Replacement	200	200	200	200	200	200	200	200	200	200
Asset Replacement and Renewal Capex	1,100	1,100	1,300	2,000	1,625	2,500	2,500	2,500	2,500	2,500
Reactive Capital Expenditure	500	500	500	500	500	500	500	500	500	500
Capital Expenditure Total	3,120	3,860	3,310	3,470	3,225	3,500	3,500	3,500	3,500	3,500
ARR Opex	130	130	130	130	130	130	130	130	130	130
Preventative Maintenance	435	435	435	435	435	435	435	435	435	435
Corrective Maintenance	938	940	937	980	977	974	971	968	968	968
Operational Expenditure Total	1,503	1,505	1,502	1,545	1,542	1,539	1,536	1,533	1,533	1,533

Figure 7-54 Expenditure on Distribution Substations
(\$K in constant prices)





Anti-graffiti Mural on Kiosk Distribution Substation

7.5.6 Ground Mounted Distribution Switchgear

Fleet Overview

This section covers ring main units and switching equipment that are often installed outdoors. It does not include zone substation circuit breakers, which were discussed in Section 7.5.2. There are 1,252 distribution circuit breakers and 2,413 other ground-mounted switches in the WELL network.

11 kV circuit breakers are used in the 11 kV distribution network to increase the reliability of supply in priority areas such as in and around the CBD. Other ground-mounted switches include fuse switches for the protection of distribution transformers, and load break switches to allow isolation and reconfiguration of components on the network, often with multiple switches combined in a single ring main unit.

The age profiles of distribution circuit breakers and ground-mounted switchgear are shown in Figure 7-55 and Figure 7-56.



11kV Switchgear Replacement at 541 Hebden Crescent Substation




Figure 7-55 Age Profile for Distribution Circuit Breakers




Figure 7-56 Age Profile of Other Ground Mounted Distribution Switchgear

The average age of distribution circuit breakers in the network is around 32 years, while the average age of ring main units is 29 years. A summary of circuit breakers and ground mounted distribution switchgear, of both stand-alone and ring main unit types, is shown in Figure 7-57 and Figure 7-58.

Category ³²	Quantity
Distribution Circuit Breakers	1,252
Oil Insulated Switches	445
Oil Insulated RMUs	196
SF ₆ Insulated Switches	97
SF ₆ Insulated RMUs	646
Solid Insulated RMUs	1,029

Figure 7-57 Summary of Ground Mounted Distribution Switchgear

³² There is a switchgear reclassification which contributed to the changes in quantities.

Manufacturer	Breaker Type	Quantity
ABB	SF ₆	27
AEI	Oil	67
BTH	Oil	49
Crompton Parkinson	Oil	1
GEC/Alstom	Oil	63
Hawker Siddeley	Vacuum	21
Merlin Gerin / Schneider	SF ₆	261
	Vacuum	2
Reyrolle	Oil	639
	Vacuum	56
South Wales	SF ₆	37
Statter	Oil	26 ³³
Total		1,249

Figure 7-58 Summary of Distribution Circuit Breakers by Manufacturer

Maintenance Activities

The following routine planned inspection and maintenance activities are undertaken on ground mounted distribution switchgear and associated equipment:

³³ This is for circuit breakers only and excludes the HV switches and ring main units.



Activity	Description	Frequency
Visual Inspection of Switchgear	Visual inspection of equipment, and condition assessment based upon visible defects. Thermal image of accessible connections. Handheld PD and Ultrasonic scan.	Annually
Switchgear Maintenance (Magnefix)	Clean and maintain Magnefix unit, inspect and replace link caps as required, test fuses, check terminations where possible.	5 yearly
Circuit Breaker Maintenance (Oil CB)	Withdraw and drain OCB, ensure correct mechanical operation, dress or replace contacts as required, undertake minor repairs, refill with clean oil, return to service. Trip timing test before and after service	5 yearly
Switch Maintenance (Oil Switch)	Clean and maintain oil switch unit, drain oil and check internally, check terminations and cable compartments. Ensure correct operation of unit. Refill with clean oil.	5 yearly
Circuit Breaker Maintenance (Vacuum or Gas CB)	Withdraw CB and maintain carriage and mechanisms as required, record condition of interrupter bottles where possible, clean and return to service. Trip timing test before and after service	5 yearly
Switch Maintenance (Vacuum or Gas Switch)	Clean and maintain switch unit, check terminations and cable compartments. Ensure correct operation of unit. Check gas / vacuum levels.	5 yearly
11 kV Switchboard Major Maintenance	Full or bus section shutdown, removal of all busbar and chamber access panels, clean and inspect all switchboard fixed portion components, undertake condition and diagnostic tests as required. Maintain VTs and CTs. Return to service	10 yearly

Figure 7-59 Inspection and Routine Maintenance Schedule for Distribution Switchgear

Distribution Switchgear Condition

The switchgear installed on the WELL network is generally in good condition and comprises both oil and gas insulated ring main units, as well as solid resin insulated equipment. Routine maintenance addresses the majority of minor defects but, a unit requires replacement when the condition deteriorates to a point that is no longer cost effective to repair. Common condition issues experienced include mechanical wear of both the enclosure/body as well as operating mechanisms, electrical discharge issues or poor oil condition and insulation levels.

Figure 7-60 shows the health-criticality matrix of WELL's fleet of ground-mounted distribution switchgear. Distribution switchgear asset health is comprised of type issues and the unit's condition ranking, while asset criticality is determined by the 11 kV feeder that the unit is connected to.

		Asset Criticality							
		Lowest Impact					Highest Impact		
		5.0	4.0	3.0	2.5	2.0	1.5	1.0	
Asset Health	Worst Health	1.0	15	18	63	12	-	-	-
	1.5	62	195	526	160	48	85	-	
	2.0	9	25	69	19	8	11	-	
	2.5	46	33	117	44	120	67	-	
	3.0	84	87	442	68	429	215	-	
	4.0	19	25	85	15	54	40	-	
	Best Health	5.0	19	13	59	19	9	13	-

Figure 7-60 Distribution Switchgear Health-Criticality Matrix

Specific condition issues for distribution switchgear are:

Solid Insulation Magnefix

Magnefix switchgear is cleaned five-yearly, with targeted cleaning for a number of sites undertaken more frequently as a corrective maintenance activity. Magnefix switchgear is generally reliable however there are specific cleaning requirements to avoid tracking problems associated with the resin body casing due to the accumulation of dust and other deposits (such as blown salt and diesel fumes).

There have been past experiences of Magnefix failures on the network due to a termination failure. It is believed that the “Figure 8” connectors on some older units (typically installed between 1968 and 1975) fail under heavy loads due to heating and thermo-mechanical cycling problems. The failures all occurred on residential feeders with recent load growth and during the winter evening peak. A survey of older units has shown a number with low or leaking termination grease levels, which may be a physical sign of heating in the connector. These units are prioritised for topping up of grease levels within the termination cable boxes.

Yorkshire SO-HI

Yorkshire SO-HI circuit breakers were installed during the 1970s and 1980s in indoor kiosk type substations. SO-HI switchgear has a history of failing in service, and in 2011 WELL initiated a replacement programme for the SO-HI units, commencing with sites identified as having a high consequence of failure. This programme was completed in 2017 and all SO-HI units have been removed from the system.

Long and Crawford

As at October 2017, there are 25 Long and Crawford ring main units in service, installed between 1960 and 1996. These are installed in outdoor cage substations often subject to harsh environments. Other networks have experienced catastrophic failures of Long and Crawford fuse switches. WELL has imposed operational restrictions on Long and Crawford fuse switches to prevent the fuse compartments being opened while the switchgear is alive, and a programme to replace Long and Crawford commenced in 2016, for completion by 2022.



Statter

As at October 2017, there are 64 sites with Statter switchgear, with 155 units in service including circuit breakers, oil switches and fuse switches, installed between 1955 and 1991.

In recent years, there have been instances where Statter switchgear has failed to operate requiring operating restrictions to be in place until the unit is repaired or replaced. Statter switchgear is at the end of its useful service life and is becoming difficult to keep in service due to a lack of spares.

The majority of Statter installations do not have protective elements enabled or remote control on the circuit breakers. The units can be replaced with conventional ring main units without causing a decrease in network reliability. In a few cases, the units have full protection and control, and are located on feeders with high cumulative SAIDI. These will be replaced with modular secondary class circuit breakers to maintain reliability levels. There is an ongoing programme for the replacement of Statter switchgear which is scheduled for completion in 2022.

Renewal and Refurbishment

HV Distribution Switchgear (Ground Mounted)

Note – This section excludes zone substation circuit breakers, which are discussed in Section 7.5.2.3.

Any minor defects or maintenance issues are addressed on-site during inspections. This may include such maintenance as topping up oil reservoirs, replacing bolts, rust treatment and paint repairs. Major issues that cannot be addressed on site usually result in replacement of the device. In addition to previously identified programmes for replacing specific switchgear, WELL has an ongoing refurbishment and replacement programme for other ground mounted distribution switchgear.

Oil insulated switchgear is no longer installed with vacuum or gas (SF6) insulated types now being used³⁴. In rare cases, when any switchgear device fails, the reason for the failure is studied and cost benefit analysis undertaken to determine whether to repair, refurbish, replace, or decommission the device. The maintenance policies for other devices of the same type are also reviewed. As noted above, there are several types of ring main switch with identified issues around age, condition and known operational issues. These are being replaced based on the risk assessment for that type.

Low Voltage Distribution Switchgear (Substation)

Low voltage distribution switchgear and fusing is maintained as part of routine substation maintenance and any issues arising are dealt with at the time. The Wellington City area has a large number of open LV distribution boards in substations and a safety programme to cover these with clear Perspex covers has been completed.

In early 2016 a safety alert was issued to contractors prohibiting live work between the transformer bushings and the low voltage busbars, and work in situations where items may contact live busbars. This has been followed up with further work to detail an arc flash PPE policy which was published in 2017. This policy will be reviewed in 2018 to align to the Arc Flash Guideline published by the EEA.

³⁴ Newer solid insulation switchgear is also being trialled on the network as a future option for approval.

The overall performance of LV distribution switchgear and fusing is good and there are no programmes underway to replace this equipment.

Expenditure Summary for Ground-mounted Switchgear

Figure 7-61 details the expected expenditure on ground-mounted switchgear by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Long and Crawford Replacement Programme	690	630	630	473	-	-	-	-	-	-
Statter Replacement Programme	1,000	1,000	1,125	1,000	-	-	-	-	-	-
Other Asset Replacement and Renewal Capex	525	310	245	245	1,500	2,500	3,000	3,000	3,000	3,000
Reactive Capital Expenditure	450	450	650	650	650	650	650	650	650	650
Capital Expenditure Total	2,665	2,390	2,650	2,368	2,150	3,150	3,650	3,650	3,650	3,650
ARR Opex	130	130	130	130	130	130	130	130	130	130
Preventative Maintenance	600	600	600	600	600	600	600	600	600	600
Corrective Maintenance	413	404	395	387	379	370	362	354	353	353
Operational Expenditure Total	1,143	1,134	1,125	1,117	1,109	1,100	1,092	1,084	1,083	1,083

Figure 7-61 Expenditure on Ground-mounted Switchgear
(\$K in constant prices)

7.5.6.1 Low Voltage Pits and Pillars

Fleet Overview

Pillars and pits provide the point for the connection of customer service cables to the WELL underground LV reticulation. They contain the fuses necessary to isolate a service cable from the network. Pits are manufactured from polyethylene, as are most of the newer pillars. Earlier style pillars were constructed of concrete pipe, steel or aluminium. There are 505³⁵ link pillars, pits and cabinets in service on WELL's network. These are used to parallel adjacent LV circuits to provide back feeds during outages, as well as providing the ability to sectionalise large LV circuits. A high-level breakdown of types is listed in Figure 7-62.

³⁵ Reclassification of link pillars, pits and cabinets has been undertaken.

Type	Quantity
Customer service pillar	8,989
Customer service pit	2,016
Link pillars, pits and cabinets	505
Total	11,510

Figure 7-62 Summary of LV Pillars and Pits

An age profile of pillars and pits is shown in Figure 7-63.




Figure 7-63 Age Profile of Pillars, Pillars and Cabinets

Maintenance Activities

The following routine planned inspection and maintenance activities are undertaken on low voltage pits and pillars, for either consumer service connection and fusing or network LV linking:

Activity	Description	Frequency
Inspection of Service Pillars	Visual inspection and condition assessment of service pillar, minor repairs to lid as required.	5 yearly
Inspection of Service Pits	Visual inspection and condition assessment of service pit, minor repairs as required.	5 yearly
Inspection of Link Pillars	Visual inspection and condition assessment of link pillar, thermal imaging and minor repairs as required.	5 yearly
U/G link box inspection including Thermal Image	Visual inspection and condition assessment of link box, thermal imaging and minor repairs as required.	5 yearly

Figure 7-64 Inspection and Routine Maintenance Schedule for LV Pits and Pillars

WELL includes a loop impedance test to check the condition of the connections from the fuses to the source in its underground pillars inspection regime. Where practical, damaged pillars are repaired but otherwise a new pillar or a pit is installed.

Renewal and Refurbishment

Pillars are generally replaced following faults or reports of damage. Pillars with a high likelihood of future repeat damage by vehicles are replaced with pits. When large groups of older pillars, such as concrete or 'mushroom' type, are located and their overall condition is poor they are replaced as repair is impractical or uneconomic.

There are a number of different variants of service connection pillars on the network that are being replaced in small batches, particularly under-veranda service connection boxes in older commercial areas.

There is an ongoing replacement of underground link boxes around Wellington City driven by the condition of some of these assets. The link boxes are either jointed through, where the functionality is no longer required, or replaced entirely to provide the same functionality. Link boxes will be replaced following an unsatisfactory inspection outcome, and it is expected that fewer than 10 will require replacement every year.



Expenditure Summary for Low Voltage Pits and Pillars

Figure 7-65 details the expected expenditure on low voltage pits and pillars by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Asset Replacement and Renewal Capex	150	150	150	150	150	150	150	150	150	150
Reactive Capital Expenditure	150	150	150	150	150	150	150	150	150	150
Capital Expenditure Total	300	300	300	300	300	300	300	300	300	300
Preventative Maintenance	60	60	60	60	60	60	60	60	60	60
Corrective Maintenance	50	50	50	50	50	50	50	50	50	50
Operational Expenditure Total	110	110	110	110	110	110	110	110	110	110

Figure 7-65 Expenditure on Low Voltage Pits and Pillars (\$K in constant prices)

7.5.7 Pole-mounted Distribution Switchgear

7.5.7.1 Reclosers and Gas Switches

Fleet Overview

Automatic circuit reclosers are pole mounted circuit breakers that provide protection for the rural 11 kV overhead network. The majority of the 17 reclosers on the network are vacuum models with electronic controllers, with only four being older hydraulic types. The individual types of auto-reclosers are shown in the Figure 7-66.

Manufacturer	Insulation	Model	Quantity
G&W	Solid/Vacuum	ViperS	13
Reyrolle	Oil	OYT	2
McGraw-Edison	Oil	KFE	2
Total			17

Figure 7-66 Summary of Recloser Types

The age profile of WELL's reclosers is shown in Figure 7-67.




Figure 7-67 Age Profile of Reclosers

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on reclosers:

Activity	Description	Frequency
Visual Inspection and Thermal Image	Visual inspection of equipment and condition assessment based upon visible defects. Thermal image of accessible connections.	Annually
Recloser Operational Check	Bypass unit or back feed, arrange remote and local operation in conjunction with NCR to ensure correct operation and indication.	Annually
Recloser Service	Maintenance of recloser, inspect and maintain contacts, change oil as required, prove correct operation.	3 yearly
Inspection and Testing of Earthing	Visual inspection of earthing system installation and mechanical protection, testing of individual and combined earth bank resistance.	5 yearly

Figure 7-68 Inspection and Routine Maintenance Schedule for Auto Reclosers

Renewal and Refurbishment

One major contributor towards network performance in rural areas is having reliable and appropriately placed reclosers in service. The majority of the units in service are relatively new, in good condition and performing as expected, however all types of hydraulic recloser have experienced failures in recent years. Refurbishment has proven ineffective at returning failed hydraulic reclosers to effective service, and units are instead replaced with electronic reclosers on failure.



A replacement programme commenced in 2013, with the intention of phasing out hydraulic reclosers from service by 2020. A higher than expected rate of failure of hydraulic reclosers resulted in more units being replaced in 2015 than anticipated, with the programme now expected to be completed during 2019. Units are prioritised for replacement on the basis of performance history, other defects, and the potential SAIDI impact of future failures.

Due to the high number of consumers being interrupted under fault conditions, the number of reclosers installed on the system will be reviewed in 2018 with a view to increasing the amount installed. A standard defining the optimal number and placement of sectionalising devices such as reclosers will be published in 2018 which will assist in defining these numbers going forward.

Expenditure Summary for Reclosers

Figure 7-69 details the expected expenditure on reclosers by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Asset Replacement and Renewal Capex	440	588	441	882	-	-	-	-	-	-
Capital Expenditure Total	440	588	441	882	-	-	-	-	-	-
Preventative Maintenance	8	8	7	7	7	7	7	7	7	7
Corrective Maintenance	10	10	10	10	10	10	10	10	10	10
Operational Expenditure Total	18	18	17	17	17	17	17	17	17	17

Figure 7-69 Expenditure on Reclosers
(\$K in constant prices)

7.5.7.2 Overhead Switches, Links and Fuses

Fleet Overview

Overhead switchgear is used for breaking the overhead network into sections, and providing protection to pole mounted distribution transformers, and cables at overhead to underground transition points. A summary of the quantities of different categories of overhead switches is shown in Figure 7-70.

Category	Quantity
Gas Switches	77
Air Break Switches	279
Knife Links	101
Dropout Fuses	2,120
Dropout Sectionalisers	11
Total	2,588

Figure 7-70 Summary of Pole Mounted Distribution Switchgear

The age profiles of these devices are shown in Figure 7-71.




Figure 7-71 Age Profile of Overhead Switchgear and Devices

Maintenance Activities

The following routine planned inspection, testing and maintenance activities that are undertaken on overhead switches, links and fuses are shown in Figure 7-72.

Activity	Description	Frequency
Visual Inspection and Thermal Image	Visual inspection of equipment and condition assessment based upon visible defects. Thermal image of accessible connections.	Annually
ABS Service	Maintain air break switch, clean and adjust contacts, check correct operation.	3 yearly
HV Knife Link Service	Maintain knife links, clean and adjust contacts, check correct operation.	3 yearly
Gas Switch Service	Maintain gas switch, check and adjust mechanism as required.	9 yearly
Remote Controlled Switch Operational Check	Bypass unit or back feed, arrange remote and local operation in conjunction with NCR to ensure correct operation and indication.	Annually
Inspection and Testing of Earthing	Visual inspection of earthing system installation and mechanical protection, testing of individual and combined earth bank resistance.	5 yearly

Figure 7-72 Inspection and Routine Maintenance Schedule for Overhead Switch Equipment

All overhead switches and links are treated in the same manner, and are maintained under the preventative maintenance programme detailed above. Overhead HV fuses are visually inspected during both the annual overhead line survey and at the time of transformer maintenance (for fuses supplying overhead transformers). The large quantity and low risk associated with fuses does not justify an independent inspection and maintenance programme.

Condition of Overhead Switches, Links and Fuses

Generally, the condition of overhead equipment on the network is good. The environment subjects equipment to wind, salt spray, pollution and debris, which causes a small number of units to fail annually. Common modes of deterioration are corrosion of steel frame components and operating handles, mechanical damage to insulators, as well as corrosion and electrical welding of contacts. In harsh environments, fully enclosed gas insulated switches with stainless steel components are now being used.

A problem has previously been identified with some types of expulsion drop out (EDO) fuses that were overheating. This is a result of the use of different metals causing the pivot point on the fuse holder to seize and prevent the fuse holder from operating as designed. Over the past four years this has not been a major issue and therefore replacement currently only occurs as required. The same can be said for in-line links, which have started to show signs of failure when used on copper conductor and subjected to fault currents. This situation was monitored over the course of 2017 and a specialist metallurgist was engaged to identify the root cause of failures. The analysis undertaken has shown that the common point of failure has been on temporary links and the application techniques of live line clamps. A temporary suspension on the use of temporary in-line links (and removal of those that were already on the network) has been put in place until a resolution is agreed upon.

The coastal environment around Wellington causes accelerated corrosion on galvanised overhead equipment components and, where possible, stainless steel fittings are used as they have proven to provide a longer and more cost effective solution.

Renewal and Refurbishment

Any renewal activity on these assets is driven from standard inspection rounds and resultant maintenance activities arise from the identification of corrective work. With the extensive pole and cross arm replacements undertaken over recent years, a large number of overhead switches have now been replaced. Replacement generally occurs following a poor condition assessment result from the routine inspections, or at the time of pole or cross arm replacement if the condition of the switch justifies this at that time.

Expenditure Summary for Overhead Switchgear

Figure 7-73 details the expected expenditure on overhead switchgear by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Reactive Capital Expenditure	200	200	200	200	200	200	200	200	200	200
Capital Expenditure Total	200	200	200	200	200	200	200	200	200	200
Preventative Maintenance	120	120	120	120	120	120	120	120	120	120
Corrective Maintenance	122	124	125	126	127	129	130	131	132	132
Operational Expenditure Total	242	244	245	246	247	249	250	251	252	252

Figure 7-73 Expenditure on Overhead Switchgear
(\$K in constant prices)

7.5.8 Other System Fixed Assets

7.5.8.1 Substation DC Systems

Fleet Overview

The DC auxiliary systems provide power supply to the substation protection, control, metering, monitoring, automation and communication systems, as well as circuit breaker tripping and closing mechanisms. The standard DC auxiliary system comprises batteries, battery chargers, DC/DC converters and a battery monitoring system. WELL has a number of different DC voltages: 24, 30, 36, 48, and 110V, largely for historical reasons, however, it has standardised on 24V for all new or replacement installations.

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on substation DC supply systems (battery banks):



Activity	Description	Frequency
Inspection and monitoring of battery & charger condition.	Routine visual inspection of batteries, chargers and associated equipment. Voltage check on batteries and charger.	Annually
Comprehensive battery discharge test.	Comprehensive battery discharge test for all batteries, measurement and reporting of results.	2 yearly (Zone only)

Figure 7-74 Inspection and Routine Maintenance Schedule for Zone Substation Battery Banks

Valve regulated lead acid batteries are now the only type of battery used. Maintenance is based on the recommendations of IEEE–1188 (IEEE Recommended Practice for Maintenance, Testing and Replacement of Valve Regulated Lead Acid Batteries for Stationary Applications).

Battery and Charger Condition

The overall condition of the battery population is very good. Battery chargers are also generally in good condition. Many have SCADA supervision so the NCR is notified if the charger has failed. Given the low value and high repair cost of battery chargers, they are repaired only where it is clearly economic.

Battery Replacement

WELL has a total of 523³⁶ battery banks across 287 sites. Batteries are a critical system for substation operation, but are low cost items. WELL's policy is that all batteries are replaced at 80% of their design life rather than implementing an extensive testing regime. For a number of sites with higher ampere-hour demand, 10-year life batteries are available. For smaller sites, or communications batteries where the demand is lower, batteries are installed with 5-year lives. As part of primary plant replacements, WELL is standardising the voltages used for switchgear operation as well as communications equipment.

Expenditure Summary for Substation Batteries

Figure 7-75 details the expected expenditure on substation batteries by regulatory year.

³⁶ This excludes common alarms requiring 9V batteries.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Asset Replacement and Renewal Capex	173	349	266	300	300	300	300	300	300	300
Capital Expenditure Total	173	349	266	300	300	300	300	300	300	300
Preventative Maintenance	20	20	20	20	20	20	20	20	20	20
Corrective Maintenance	20	20	20	20	20	20	20	20	20	20
Operational Expenditure Total	40	40	40	40	40	40	40	40	40	40

Figure 7-75 Expenditure on Substation Batteries
(\$K in constant prices)

7.5.8.2 Substation Protection Relays

Fleet Overview

Secondary protection assets are relays that automatically detect conditions that indicate a potential primary equipment fault and automatically issue control signals to disconnect the faulted equipment. This ensures that the system remains safe and that damage is minimised. Protection assets are also installed to limit the number of consumers affected by an equipment failure.

On the HV system, there are approximately 1,415 protection relays in operation. The majority of these are electromechanical devices. The remainder use solid state electronic and microprocessor technology. Relays are generally mounted as part of a substation switchboard and are normally upgraded at the time of switchgear replacement.

On sub transmission circuits, and in the Wellington City area where the network is comprised of closed 11 kV rings, protection relays use differential protection where the power entering a circuit is compared with the power output. As a backup on these circuits, and in situations where differential protection is not required (such as radial feeders with normally open points), overcurrent and earth fault (OC/EF) relays are used where circuit currents are measured and a disconnect signal issued if these move outside an expected range.

At distribution level, 11 kV fuses are also used for protection of distribution transformers and other equipment. Fuses are used on the LV system for the protection of cables and equipment. Fuses form part of the primary circuit and are not secondary assets.

Automatic Under Frequency Load Shedding (AUFLS) relays are installed at 19 zone substations. These are programmed to trip feeders in the event of the system frequency dropping below certain setpoints, as required by the System Operator rules.

The average age of the protection relays on the WELL network is around 41 years with approximately 45% of the protection relays are more than 40 years old.

The age profiles of these devices are shown in Figure 7-76.






Figure 7-76 Age Profile of Protection Relays

Maintenance Activities

The following routine planned testing and maintenance activities are undertaken on protection relays:

Activity	Description	Frequency
Protection Testing for Electromechanical Relays	Visual inspection and testing of relay using secondary injection. Confirm as tested settings against expected settings. Update of test record and results into Protection Database.	2 yearly (Zone) 5 yearly (Distribution)
Protection Testing for Numerical Relays	Visual inspection, clearing of local indications, and testing of relay using secondary injection. Confirm as tested settings against expected settings. Confirm correct operation of logic and inter-trip functions. Update of test record and results into Protection Database.	2 yearly (Zone) 5 yearly (Distribution)
Numerical Relay Battery Replacement	Replacement of backup battery in numeric relay.	4 yearly (Zone) 5 yearly (Distribution)

Figure 7-77 Inspection and Routine Maintenance Schedule for Protection Relays

The testing of differential relays (Reyrolle SOLKOR, or similar) also serves to test the copper pilot cables between substations. Upon a failed test, the protection circuit is either moved to healthy pairs on the pilot cable or the cable is physically repaired. Due to deteriorating outer sheaths on pilot cables, some early pilot

cables are now suffering from moisture ingress and subsequent degradation of insulation quality. A grease-filled pilot joint is now being used to block moisture from spreading through entire sections of cable.

Numerical relays, although equipped with self-diagnostic functions, are tested in line with the table above. With more complex protection schemes coming into service, these need to be tested to ensure the correct functions and logic schemes are still operating as expected.

Renewal and Replacement

Generally, all protection relays are in good condition with the exception of PBO electromechanical and Nilstat ITP solid state relays, which have performance and functionality issues. The relay replacement programmes focus on relay condition and coordination with other projects especially for assets such as switchgear and transformers. Rarely does a relay fail in-service and deterioration of relays is identified during routine maintenance testing which may lead to individual relay replacement.

At the time of primary equipment replacement, the opportunity is taken to upgrade associated protection schemes to meet the current standards. To date, electromechanical relays have provided reliable service and are expected to remain in service for the life of the switchgear they control. For newer numeric relays, it is not expected that the relay will provide the same length of service, and a service life of less than the switchgear life is expected.

The following programmes and projects are included in the asset replacement and maintenance budgets:

- Ongoing replacement of PBO relays in conjunction with switchgear;
- Nilstat overcurrent relays are being replaced. The only remaining units of this type are in the Reyrolle Type C switchboard at Gracefield zone substation and, as this switchboard is planned for replacement in 2018;
- Ongoing zone substation and network protection and control upgrades for assets supplied from GXPs, when GXP upgrades are undertaken by Transpower. Such an upgrade will be undertaken in 2019 and 2020 for Maidstone and Brown Owl Zone Substations due to the outdoor to indoor conversion that has occurred at Upper Hutt GXP in 2017; and
- Ongoing protection and control upgrades across the network as identified by asset condition monitoring.

The Authority is proposing to replace AUFLS with an Extended Reserves scheme. This may require replacement of existing AUFLS relays in order to meet the new requirements, however the timing, technical specifications and funding mechanisms for this are not currently known, and as such this work has not been included in this AMP.

Expenditure Summary for Protection Relays

Figure 7-78 details the expected expenditure on protection relays by regulatory year.



Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission Relay Replacement Programme	210	1,178	1,111	1,000	740	-	-	-	-	-
Other Asset Replacement and Renewal Capex	250	250	250	450	600	600	600	600	600	600
Capital Expenditure Total	460	1,428	1,361	1,450	1,340	600	600	600	600	600
Preventative Maintenance	130	130	130	130	130	130	130	130	130	130
Corrective Maintenance	15	15	15	15	15	15	15	15	15	15
Operational Expenditure Total	145	145	145	145	145	145	145	145	145	145

Figure 7-78 Expenditure on Protection Relays
(\$K in constant prices)

7.5.8.3 SCADA and Communications Assets

Fleet Overview

The SCADA master station is a GE PowerOn Fusion system, commissioned in early 2016. A legacy Foxboro system has been retained in the short term to provide the automatic load control function until an alternative system is implemented.

The SCADA system is used for real time monitoring of system status and to provide an interface to remotely operate the network. SCADA can monitor and control the operation of primary equipment at the zone substations and larger distribution substations, and provides status indications from Transpower-owned assets at GXPs.

More specifically, SCADA is used to:

- Monitor the operation of the network from a single control room by remotely indicating key parameters such as voltage and current at key locations;
- Permit the remote control of selected primary equipment in real time;
- Graphically display equipment outages on a dynamic network schematic; and
- Transmit local system alarms to the control room for action.

System information is collected by remote terminal units (RTUs) at each remote location and is transmitted to a SCADA central master station through dedicated communication links. Control signals travel in the opposite direction over the same communications links.

The most common communication links are copper pilot and fibre optic cables. Typically the copper pilots are WELL owned while some fibre links are under lease agreements.

WELL has two NCRs at separate sites, with one set up as a Disaster Recovery site. These sites are interconnected via the Transmission Control Protocol/Internet Protocol (TCP/IP) network.

An age profile of SCADA RTUs is shown in Figure 7-79.




Figure 7-79 Age Profile of SCADA RTUs

As substation sites are being upgraded or developed, and if IP network connections are available, the station RTU is upgraded and moved onto the substation TCP/IP network using the DNP3.0 protocol.

There are currently 65 sites (a mixture of zone and distribution substations) on the substation TCP/IP network.

There are two Siemens Power Automation System (PAS) units that act as a protocol converter between the Siemens IEC61850 field devices located at three sites and the DNP3.0 SCADA master station. These units are at end of life and the replacement of these PAS units in conjunction with the installation of standard RTUs will be completed by 2019.

Maintenance Activities

The SCADA system is generally self-monitoring and there is little preventative maintenance carried out on it apart from planned server and software upgrades and replacement. Master station maintenance is broken into two categories:

- (a) Hardware support for the disaster recovery site is provided as required by Wellington based maintenance contractors; and
- (b) Software maintenance and support is provided by external service providers.



Existing RTUs are managed on a run to failure strategy. First line maintenance on the system is carried out as required by the Field Service Provider within the scope of its substation maintenance contracts. The substation level IP network is monitored and supported from within New Zealand by the respective service providers of the IP network infrastructure.

The SCADA front end processors have Uninterruptible Power Supply (UPS) systems to provide backup supply and there is a UPS system providing supply to the operator terminals in the NCR. This is subject to a maintenance programme provided by the equipment supplier. In addition, these units have their self-diagnostics remotely monitored and dual redundancy of converters and batteries to provide a high level of supply security in the unlikely event of failure.

SCADA System Component Concerns

C225 RTU

There are 14 C225 RTUs in service on the network. Power supply failure is the most common failure mode with around one failure a year. Spares are at a central location and repairs are carried out where possible. These RTUs are being replaced in conjunction with GXP protection upgrades, and the redundant units are held as spares.

C5 RTU

There are six C5 RTU's in service at very small distribution substations. They are no longer manufactured and are difficult to repair, so as they fail they are interchanged with modern alternatives.

Dataterm RTU

There are five of these still in service on the network, including three at zone substations. These RTU's have an inherent design flaw in the analogue card, which, over time, causes the analogues to "jump." This is repairable with the replacement of reed relays on the analogue card at an approximate cost of \$500 per card. There are normally four cards per RTU and the cards fail at a rate of about five per year. These units are being replaced with Foxboro SCD5200 RTUs as zone substations are upgraded and moved onto the IP network.

Miniterm RTU

There are 48 of these in service on the network. These units fail at the rate of approximately two a year due to board level IC failure, with replacement ICs gradually becoming harder to source. These RTU's cannot be directly replaced by current technology however spare units are becoming available as a result of the switchgear replacement works. There is no active programme for replacing these but replacement occurs in conjunction with substation switchgear replacements, or where a risk is identified in having this type of RTU installed.

Common Alarms

There are 43 of these in service on the network. These are a custom-built device, placed in minor "ringed" distribution substations to give an indication back to the NCR of a tripping event. They are prone to failure and there are no spares. On failure, the units are replaced by current technology such as a low cost RC02 RTU which is widely used on the network.

Cisco 2811 Routers

There are 32 Cisco 2811 routers in service, located in distribution substations connected to the TCP/IP network. These devices are no longer supported by the manufacturer and replacement parts cannot be purchased. There are no concerns about the performance of the equipment but where expansion is required, for example the addition of VOIP interface cards, the 2811 router is replaced with its modern equivalent and returned to stock as a spare.

Renewal and Refurbishment

The asset replacement budget provides for the ongoing replacement of obsolete RTUs throughout the network. Obsolete RTUs that may have a significant impact on network reliability are targeted first with priority being given to the zone and major switching substations.

If an RTU at a zone substation or major switching point in the network is adjacent to the existing TCP/IP network, consideration is given to upgrading the equipment to allow TCP/IP connection in order to continuously improve communication system reliability. Furthermore the TCP/IP infrastructure will also allow other substation based equipment (such as security alarms etc.) to efficiently communicate with distant receive devices.

The priority of the substation RTU replacement programme will align with GXP protection upgrade and zone substation switchgear replacement projects. There is currently no programme to replace RTUs at distribution substations as these sites generally have a lower risk profile than GXPs and zone substations and replacement can occur upon failure of the RTU. However an RTU upgrade will be scheduled when a specific risk is identified. In addition, sites where switchgear is upgraded may also have an RTU upgrade. These are incorporated as part of the switchgear replacement project and the need for an RTU replacement is evaluated on a case-by-case basis.

Copper pilot cables are repaired on failure. When the business case for new digital communication equipment requires a higher level of service, then copper pilot replacement with fibre optic cable is determined on a case-by-case basis.

Analogue SCADA Radio Replacement

The Network Communications Strategy has identified a risk associated with the age and configuration of the analogue radio network which is used as the communications link for a number of field devices (such as reclosers and remote switches). A review of the existing network, future requirements and potential replacement systems resulted in the recommendation that the system be replaced with a mesh radio network. The cost of replacing the existing network has been estimated at approximately \$500,000.

Expenditure Summary for SCADA and Communications Assets

Figure 7-80 details the expected expenditure on SCADA and communications assets by regulatory year.



Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
RTU Replacement Programme	1,450	900	950	825	500	500	500	500	500	500
SCADA Radio Replacement Programme	285	135	-	-	-	-	-	-	-	-
Reactive Capital Expenditure	100	100	100	100	100	100	100	100	100	100
Capital Expenditure Total	1,835	1,135	1,050	925	600	600	600	600	600	600
Corrective Maintenance	20	20	20	20	20	20	20	20	20	20
Operational Expenditure Total	20	20	20	20	20	20	20	20	20	20

Figure 7-80 Expenditure on SCADA and Communications Assets
(\$K in constant prices)

7.5.9 Other Network Assets

7.5.9.1 Metering

WELL does not own any metering assets as these are owned by retailers and metering companies.

Check meters installed at GXP's and Maximum Demand Indicator (MDI) meters are installed in a large number of distribution substations, predominantly those used for street LV supply. MDIs are used for operational and planning purposes only and are considered part of the distribution substation. In future, there may be benefits from accessing smart metering data from consumer premises to feed into the network planning and asset management processes, as well as for real time monitoring of the performance of the low voltage network.

Check meters are not proactively maintained; however their output is continuously monitored by SCADA and compared to the Transpower revenue meters. Alarms are triggered where the discrepancy between the Transpower revenue meters and WELL's check meters exceeds an acceptable tolerance.

7.5.9.2 Generators and Mobile Substations

WELL owns six mobile generators and a fixed generator supporting the disaster recovery control room site. WELL makes use of one of its mobile generators at its temporary corporate office.

The works contractor provides all generation required for network operations and outage mitigation, where required.

7.5.9.3 Load Control Equipment

Fleet Overview

WELL uses a ripple injection signal load control system to inject 475Hz and 1050Hz signals into the network for the control of selected loads such as water heating and storage heaters at consumer premises, to control street lighting and also to provide tariff signalling on behalf of retailers using the network. All

ripple injection is controlled automatically by the Foxboro master station but can also be controlled remotely from the NCR.

There are 23 ripple injection plants on the network and these are located at GXPs and zone substations. The Southern area has a 475Hz signal injected into the 33 kV network with one plant per GXP and two plants injecting at the Kaiwharawhara 11 kV point of supply. The Northeast and Northwest areas have a 1050Hz signal injected at 11 kV at each zone substation.

The 213 previously used DC bias load control units have now all been either removed or bypassed.

An age profile of ripple plant is shown in Figure 7-81.




Figure 7-81 Age Profile of Ripple Plant

Maintenance Activities

The following routine planned inspection, testing and maintenance activities are undertaken on load control equipment. WELL owns the injection plants located at substations and the blocking cells at GXPs, but does not own the consumer receivers. As such, the full end-to-end testing of the ripple system is very problematic.



Activity	Description	Frequency
General Inspection	Check output signal, visual inspection, thermal image and partial discharge scan, motor generator test run.	6 monthly
Maintain Ripple Injection Plant	Clean and inspect all equipment, maintain motor generator sets, coupling cell test and inspection.	Annually
Blocking Cell Testing and Maintenance	Visual inspection, cleaning and maintenance of ripple blocking cells at GXP's as required.	5 yearly

Figure 7-82 Inspection and Routine Maintenance Schedule for Ripple Plant

Renewal and Refurbishment

The existing load control plant is generally reliable, with repairs and maintenance undertaken as required. WELL has no immediate plans to replace any ripple injection plant due to age or condition but is currently reviewing its load control asset strategy which may recommend investment during the planning period.

The rotary injection plants in the Hutt Valley area, while old, are easily maintained and repaired. Interconnectivity at 11 kV allows the ripple signal to be provided from adjacent substations in the event of failure.

The static injection plants in Wellington City are approaching end of life. A stock of spare parts is held locally, but many components such as integrated circuits are no longer manufactured. The risk of failure of a plant is being managed by the stock of strategic spares.

In February 2017, a static plant failed at Jubilee Road. This unit was replaced with the strategic spare and a replacement unit has since been replaced.

Later in 2017, a transmitter at Frederick Street failed which had to be replaced with the spare unit that had come out of Jubilee Road and a new strategic spare was purchased.

Potential replacements for the Foxboro master station are currently being evaluated. This upgrade will require the replacement of the load control PLCs located at injection plants.

Strategic Spares

The spares held for load control plant is shown in Figure 7-83.

Strategic Spares	
Injection plant	<p>A spare 24kVA rotary motor-generator set is held for the 11 kV ripple system in the Hutt Valley.</p> <p>The spare 300kVA solid state transmitter at Frederick street was used in 2017 during a breakdown. A new spare has been sourced and purchased.</p> <p>An assortment of coupling cell equipment is held in store.</p>
Controllers	<p>A spare Load Control PLC is kept as a strategic spare, as the same type is used across the network.</p>

Figure 7-83 Spares Held for Load Control Plant

Expenditure Summary for Other Network Assets

Figure 6-84 details the expected expenditure other network assets by regulatory year.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Load Control PLC Replacement	-	400	300	300	-	-	-	-	-	-
Load Control primary plant	-	-	-	-	-	-	-	-	-	-
Reactive Capital Expenditure	200	200	400	400	400	400	400	400	400	400
Capital Expenditure Total	200	600	700	700	400	400	400	400	400	400
Preventative Maintenance	70	70	68	68	68	68	68	68	68	68
Corrective Maintenance	153	185	136	216	223	250	283	280	280	280
Operational Expenditure Total	223	255	204	284	291	318	351	348	348	348

Figure 7-84 Expenditure on Other Network Assets
(\$K in constant prices)

7.5.10 Assets Located at Bulk Electricity Supply Points Owned by Others

WELL owns a range of equipment installed at Transpower GXPs. These assets are included in the asset categories listed above, but are described further below.

7.5.10.1 33 kV and 11 kV Lines, Poles and Cables

WELL owns lines, poles, cables, and cable support structures at all GXPs from which it takes supply. The Wellington City area is fully underground cabled, whereas in the Hutt Valley and Porirua areas many circuits are connected to the GXP via an overhead line.



7.5.10.2 11 kV switchgear

WELL owns the 11 kV switchgear located within the Kaiwharawhara GXP. The 11 kV switchboards at all other GXPs where supply is given at 11 kV are owned by Transpower.

7.5.10.3 Protection Relays and Metering

WELL owns 33 kV line and cable protection (differential) and inter-tripping relays at all GXPs except Kaiwharawhara. At Kaiwharawhara, WELL owns the relays associated with the 11 kV switchgear except those on the incomers, which are owned by Transpower. WELL also owns check metering at all GXPs.

7.5.10.4 SCADA, RTUs and Communications Equipment

WELL owns SCADA RTUs and associated communications equipment at all GXPs.

7.5.10.5 DC Power Supplies and Battery Banks

WELL owns battery banks and DC supply equipment at all GXPs.

7.5.10.6 Load Control Equipment

WELL owns load control injection plant at Haywards and Melling GXPs, and also has ripple blocking circuits installed on the 33 kV bus at the Takapu Road, Melling and Upper Hutt GXPs.

7.6 Asset Replacement and Renewal Summary for 2018-2028

The total projected capital budget for asset replacement and renewal for 2018 to 2028 is presented in Figure 7-85. This includes provision for replacements that arise from condition assessment programmes during the year. For the later years in the planning horizon, these projections are less certain in nature. Whether they proceed will depend on the risks to the network and the risks relative to other asset replacement projects. Should the consequence of failure increase, or the asset deteriorates faster than expected, then renewal may need to be brought forward. Conversely, should the risk level decrease then the project may be able to be deferred until later in the planning period or an alternative found.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	250	250	350	350	300	1,175	2,925	300	300	300
Zone Substations	2,050	900	2,000	1,250	1,250	250	250	250	250	250
Distribution Poles and Lines	7,000	6,709	6,710	6,522	7,531	7,825	8,475	10,917	9,801	10,547
Distribution Cables	200	200	250	250	2,750	2,750	3,250	3,750	4,750	6,250
Distribution Substations	2,100	2,100	2,300	3,000	2,625	3,500	3,500	3,500	3,500	3,500
Distribution Switchgear	3,305	3,178	3,291	3,450	2,350	3,350	3,850	3,850	3,850	3,850
Other Network Assets	2,968	3,812	3,677	3,675	2,940	2,200	2,200	2,200	2,200	2,200
Total	17,873	17,149	18,578	18,497	19,746	21,050	24,450	24,767	24,651	26,897

Figure 7-85 System Asset Replacement and Renewal Capital Expenditure Forecast
(\$K in constant prices)

A breakdown of forecast preventative maintenance expenditure by asset category is shown in Figure 7-86. This budget is relatively constant, and is set by the asset strategies and maintenance standards that define inspection tasks and frequencies.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	116	116	116	116	116	116	114	114	114	114
Zone Substations	293	272	261	271	266	271	261	271	291	266
Distribution Poles and Lines	441	439	437	434	433	431	429	428	427	428
Distribution Cables	200	200	200	200	200	200	200	200	200	200
Distribution Substations	435	435	435	435	435	435	435	435	435	435
Distribution Switchgear	728	728	727	727	727	727	727	727	727	727
Other Network Assets	280	280	278	278	278	278	278	278	278	278
Total	2,493	2,470	2,454	2,461	2,455	2,458	2,444	2,453	2,472	2,448

Figure 7-86 Preventative Maintenance by Asset Category
(\$K in constant prices)

The forecast corrective maintenance expenditure by asset category is shown in Figure 7-87. This excludes capitalised maintenance, which is instead incorporated into the Asset Renewal and Replacement (ARR)



expenditure forecast in Figure 7-88. These forecasts are based on historical trends and forecast asset replacements, however year on year variances across the different asset categories will occur depending on the nature of the corrective maintenance that is required in any given year.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	-	-	-	-	-	-	-	-	-	-
Zone Substations	163	165	166	168	170	173	174	177	172	172
Distribution Poles and Lines	832	824	763	764	858	866	874	880	880	880
Distribution Cables	169	175	181	187	194	200	207	215	222	222
Distribution Substations	938	940	937	980	977	974	971	968	968	968
Distribution Switchgear	545	538	530	523	516	509	502	495	495	495
Other Network Assets	258	290	241	321	328	355	388	385	385	385
Total	2,905	2,932	2,818	2,943	3,043	3,077	3,116	3,120	3,122	3,122

Figure 7-87 Corrective Maintenance by Asset Category
(\$K in constant prices)

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
ARR Opex	1,568	1,583	1,605	1,626	1,650	1,673	1,692	1,703	1,567	1,660

Figure 7-88 Asset Renewal and Replacement Opex
(\$K in constant prices)

7.6.1 Reliability, Safety and Environmental Programmes for 2018-2028

Asset management expenditure that is not directly the result of asset health drivers is categorised into quality of supply and other reliability, safety and environmental expenditure. Quality of supply projects target the worst performing feeders. Other reliability, safety and environmental projects includes the BAU seismic programme. The total projected capital budget for these categories is presented in Figure 7-89.

Programme	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Worst Performing Feeders	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Total Quality of Supply	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Seismic Programme ³⁷	1,320	2,130	1,010	470	600	-	-	-	-	-
Total Other Regulatory, Safety and Environment	1,320	2,130	1,010	470	600	-	-	-	-	-

Figure 7-89 Reliability, Safety and Environmental Capital Expenditure (\$K in constant prices)

7.6.2 Asset Management Expenditure

The total capital and operational expenditure forecasts are shown in Figures 7-90 and 7-91. For clarity, the operational expenditure forecast does not include non-maintenance related operational expenditure. Service interruptions and emergency maintenance can only be forecast and reported at a system level as the Field Service Agreement defines the rates for fault response services at a total level and not further broken down into asset category detail levels.

Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Asset Replacement & Renewal	17,073	17,349	19,078	18,997	20,646	21,550	24,950	24,367	25,151	27,397
Reliability, Safety & Environment (other)	1,320	2,130	1,010	470	600	-	-	-	-	-
Quality of Supply	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Subtotal - Capital Expenditure on Asset Replacement Safety and Quality	21,803	20,789	21,613	20,497	21,996	22,408	25,413	25,736	25,620	27,866

Figure 7-90 Asset Management Capital Expenditure Forecast (\$K in constant prices)

³⁷ Note that this expenditure does not include the Seismic Strengthening work covered by the SCPP which is covered in Section 11.

Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Service interruptions & emergency maintenance	3,894	3,898	3,897	3,898	3,897	3,897	3,897	3,898	3,898	3,876
Vegetation management	1,651	1,652	1,652	1,652	1,652	1,653	1,652	1,653	1,653	1,645
Routine & corrective maintenance and inspection maintenance	6,698	6,767	6,705	6,909	7,078	7,194	7,302	7,402	7,515	7,587
Asset replacement & renewal maintenance	1,568	1,583	1,605	1,626	1,650	1,673	1,692	1,703	1,567	1,660
Subtotal - Operational Expenditure on Asset Management	13,811	13,900	13,859	14,085	14,277	14,417	14,543	14,656	14,633	14,768

Figure 7-91 Asset Management Operational Expenditure Forecast

This page is intentionally blank





Section 8

Network Development

8 Network Development

This section sets out WELL's network development investment plan over the next 10 years. The purpose of network development is to safely deliver the level of capacity and security of supply required to achieve, over the planning period, the service levels and network performance described in Sections 5 and 6.

Due to the uncertainty in how demand for network capacity will change over time, planning for development investment requires constant monitoring of the need for projects and the investment timing to ensure it is efficient and that consumers are receiving the price and quality outcomes they are expecting.

This section covers:

- Network planning policies and standards;
- Demand forecast;
- An overview of the Network Development and Reinforcement Plan (NDRP);
- Network development plans for the Southern, Northwestern and the Northeastern areas; and
- Customer initiated projects and relocations.

8.1 Network Planning Policies and Standards

The purpose of these policies and standards is to ensure the network delivers the service levels discussed in Sections 5 and 6.

The policy and standards cover the following areas:

- Security criteria – which specify the network capacity (including levels of redundancy) required to ensure the level of reliability is maintained;
- Technical standards – voltage levels, power factor and harmonic level standards to ensure the network remains safe and secure, and that overall network costs are minimised;
- Standardised designs – these reduce design costs and minimise spare equipment holding costs, leading to lower overall project and maintenance costs;
- The impact of embedded generation on planning;
- The use of non-network solutions within the planning process;
- The definition of asset capacity utilised for planning purposes; and
- Demand forecasting policies and methodology.

Each of these is discussed in the following sections.



8.1.1 Security Criteria

The design of WELL's network is based on the security criteria shown in Figure 8-1 (sub transmission criteria) and Figure 8-2 (distribution criteria).

The security criteria are consistent with industry best practice³⁸ and are designed to:

- Match the security of supply with consumer requirements;
- Optimise capital and operational expenditure without a significant increase in supply risks; and
- Increase asset utilisation and reduce system losses.

The security criteria accepts there is a small risk that supply may be interrupted, and not be able to be backfed, when a fault occurs during peak demand times. This is more cost-effective than removing this small risk altogether.

The WELL sub transmission network consists of a series of radial circuits from Transpower's GXPs to the zone substations. The zone substations do not have a 33 kV bus and the sub transmission circuits connect directly onto the high voltage terminals of the 33/11 kV power transformers. In the Southern Area the 11 kV bus is normally operated open to restrict fault levels. Within the Northwestern and Northeastern areas the 11 kV bus is operated closed. The network utilises equipment cyclic capacity to meet sustained peak demand and provide N-1 security. At the zone substations where the 11 kV bus is normally operated open, the brief interruption to consumers following a sub transmission or transformer fault, while the bus tie is closed, is considered to satisfy the N-1 security criteria. There is currently a programme underway to implement an automatic bus tie change-over scheme to improve reliability without needing to operate the system at higher prospective fault levels.

Sub-transmission

The length of time (defined as a percentage) when the sub-transmission network cannot meet N-1 security is defined for each category of consumer. Absolute limits are also set on the maximum load that would be lost for the occurrence of a contingency event. The security criteria are based on the sustained peak demand which is calculated as 'loading that lasts for two hours or longer and occurs at least five times during the year'. This differs from the anytime peak demand which is measured over a 30 minute period and can occur as a result of abnormal system operations.

³⁸ *Guide for Security of Supply*, Electricity Engineers' Association, August 2013.

Figure 8-1 shows the applicable security criteria for the sub transmission network.

Type of Load	Security Criteria
CBD	N-1 capacity ³⁹ , for 99.5% of the time in a year. For the remaining times, supply will be restored within 3 hours following an interruption.
Mixed commercial / industrial / residential substations	N-1 capacity for 98% of the time in a year. For the remaining times, supply will be restored within 3 hours following an interruption.
Predominantly residential substations	N-1 capacity for 95% of the time in a year. For the remaining times, supply will be restored within 3 hours following an interruption.

Figure 8-1 Security Criteria for the Sub transmission Network

Distribution

Figure 8-2 shows the applicable security criteria for the distribution network.

Type of Load	Security Criteria ⁴⁰
CBD or high density industrial	N-1 capacity for 99.5% of the time in a year. For the remaining times, supply will be restored within 3 hours following an interruption.
Mixed commercial / industrial / residential feeders	N-1 capacity for 98% of the time in a year. For the remaining times, supply will be restored within 3 hours following an interruption.
Predominantly residential feeders	N-1 capacity for 95% of the time in a year. For the remaining times, supply will be restored within 3 hours following an interruption.
Overhead spurs supplying up to 1MVA urban area	Loss of supply upon failure. Supply restoration dependent on repair time.
Underground spurs supplying up to 400kVA.	Loss of supply upon failure. Supply restoration dependent on repair time.

Figure 8-2 Security Criteria for the Distribution Network

³⁹ A brief supply interruption of up to five minutes may occur following an equipment failure while the network is reconfigured.

⁴⁰ In areas other than the CBD an operator may need to travel to the fault location to manually operate network switchgear, in which case the supply interruption could last for up to 1 hour.



Basis for the criteria

While the reliability of WELL's distribution system is high, notwithstanding the difficult physical environment in which the system must operate⁴¹, it is uneconomic to design a network where supply interruptions will never occur. Hence, the network is designed to limit the amount of time over a year when it is not possible to restore supply by reconfiguring the network following a single unplanned equipment failure. This approach recognises that electricity demand on the network varies according to the time of day and season of the year, and that the time over which the system is exposed to its peak demand is very small.

The security criteria do not apply to faults on distribution transformers, the low voltage network or to failures of connection assets used to supply individual consumers, which are typically designed for 'N' security. In such situations an interruption will last for the time taken to make a repair.

The security criteria also do not apply when multiple equipment outages affect the same part of the network or when major storms or other severe events have a high impact on the system. WELL has emergency plans in place to prioritise response and repair efforts to assist mitigating the impact of such situations (as discussed in Section 11) but, when they occur, longer supply interruptions than shown in the tables are possible.

Most of the 11 kV feeders in the Wellington CBD, in some locations around Wellington city eastern suburbs, and in the Porirua commercial centre are operated in a closed ring configuration with radial secondary feeders interconnecting neighbouring rings or zone substations. This arrangement provides a high level of security and hence a high level of supply reliability. The urban 11 kV network outside these areas typically comprises radial feeders with a number of mid-feeder switchboards with circuit breakers. The radial feeders are connected through normally open interconnectors to other feeders so that, in the event of an equipment failure, supply to consumers can be switched to neighbouring feeders. To allow for this flexibility, distribution feeders are not operated at their full thermal rating under normal system operating conditions. The maximum feeder utilisation factor at which WELL currently operates the distribution feeders during normal and contingency operation is identified in the table in Figure 8-3. This is a guideline limit and signals the point where greater analysis is required. The actual N-1 post event loading and implementation of any required solutions is determined using contingency analysis.

Feeder Operation	Normal Operation Loading (%)	Contingency Operation Loading (%)
Two Feeder Mesh Ring	50	100
Three Feeder Mesh Ring	66	100
Four Feeder Mesh Ring	75	100
Five Feeder Mesh Ring	80	100

⁴¹ Much of WELL's supply area is renowned for its high winds. There can also be a high concentration of salt in the atmosphere, blown in from the sea.

Feeder Operation	Normal Operation Loading (%)	Contingency Operation Loading (%)
Radial Feeder	66	100

Figure 8-3 11 kV Feeder Utilisation during Normal and Contingency Operation

A consumer may desire a level of security above that offered by a standard connection. Should this arise, WELL offers a range of alternatives that provide different levels of security at different prices (price/quality trade off). The consumer can then choose to pay for a higher level of security to meet their needs for the load that are being supplied.

8.1.2 Voltage Levels

Sub transmission voltage is nominally 33 kV in line with the source voltage at the supplying GXP. The voltage used at the distribution level is nominally 11 kV. The LV distribution network supplies the majority of consumers at nominally 230V single phase or 400 V three phase. By agreement with consumers, supply can also be connected at 11 kV or 33 kV depending upon the load requirements.

Regulation 28 of the Electricity (Safety) Regulations 2010 requires that standard LV supply voltages (230V single phase or 400 V three phase) must be kept within +/-6% of the nominal supply voltage calculated at the point of supply, except for momentary fluctuations. Supplies at other voltages must be kept within +/-5% of the nominal supply voltage except for momentary fluctuations, unless agreed otherwise with consumers.

Design of the network takes into account voltage variability due to changes in loading and embedded generation under normal and contingency conditions. All WELL zone substation transformers are fitted with on-load tap changers (OLTC) controlled by voltage regulation systems to maintain the supply voltage within acceptable limits. Distribution transformers typically have an off-load tap changer which can be manually adjusted to maintain acceptable voltage at different network locations.

8.1.3 Fault Levels

WELL operates its 11 kV network to restrict the maximum fault level to 13 kA which ensures the fault rating for several legacy makes and models of switchgear is not exceeded. Restriction of fault levels is achieved by operating all zone substations supplied from Central Park and Wilton GXPs with a split 11 kV bus such that each zone substation transformer is supplying an independent bus section. The prospective fault level at all other zone substations does not exceed 13 kA⁴² (except Korokoro which exceeds 13 KA but has acceptable downstream fault rated switchgear), meaning the 11 kV bus can be operated closed, with the supply transformers supplying a common bus. New switchgear is typically rated for 25 kA for use within zone substations and 21 kA for use within the distribution network.



8.1.4 Power Factor

All connected consumers are responsible for ensuring that their demand for reactive power does not exceed the maximum level allowed, or the power factor limits specified in WELL's network pricing schedule and connection requirements. The power factor of a consumer's load measured at the metering point must not be less than 0.95 lagging at all times. Corrective action may be requested by WELL if the consumer's power factor falls below this threshold. All demand forecasting and network planning assumes the power factor of all loads is 0.95 lagging.

8.1.5 Acceptable Harmonic Distortion

Harmonic currents result from the normal operation of nonlinear devices on the power system. Voltage distortion results as these currents cause nonlinear voltage drops across the system. Harmonic distortion levels are defined by magnitudes and phase angle of each individual harmonic component. It is also common to use a single quantity, the "Total Harmonic Distortion" (THD), as a measure of the magnitude of harmonic distortion. Current and voltage harmonic levels are to be within the 5% THD limit specified in the Electrical Safety Regulations 2010 at the point of supply to the consumer.

8.1.6 Standardised Designs

The implementation of standardised designs for common developments allows for improvements in safety by design principles, significant reduction in design expenditure and reduces the requirement for review and assessment. Standardised designs also aid in consistency in installation, commissioning and maintenance processes, thus improving familiarity for field staff and potentially reducing the cost of implementation.

Standardised designs are implemented for the purpose of asset and installation specification. At present, design standards are utilised for protection design, zone substation and distribution level earthing and LV reticulation as well as designs for underground subdivision.

There is no standardisation of high voltage (HV) network augmentation because these are project by project dependent.

8.1.7 Energy Efficiency

The processes and strategies used by WELL that promote the energy efficiency of the network are:

- Network planning – to design systems that do not lead to high losses or inefficient conveyance of electricity by selecting the correct conductor types and operating voltages in order to minimise total costs (including the cost of losses) over the lifetime of the asset;
- Equipment procurement – to select and approve the use of equipment that meets recognised efficiency standards; for example, selecting distribution transformers that meet recognised AS/NZS standards. For large items such as zone substation power transformers, the purchase decision includes lifecycle loss analysis (copper and iron) to determine the relative economics of the different units offered; and
- Network Operations – to operate the network in the most efficient manner available given current network constraints and utilise the load management system to optimise the system loadings (which in turn affects the efficiency of the network).



8.1.8 Non-Network Solution Policy

Non-network solutions include load control, demand side management solutions, use of emerging technologies and network reconfigurations.

WELL's load control system is used to reduce peak demand on the network by moving load to off-peak periods to optimise investment in network capacity. This has the effect of deferring demand-driven network investments. The use of the load control system has also resulted in the deferral of investment, providing an effective means of promptly returning supply to consumers following network outages.

WELL specifies equipment for use that incorporates new technologies where it is practicable and economic. This means that new technologies will be implemented if the benefits to the network and stakeholders meet or exceed the additional costs incurred in procuring, installing and using them. Therefore, it is unlikely that wide scale replacements of existing assets will occur; rather new equipment will be introduced as existing assets reach their end of life or are replaced due to a requirement for a change in capacity or functionality.

There is also a great level of uncertainty with the fast changing nature of the emerging technologies. WELL's approach is described in section 9.

To date the cost of implementing emerging technologies have been found to be significantly higher than the alternative network-based solutions. As discussed in Section 3, WELL is introducing a new tariff structure to incentivise consumers to use new technologies in a way that smooths peak demand.

8.1.9 Impact of Distributed Generation

The magnitude of small distributed generation currently installed within the network is relatively low⁴³ compared to other areas in New Zealand and overseas, and is expected to remain relatively low across the first half of the planning period. This assumption will be monitored and re-assessed in the event of large scale uptake of distributed generation in the future and annually in the AMP process. WELL welcomes enquiries from third parties interested in installing embedded generation and has a well-defined connection policy, as described below.

8.1.9.1 Connection policy

WELL has a distributed generation connection policy and procedures, for the assessment and connection of distributed generation in line with the Electricity Industry Participation Code 2010, Part 6.

The AS 4777 "Grid connection of energy systems via inverters" referred to in the code has been recently updated and is currently before Energy Safety for approval. The new AS/NZS 4777 standard is expected to be accepted into the regulations in 2018. Once this occurs, WELL will update its standards. This will be done using the EEA "Guideline for the Connection of Small-Scale Inverter Based Distributed Generation" as a template.

⁴³ Installed capacity, excluding standby generation and Mill Creek (connected at 33 kV), is only 15.8MVA, or 0.3% of the system demand.





Example of Distributed Generation⁴⁴

Where it is identified that a third party scheme may have the potential to defer the need for capital investment on the network, the extent the proposal meets the following requirements will be considered in developing a technical and commercial solution with stakeholders:

- The expected level of generation at peak demand times (availability of the service at peak demand times determines the extent that it will off-set network investment);
- The service must comply with relevant technical codes and not interfere with other consumers;
- Any payments made to third parties must be linked directly to the provision of a service that gives the required technical and commercial outcomes; and
- Commercial arrangements must be consistent with avoided cost principles.

If the above issues can be managed, and the dispatch of generation can be co-ordinated with system peaks or constraints, then the use of distributed generation as part of a demand side management programme benefits WELL and its consumers.

Information about connecting distributed generation is available on the WELL website – www.welectricity.co.nz or by calling 0800 248 148.

8.1.10 Asset Capacity Definition

Asset capacity is defined as follows:

⁴⁴ Photo supplied by Meridian Energy.

- Transformers – The transformer ratings include the continuous asset capacity (based on a continuous uniform load profile), the cyclic capacity (based on the presence of fan forced cooling and oil circulation pumps) and a short duration (2 hour) emergency overload rating (dependent on the maximum operating temperature of the transformer). For operational and planning purposes, the cyclic capacities are used;
- Sub transmission Cables/Lines – Thermal conductor capacity is determined through CYMCAP modelling, considering the effect of soil resistivity, the prospective load profile and resulting thermal inertia, mutual heating due to adjacent conductors and configuration of installation. Soil and ambient temperature variations between seasons are also allowed for, providing a set of normal, cyclic and emergency ratings. For operational and planning purposes, the cyclic ratings are used;
- Sub transmission Circuit Capacity – This is determined based on the lowest rated component of the sub transmission circuit, i.e. a transformer may be rated to 36MVA cyclic while the supplying sub transmission cable is only capable of 21MVA cyclic and 17MVA cyclic during winter and summer respectively. Thus the effective rating of the sub transmission circuit is limited to the seasonal cyclic rating of the sub transmission cable; and
- Distribution Cables/Lines – Distribution feeders are rated based on the continuous capacity (provided by manufacturers datasheets) of the cable/line. Distribution cable capacity is the capacity of the lowest rated segment of the cable, thus a constraint may not be apparent at the feeder supply point, but an undersized section of cable on a particular feeder may constrain capacity at a certain point along the feeder.

The capacity of all network elements is modelled in the DigSILENT PowerFactory network model with a seasonal scaling factor applied, providing a tool to analyse network integrity against the security standard.

8.2 Demand Forecast 2018 to 2028

Growth in peak demand drives system constraints and the need for additional investment, either in the network or an alternative means of providing or managing the capacity. This section describes WELL's methodology and assumptions utilised to determine the sustained peak demand forecast for the network.

Despite the overall decline in energy use, the sustained peak demand is forecast to grow in some localised areas of the network, driven by new commercial and residential developments. This reflects a decoupling between the overall volume of energy consumed and the peak demand. There is also a strong correlation between peak demand and climatic conditions. Generally, demand peaks within the Wellington Region are driven by winter temperatures on the coldest days.

While the overall WELL load is traditionally winter peaking, recent trends have shown that a few of the zone substations within the Wellington City are now summer peaking.

8.2.1 Demand Forecast Methodology

The forecasting methodology utilised by WELL is based on a building block approach, from 11 kV feeder level up, utilising historical trends in sustained peak demand. The methodology consists of five components:



1. A starting demand level is based on the sustained peak demand between 30 Sep 2016 and 1 Oct 2017;
2. The average growth rate over the last 10 years is utilised to establish the underlying forecast growth rate;
3. The band of uncertainty in the forecast is based on two components:
 - a. For the first five years of the forecast, in addition to the average, high and low growth rates are applied based on the observed high and low variance from the average sustained peak demand, over the last five years. These are known as the growth scenarios. These three growth scenarios are extrapolated over the 5-10 year horizon by using the average growth rate to provide a medium-long term forecast with a band of uncertainty; and
 - b. Over the whole forecast period a mild, average and cold variance based on the observed spread in peak demand against winter temperature plus one case for summer temperatures. These are known as the four temperature variations applied to the forecast;
4. The addition of known future step change demand at specific sites; and

The output of the forecasting is a peak demand spread over 12⁴⁵ forecast data points per year corresponding to combinations of the demand growth and temperature variations, all centred around the long term average growth rates.

These forecast scenarios are determined at the feeder level, and are aggregated from “bottom up” to provide the Zone substation, GXP, region and system wide forecasts allowing for diversity at each level. An overview of the demand forecast methodology is shown in Figure 8-4.

⁴⁵ Twelve scenarios from permutations of the three growth scenarios (high, historical, low) and the four seasonal temperature variations (Summer, Mild Winter, Average Winter and Cold Winter).






Figure 8-4 Demand Forecasting Methodology

This model is used to determine when sub transmission and feeder level constraints are likely to occur and provides an annual maximum demand that can be used in load flow modelling.

At the sub transmission level, the 60th percentile between the upper and lower range of the sustained peak demand forecast values (differentiated by season) is used for planning purposes and has been termed, the Likely Peak Demand (LPD).

The 60th percentile allows for a sufficient margin of error given the load at risk and the scale of augmentation investment typically required when a constraint is identified at the sub transmission level. This is plotted against the applicable N-1 sub transmission capacity constraints to determine the sub transmission security of supply.

8.2.1.1 Forecasting Assumptions and Inputs

The sustained peak demand forecast for the current planning period is based on the following assumptions:

- The use of load control is assumed⁴⁶ to remain constant as per current practice;
- Removal of Trolley Buses will not have a material impact;
- No allowance is made for any significant demand changes due to major weather events or unforeseen network condition causing significant outages or abnormal operation of the network; and
- No significant impact is assumed from disruptive technologies such as PV or distributed generation, as discussed in Section 9.

⁴⁶ Total amount of controllable load expected to slowly decline.



- Half-hourly demand data per zone substation feeder is captured by the SCADA system. The demand at each GXP is metered through the time-of-use revenue metering;

The sustained peak demand forecast is based on the following information:

- Temperature volatility is based on historical temperature data recorded at three NIWA measurement sites based within the three areas of the Wellington network, the Southern, Northwest and Northeast coverage areas;
- Highly likely or confirmed step change loads, based on consumer connection requests are included in the forecast;
- Diversity factors⁴⁷ that provide peak coincident demand are calculated from historical recorded data;
- Typical demand profiles based on the majority load type in the zone; and
- Population forecasts from Statistics New Zealand⁴⁸ are used as a benchmark for comparison with the long term demand forecast.

These assumptions, data sets and trend analysis are reviewed each year and the expected impacts of any changes are incorporated into the forecast.

8.2.2 Temperature Variation

The variation in average temperature over the year is used to create forecast scenarios. Historically there is a strong inverse correlation between the temperature during the winter months and the recorded maximum demand. A year with a colder/stormier winter typically results in higher winter peak loading and consequently a higher maximum demand, while a year with a milder winter will experience lower maximum demand. There is no current identified correlation between summer temperature variations and the summer loading on the network. As such, the demand model assumes that summer temperature variations have no effect on the annual peak load profile.

To model the dependency on the winter temperatures, three scenarios were developed for each of the three network areas based on smoothed historical temperature variations provided from monitoring stations within the respective area. These load scenarios are shown as red lines in Figure 8-5, and cover mild, average and cold winter temperature profiles. Because of the known relationship between temperature and maximum demand, these temperature profiles are used to calculate the three load scenarios. Figure 8-5 shows how the winter temperature volatility correlates with the volatility in maximum demand.

⁴⁷ Diversity factors represent the difference in times of peak demand between different sites.

⁴⁸ NZ Statistics Subnational Population Projections: 2006 (base) – 2031 (October 2012 update). Used for 10+ year forecasting.




Figure 8-5 Temperature Volatility Correlation to Peak Demand Range

For example, for week 31, there is a high degree of certainty that the temperature for the network area shown will be within the range from 12° C to 15°C. Using the developed correlation between temperature and maximum demand volatility, maximum demand for the network area for week 31 will be between 240MVA and 275MVA.

8.2.3 Step Change Loads

Highly likely or confirmed step change loads are accounted for in the load forecast. These step change loads may be the result of:

- Major developments that introduce large new loads onto the network;
- New electricity generation that is expected to reduce peak demand; or
- Load reductions caused by the movement or closure of businesses.

The magnitude and location of likely step change loads is identified through customer connection requests, likely developments detailed in the individual local council District Plans and consultation with City Councils, developers, and large consumers. A number of property developers and businesses have flagged developments that may create new loads on the network.

The actual step change demand profile represents a material proportion of the change in network peak demand. The actual outcome from step change demands is uncertain, and difficult to estimate more than 12 to 24 months in advance.



8.2.4 Typical Load Profiles

Typical annual demand profiles for the CBD and residential loads are shown in Figure 8-6 and Figure 8-7. These graphs illustrate that peak CBD loads are relatively flat throughout the year with a slight trend towards a summer peak due to air conditioning load whereas residential loads peak in winter, mostly driven by domestic heating.




Figure 8-6 Typical CBD Monthly Peak Load Profile




Figure 8-7 Typical Residential Monthly Peak Load Profile

Typical daily demand profiles are shown in Figure 8-8 and Figure 8-9. These graphs illustrate that the CBD daily profile peaks and then remains relatively flat through the day, whereas the residential load profile has the typical morning and early evening peaks. These profiles are subject to change as the uptake of electric vehicles and demand management technologies changes over time.




Figure 8-8 Typical CBD Zone Substation Daily Load Profile




Figure 8-9 Typical Residential Zone Substation Daily Load Profile

8.2.5 Wellington Regional Peak Demand Forecast



Accounting for the forecast scenarios, including both short and long term trends, temperature variations and step change demands, the expected system maximum demand forecast to 2028 is shown in Figure 8-10. The spread shown in the yellow band indicates the variation in both forecast assumptions and temperature.

The following points apply to the forecast:

- The maximum forecast value for a particular year and season indicates the worst case scenario of high growth and colder average temperatures;
- The minimum forecast value for a particular year and season indicates the mild scenario of low to negative growth and warmer average temperatures; and



- The sustained peak demand used for planning purposes is the 60th percentile of the range of sustained peak demand values resultant from the various load growth and winter temperature scenarios per year.



Network	Sustained Peak Demand (MVA)											
	2017 Actual ⁴⁹	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
System Maximum Demand (MVA)	558	563	568	574	575	579	582	582	584	585	585	586

⁴⁹ The 2017 sustained peak is based on the actual data. Due to the impact of the Nov 2016 earthquake the actual data is lower than previously forecast.



Figure 8-10 Network Historic Demand and Forecast

Peak Time – 13 July 2017 Block 36	2017 Coincident Absolute Peak Demand (MVA)														
	Central Park	Gracefield	Haywards	Kaiwharawhara	Melling	Pautahanui	Takapu Road	Upper Hutt	Wilton	Mill Creek	Wellington Wind	Silverstream	Southern Landfill	Other Small DG	Total
2017 Coincident Peak Demand (MVA)	179	62	34	32	61	20	103	32	-7	56	0.7 ⁵⁰	1.6 ¹²	0.5 ¹²	0.8 ¹²	575

Figure 8-11 Coincident Peak Demand

In summary, sustained peak network demand is expected to grow at a rate of 0.2 – 0.4% p.a. over the next five years. This is driven by planned step change loads such as:

- Planned residential developments in the Porirua Northern Growth Area, Churton Park, Aotea, Whitby, Grenada North and Upper Hutt areas; and
- Expansion plans of a number of commercial and industrial consumers.

In the long term the rate of growth in sustained peak demand is driven by a number of factors including:

- A number of buildings within the Wellington CBD that are currently undergoing re-development. High efficiency HVAC systems and better insulation and consumer side demand monitoring typically result in a reduction in demand for an existing connection point;
- Uptake of new technologies such as EVs, residential and commercial batteries, and residential PV generation and gas connections; and
- Observed diversity in peak load coincidence leading to a long term reduction of overall peak demand.
- Consumer response to pricing signals

8.2.5.1 Area Sustained Peak Demand Forecasts

Figure 8-12 shows the 60th percentile of the sustained peak demand for the three areas and the aggregate demand for the Wellington region.

⁵⁰ Estimated generation capacity during coincident peak






Figure 8-12 Wellington Region Aggregate Forecast

The forecasted sustained peak demand for each of the three areas of the Wellington Region shows short term peak demand growth. The Northwestern Area is forecast to experience the highest growth due to a number of residential developments expected. Overall sustained peak demand is expected to increase in the short term and level off over the long term due to uncertainties in long term step changes. Overall forecast changes are relatively small and the uncertainty is high. The changes are shown in Figure 8-12.



8.2.6 Network Area Peak Demand Forecasts

The forecast peak demand for each network area is described in more detail below. Sustained peak demand for each area is shown in Figure 8-13.

Area	Sustained Peak Demand (MVA)											
	2017 ⁵¹	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
Southern	259	263	264	264	264	266	266	266	267	267	268	267
Northwestern	115	118	121	123	123	123	125	125	125	125	125	126
Northeastern	180	187	189	193	194	196	197	197	198	199	198	199

Figure 8-13 Sustained Peak Demand by Network Area

8.2.6.1 Southern Area Forecast

Peak demand in the Southern Area has been flat or in decline in recent years but is expected to increase due to a number of new buildings planned over the coming years. The new building developments are expected within the inner city and along the water front, around the Parliamentary Precinct and a new development at Victoria University. However the impact of the November 2016 earthquake has introduced uncertainty in to the regional forecast. Figure 8-14 shows the summer and winter peak forecasts for the Southern Area.

⁵¹ The System Maximum Demand forecast is based on the 2017 sustained peak






Figure 8-14 Southern Area Forecast

Energy consumption within the Southern Area network has been flat or declining due to a general trend towards energy efficiency. This is most prevalent within the Wellington CBD, where initiatives such as high efficiency HVAC systems, better insulation and consumer side demand monitoring have caused a reduction in average rate of energy consumption while not affecting the peak demand.

8.2.6.2 Step Change Developments

Expected developments in the Southern Area include:

- A new science building with a maximum demand of around 2MVA at the Kelburn campus of Victoria University and a redevelopment of Rutherford House in the Wellington CBD;
- Approved customer connection requests for a number of new government and ministerial buildings along Molesworth Street;
- New customer connection projects in Kaiwharawhara and Ngauranga;
- High density residential and commercial developments in the Cuba and East Te Aro precincts, including the new Film Museum and Conference Centre;

- High density residential and commercial buildings along the waterfront;
- A new airport hotel at Wellington International Airport; and
- There are other tertiary institutions, hospitals and growth industries, such as businesses supporting the international film industry, which are likely to require future capacity.

While the timing of these developments is not certain, they have been included in the forecast by accounting for step change load growth on feeders supplying the relevant areas. Although not all of these will occur, other projects not currently included as step load changes will likely occur as replacements.

8.2.6.3 Northwestern Area Forecast

The Northwestern Area is continuing to grow organically with the strongest level of residential development within WELL’s network. There is relatively high interest for new residential subdivisions in the suburbs of Whitby, Grenada North and Churton Park. The Aotea subdivision, currently supplied from the Porirua and Waitangirua zone substations, is also an area of growth. Figure 8-15 shows a moderate increase in forecast summer peak and winter peak loading.




Figure 8-15 Northwestern Area Forecast

8.2.6.4 Step Change Developments

Expected developments in the Northwestern Area include:

- Residential and light commercial development at Upper and Lower Stebbings and Lincolnshire Farms by 2019;
- Medium density residential development is expected in the Johnsonville area, particularly around the town centre within the next 3 years;
- Residential development at Silverwoods in Whitby is expected to contribute 700kVA peak demand within the next 10 years;
- Residential and commercial development in the Aotea Block development area is expected to contribute 3.15 MVA within the next 10 years. Residential development is currently in progress at a rate of 100 lots or 150 kVA of additional peak demand per year. Commercial development in the Aotea Block business park is expected to provide a further 300 kVA per year in the last five years of development;
- The growth areas, identified by the Porirua City Council, north of Plimmerton (Northern Growth Area) and in the Pauatahanui-Judgeford areas. Development of these is expected to coincide with completion of the NZTA Transmission Gully project in 2019. Allowing for the expected growth based on maps of residential and commercial development, approximately 2.5 MVA of growth is estimated prior to the end of the planning period. Growth is expected at a rate of 150-300 kVA of peak demand per year for the last five years of the planning period; and
- Planned revitalisation of the Porirua city centre is expected to proceed within the next five years. The total growth contributed over the planning period is estimated to be 1.5 - 2.3 MVA.

While the timing of these developments is not certain, they have been included in the forecast by accounting for step change load growth on feeders supplying the relevant areas. Although not all of these will occur, other projects not currently included as step load changes will likely occur as replacements.

8.2.6.5 Northeastern Area Forecast

Peak demand in the Northeastern Area is expected to marginally increase due to localised residential and commercial developments. This is driven by planned residential sub-divisions and expansion plans of industrial consumers in the Trentham and Maidstone zone substation supply areas. Figure 8-16 shows the forecast peak demand over the planning period.






Figure 8-16 Northeastern Area Forecast

8.2.6.6 Step Change Developments

A number of developments are likely within the Northeastern Area, confirmed either through requests received for customer connections or through information requests from developers. The majority of step change loads expected are due to expansion of industrial facilities within the Trentham area.

Expected developments in the Northeastern Area include:

- Expansion of a customer data centre facility which will involve an additional two confirmed stages for a total increase in installed capacity of approximately 2 MVA over the next two years. New infrastructure is planned to provide the required capacity and security of supply to these facilities, while also providing increased inter-zone inter-connectivity within the network;
- Redevelopment of an existing industrial premise to house the new Ministry of Primary Industries research centre. A load increase of 1.5 MVA is expected within the next two years; and
- A new residential development in the Wallaceville area comprising 700 lots that will release 100 sections with an installed capacity of 300 kVA per year for four years, with an expected maximum demand of 1.2 MVA.



A number of smaller fabricating and manufacturing industries have expressed an interest in developing or expanding facilities within the Petone area. The quantity and magnitude of step change demand expected will offset the declining demand from residential and other businesses in the area.

8.2.7 GXP and Zone Level Demand Forecasts

The following tables show the GXP and zone substation level forecast for each Area within the Wellington network. Figure 8-17 shows the GXP level forecast by region and Figure 8-18 shows the Zone substation level forecast by region. For both tables, the base maximum demand value for the forecast is for the year ending 31 December 2017 and Area totals are coincident sustained peak demand values.

Area	GXP ⁵²	Actual and Forecast Sustained Peak Demand ⁵³ (MVA)											
		2017 Actual	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
Southern	Central Park 33 kV	152	156	157	157	157	159	159	159	159	159	160	161
	Central Park 11 kV	25	26	26	26	26	26	26	26	26	26	26	26
	Wilton 33 kV	52	57	57	57	57	57	57	57	57	57	57	57
	Kaiwharawhara 11 kV	30	32	32	32	32	32	32	32	33	33	33	32
Northwestern	Pauatahanui 33 kV	19	21	21	21	21	21	21	21	21	21	22	22
	Takapu Rd 33 kV	96	101	104	106	106	106	108	108	108	108	107	108
Northeastern	Gracefield 33 kV	62	65	66	68	69	69	70	70	70	70	70	70
	Haywards 33 kV	15	17	17	18	18	18	18	18	18	18	18	18
	Melling 33 kV	32	33	33	34	34	35	35	35	36	36	36	36
	Upper Hutt 33 kV	31	32	33	33	33	33	33	33	33	33	32	33
	Haywards 11 kV	17	19	19	19	19	19	19	19	19	20	20	20

⁵² Transpower's published P90 forecasts at the GXP level allow for a large margin of uncertainty, prudent for transmission level planning and as such, are not consistent with WELL's forecasts which are less conservative for the purposes of subtransmission and distribution planning.

⁵³ Forecast values are for the normal growth average seasonal temperature case correspond to the 60th percentile deduced from the peak demand range and include step change loading due to planned load transfer or confirmed customer connections.

Area	GXP ⁵²	Actual and Forecast Sustained Peak Demand ⁵³ (MVA)											
		2017 Actual	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
	Melling 11 kV	25	27	27	27	27	28	28	28	28	28	28	28

Figure 8-17 Wellington Area GXP Level Forecast

Area	Zone	Actual and Forecast Sustained Peak Demand ⁵⁴ (MVA)											
		2017 Actual	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
Southern Area	Palm Grove	26	27	27	27	27	27	27	27	28	28	28	28
	Frederick St	30	31	32	32	32	32	32	32	32	32	33	33
	Evans Bay	13	13	13	13	13	13	13	13	12	12	12	12
	Hataitai	17	17	17	17	17	18	18	18	18	18	18	18
	University	19	19	19	19	19	19	19	19	19	19	19	19
	The Terrace	31	32	33	33	33	33	33	33	33	33	33	33
	8 Ira St	16	16	16	16	16	17	17	17	17	17	17	18
	Nairn St	25	26	26	26	26	26	26	26	26	26	26	26
	Karori	16	16	16	16	16	16	16	16	16	16	16	16
	Moore St ⁵⁵	21 ⁵⁶	26	27	28	28	28	29	29	29	29	30	30
Waikowhai	15	15	15	15	15	15	15	15	15	15	15	15	
Northwestern Area	Mana-Plimmerton	19	21	21	21	21	21	21	21	21	21	22	22
	Johnsonville	22	23	23	24	24	24	25	25	25	25	25	26
	Kenepuru	12	13	14	14	14	14	14	14	14	14	13	13
	Ngauranga	10	11	12	13	13	13	13	13	13	13	13	13
	Porirua	21	22	22	22	22	22	23	23	23	23	23	23
	Tawa	15	15	16	16	16	16	17	17	17	17	17	17
	Waitangirua	16	17	17	17	17	17	17	17	17	17	17	17
Northeastern Area	Gracefield	11	12	12	13	13	13	13	13	13	13	13	13
	Korokoro	20	21	21	21	22	22	22	22	22	22	22	22
	Seaview	14	14	15	15	15	15	15	15	15	15	15	15

⁵⁴ Forecast values are for the normal growth average seasonal temperature case correspond to the 60th percentile deduced from the peak demand range and include step change loading due to planned load transfer or confirmed customer connections.

⁵⁵ The Terrace and Moore St zone substations have a summer peak. All other stations are winter peaking.

⁵⁶ Due to the impact of the 2017 Kaikoura Earthquake, Moore Street Zone Sub 2017 Actual Sustained Peak was 21MVA, however this is not considered for the long term forecast.

Area	Zone	Actual and Forecast Sustained Peak Demand ⁵⁴ (MVA)											
		2017 Actual	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
	Wainuiomata	17	18	18	19	19	19	20	20	20	20	20	20
	Trentham	15	17	17	18	18	18	18	18	18	18	18	18
	Naenae	16	17	17	17	17	18	18	18	18	18	18	18
	Waterloo	16	16	16	17	17	17	17	17	18	18	18	18
	Brown Owl	16	16	17	17	17	17	17	17	17	17	17	18
	Maidstone	15	16	16	16	16	16	16	16	16	16	16	15

Figure 8-18 Wellington Area Zone Substation Level Forecast

8.3 Overview of the Network Development and Reinforcement Plan (NDRP)

The NDRP describes the identified need, options and investment path for the network over the next 10 years. Each of the three network areas are largely electrically independent and have a different set of challenges. While planning for each network area uses a consistent methodology, they are not all equal in terms of the level of development required. A detailed external review of the development plan has been completed for the Southern and Northwestern Area networks which have higher development needs. A similar review for the Northeastern Area is planned for 2018.

The discussion for each area is structured in accordance with the network hierarchy of GXP level requirements, sub transmission and zone substations and then distribution level investments. The GXP level discussion has been developed with reference to Transpower's Annual Planning Report and other formal discussions with Transpower regarding their proposed development plans.

The NDRP for each network area is described the in the following sections.

8.4 Southern Area NDRP

This section provides a summary of the Southern Area NDRP. It is structured as follows:

- Potential GXP developments;
- Identified sub transmission and distribution development needs and options;
- The network development plan for the planning period; and
- A summary of the expected expenditure profile.

Details of the projects currently in progress or completed in the previous year are described in Appendix C.

8.4.1 GXP Development

The Southern network is supplied from three GXPs, Central Park, Wilton and Kaiwharawhara. The transformer capacity and the maximum system demand are set out in Figure 8-19.

GXP	Installed Capacity	Transformer Cyclic	Maximum Sustained Demand (MVA)
-----	--------------------	--------------------	--------------------------------

	(MVA)	N-1 Capacity (Firm Capacity, MVA)	2017	2028
Central Park 33 kV	2x100 + 1x120	200	152	161
Central Park 11 kV	2x25	30	25	26
Wilton 33 kV	2x100	106	52	57
Kaiwharawhara 11 kV	2x40	41	30	32
Total (after diversity)	-	-	259	267

Figure 8-19 Southern Area GXP Capacities

Many of the investment needs identified at Transpower GXPs have been detailed in Transpower's Transmission Planning Report. In 2017 WELL formally requested Transpower to carry out a resiliency and development option review at Central Park GXP and is currently in discussions with Transpower on various shortlisted options. Several risk mitigation initiatives are also planned for 2018. Further detail on this is outlined in Section 11.

The development need at each GXP is discussed further below.

8.4.1.1 Central Park GXP

The Central Park GXP consists of a sectionalised 33 kV bus and 14 sub transmission feeders to seven zone substations, two 33/11 kV transformers and an 11 kV bus. Each zone substation is supplied from two separate bus sections to provide N-1 redundancy. The 11 kV bus at Central Park supplies Nairn Street zone substation.

8.4.1.2 Wilton GXP

Part of the Wellington CBD is supplied from the Wilton 110 kV bus which has been identified as a risk and there is a project currently underway to rebuild it as a three-section bus. These works are due to be completed in 2018. This will address the supply diversity and resilience concerns at Wilton as each of the three Central Park circuits will be terminated to an individual bus section.

Transpower has also undertaken a risk assessment of a loss of key assets at Wilton, such as the entire 220kV or 110 kV bus structures, and has developed concept plans for bypass arrangements that would allow it to restore supply within short timeframes, should such an event occur.

Based on the demand forecasts, the loading will not breach the firm capacity at Wilton during the planning period.

8.4.1.3 Kaiwharawhara GXP

Transpower have no planned works at Kaiwharawhara and based on the demand forecasts, the loading will not exceed the firm capacity at Kaiwharawhara during the planning period.



8.4.2 Sub-transmission and Distribution Development Plans

This section describes the identified security of supply constraints and development needs for the Southern Area sub-transmission and distribution networks.

The distribution network supplying the Wellington CBD is a highly meshed system with overlapping supply boundaries resulting in a high level of inter-dependency between sites. Development options for the Wellington CBD therefore need to consider these inter-dependencies and the effect on the Wellington CBD network as a whole.

The Southern area network consists of 22 sub-transmission 33 kV circuits supplying 11 zone substations. Each zone substation supplies the respective 11 kV distribution network with inter-connectivity via switched open points to adjacent zones. The characteristics of each zone substation are listed in Figure 8-20. Assets causing capacity constraints are shown in red text in the table.

Zone Substation	Transformer Firm Capacity (MVA)	Single Incoming Circuit Capacity (MVA)		Peak Season	Sustained Peak Demand (MVA)		Date constraints are binding and season constrained	ICP counts as at 2018
		Winter	Summer		2017	2028		
Existing constraints								
Frederick St	36	23.2	19.5	Winter	30	33	Existing Winter and Summer constraint (24)	7,423
Palm Grove	24	34	32	Winter	26	28	Existing Winter constraint	10,179
The Terrace	30	34	32	Summer	31	33	Existing Summer constraint	1,597
Nairn St	30	25	25	Winter	25	26	Existing Winter and Summer constraint (26)	7,180
Forecasted constraints								
Hataitai	23	22	13	Winter	17	18	2022 Summer constraint (14)	6,779
Not Constrained								
Evans Bay	24	19	15	Winter	13	12	Not Constrained	4,879
University	24	25	20	Winter	19	19	Not Constrained	6,130

Zone Substation	Transformer Firm Capacity (MVA)	Single Incoming Circuit Capacity (MVA)		Peak Season	Sustained Peak Demand (MVA)		Date constraints are binding and season constrained	ICP counts as at 2018
		Winter	Summer		2017	2028		
Waikowhai	19	21	13	Winter	15	15	Not Constrained	5,843
Moore St	30	36	31	Summer	21	30	Not Constrained	785
8 Ira St	24	21	15	Winter	16	18	Not Constrained	4,849
Karori	24	21	11	Winter	16	16	Not Constrained	5,999

Figure 8-20 Southern Area Zone Substation Capacities

At the sub transmission level, WELL's planning criteria is to maintain N-1 capacity down to the 11 kV incomer level. A typical sub transmission circuit in the area is configured in the following manner:

- Cabling at 33 kV to the zone substation supply transformers. This consists of a double circuit arrangement terminating to separate supply transformers. Cables are operated at the cyclic rating. The magnitude of cyclic rating is determined by the ambient temperature (summer and winter) and pre-event loading;
- Zone substation 33 kV/11 kV supply transformers, in the 20-36 MVA range, fitted with oil circulation pumps and cooling fans to provide a higher cyclic rating; and
- 11 kV cabling from the 11 kV terminations of the transformers to the incomers on the switchboard which can potentially constrain the sub transmission circuit rating if undersized, is also considered a component of the sub transmission circuit.

The development needs for the Southern Area at the sub transmission and distribution level are outlined in the following sections.

8.4.2.1 Sub transmission Development Needs

Sub transmission constraints can be quantified in terms of duration of potential overload and assessed against the security criteria in Figure 8-, using a load duration curve. Forecasted constraints are quantified in terms of when the risk of overload is likely to occur based on the forecast peak demand for a given year.

The zone substations that are forecast to be beyond N-1 security during the planning period are described below.

Frederick Street

The sustained peak load supplied by Frederick Street currently exceeds the cyclic N-1 capacity of the sub transmission supply cables. The constraint is due to the heating effects of the two cables being in close proximity to each other at a pinch point in the streets of Wellington CBD. Work was undertaken in late 2015



to mitigate most, but not all, of the constraining sections. These works have resulted in an increase in the cyclic capacity of the Frederick Street sub transmission cables, from 17/21 MVA (summer/winter cyclic rating) to 19.5/23.2 MVA. The maximum demand at Frederick Street is still in excess of the sub transmission cable capacity.

Figure 8-21 illustrates the seasonal constraint levels and the minimum off load requirements on each circuit.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Frederick St 1	Winter	23.2	30.36	7.16
	Summer	19.5	21.76	2.26
Frederick St 2	Winter	23.2	30.36	7.16
	Summer	19.5	21.76	2.26

Figure 8-21 Current Frederick Street Sub transmission Constraints

Following a fault on the sub transmission system, WELL currently closes the 11 kV bus tie and restores supply to consumers through partially off-loading Frederick Street to an alternative zone substation.

Future step change loading on feeders inter-connecting with Frederick Street will reduce the available transfer capacity and post contingency offload will become difficult.

Figure 8-22 shows the load duration curve against the N-1 cyclic ratings of transformer and sub transmission cable.




Figure 8-22 Frederick Street Load Duration

The load duration curve shows the proportion of load is at risk. The loading exceeds the cable’s N-1 summer cyclic rating for approximately 5.2% of the time in summer and the cable’s N-1 winter cyclic rating for approximately 11.7% of the time in winter. This analysis uses a load duration curve based on 30 minute periods and is higher than the sustained peak.

In 2016 the load pattern in Frederick Street was showing a greater level of constraints in summer than winter but this has changed back to a traditional level of winter constraints in 2017.

Based on the estimated growth scenarios and step change growth accounted for within the planning period, the load at Frederick Street is forecasted to change as shown in Figure 8-23. The sub transmission capacity constraints are plotted for comparison.




Figure 8-23 Frederick Street Load Forecast

Palm Grove

The sustained peak demand at Palm Grove currently exceeds the capacity of the two 24 MVA transformers as illustrated in Figure 8.24.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Palm Grove 1	Winter	24	26.45	2.45
	Summer	24	19.89	0
Palm Grove 2	Winter	24	26.45	2.45
	Summer	24	19.89	0

Figure 8-24 Current Palm Grove Sub transmission Constraints

Following an outage of a single sub transmission circuit at Palm Grove during peak demand periods, the bus-tie is closed and switching is performed to move load to adjacent zones.

The back-feed switching must also be sequenced to maintain supply to Wellington Hospital as supply interruptions of any duration to the hospital are unacceptable. WELL continues to have discussions with the

Capital Coast District Health Board (CCDHB) about the potential options for mitigating the security of supply and resilience risks at Wellington Hospital. In December 2017, WELL presented several developed options to the CCDHB for security improvements and adding extra capacity, with the expectation of having a detailed solution study based on a shortlisted option completed in 2018.

Wellington Hospital and the CCDHB have also previously indicated high level plans to expand facilities within the planning period. The capacity and timing of these expansion plans are being worked through.

The magnitude of load at risk and duration is summarised in Figure 8-25.




Figure 8-25 Palm Grove Load Duration

The sustained peak demand loading during winter exceeds the N-1 transformer cyclic capacity for approximately 2.6% of the time during winter, which exceeds the security criteria for a CBD zone substation. The magnitude of this breach is expected to increase due to organic and step change load growth (with the impact of the additional capacity at the public hospital, private hospital and EV buses). This load duration curve is based on 30 minute periods and is higher than the sustained peak.

Based on the growth scenarios and the development accounted for within the planning period, the load at Palm Grove is forecasted to grow as shown in Figure 8-26.




Figure 8-26 Palm Grove Load Forecast

The Terrace

The sustained peak demand at The Terrace currently exceeds the capacity of the two 30 MVA transformers as illustrated in Figure 8-27.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
The Terrace 1	Winter	30	31.08	1.08
	Summer	30	29.46	0
The Terrace 2	Winter	30	31.08	1.08
	Summer	30	29.46	0

Figure 8-27 Current The Terrace Sub transmission Constraints

The load duration curve given in Figure 8-28 shows that over the last 12 month period the loading exceeds the transformer’s N-1 cyclic capacity for approximately 1.2% of the year, which is slightly above the CBD security criteria for a CBD zone substation.






Figure 8-28 The Terrace Load Duration

The magnitude of the exceedance is expected to increase due to organic growth in the area and step change growth from new capacity connections, to date about 1.5 MVA of additional load is scheduled to be online within the next 2 years, as shown in Figure 8-29. This load duration curve is based on 30 minute periods and is higher than the sustained peak. A strategy to manage future loading will be confirmed when the load is confirmed.




Figure 8-29 The Terrace Load Forecast

Nairn Street

The sustained peak demand at Nairn Street currently exceeds the capacity of the 11kV incomer cables from Central Park GXP, as shown in Figure 8-30.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Nairn St 1	Winter	25	25.1	0.1
	Summer	25	16.81	0
Nairn St 2	Winter	25	25.1	0.1
	Summer	25	16.81	0

Figure 8-30 Current Nairn Street Sub transmission Constraints

The load duration curve shows only a small portion of the yearly load duration (< 0.05%) is at risk and this is within the CBD security planning criteria.




Figure 8-31 Nairn Street Load Duration

The Nairn Street substation has very limited organic growth therefore the situation is not expected to further deteriorate. 1MVA of customer initiated projects will cause a step change increase in 2018 and this has been included in the load forecast.

WELL continues to monitor the substation peak load and develop remedial solutions accordingly.




Figure 8-32 Nairn Street Load Forecast

Hataitai

The sustained winter peak demand supplied by Hataitai is currently within the available N-1 capacity at the zone substation. However the summer rating of the sub transmission circuits is predicted to become a constraint in 2022.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2022 (MVA)	Minimum off load for N-1 @ peak (MVA)
Hataitai 1	Winter	22	18	0
	Summer	13	14	1
Hataitai 2	Winter	22	18	0
	Summer	13	14	1

Figure 8-33 Current Hataitai Sub transmission Constraints

WELL continues to monitor the load growth and will investigate options to mitigate the constraining sections through pinch point removal or other means to remove the system constraints.

The forecasted sustained peak demand at Hataitai is shown in Figure 8-34.




Figure 8-34 Hataitai Demand Forecast

8.4.2.2 Distribution Level Development Needs

The most critical distribution level issues are those associated with:

- Meshed ring feeders supplying a high number of consumers; and
- Links between zone substations which can be used for load transfer.

Figure 8-35 shows the current and forecast loading for each feeder. This is used to determine whether further contingency analysis of each individual feeder is required. Alongside each feeder the steady state control that has been applied to manage any risks that might arise has been provided.



Feeder	Topology	Zone Substation	Worst case loading from	Worst case loading to	Present Loading	+5 years	Feeder ICP Count	Control
Current								
EVA CB2/4	2 Fdr Mesh	Evans Bay	Evans Bay	69 Miramar Avenue	67%	67%	2,686	Monitor growth
FRE CB13/14	2 Fdr Mesh	Frederick Street	Frederick Street	21 Tasman Street	73%	77%	3,157	Network augmentation
HAI CB3/5	2 Fdr Mesh	Haitaitai	Taurima Street	Konini Road	54%	54%	2,219	Monitor growth
MOO CB1/2	2 Fdr Mesh	Moore Street	Moore Street	National Library	50%	53%	179	Monitor growth
MOO CB12/14	2 Fdr Mesh	Moore Street	50 Thorndon Quay	Stadium	60%	64%	42	Network augmentation
PAL CB8/10/12	3 Fdr Mesh	Palm Grove	Palm Grove	The Parade	70%	72%	4,990	Monitor growth
UNI CB8/10	2 Fdr Mesh	University	University	Chaytor Street	62%	62%	2,838	Monitor growth
UNI CB12	Radial	University	University	Adams Terrace	68%	68%	635	Monitor growth
NAI CB11/13	2 Fdr Mesh	Nairn Street	Moore Street	39 Brooklyn Road	51%	52%	2,716	Monitor Growth
KAR CB3/6	2 Fdr Mesh	Karori	Karori	Dasent Street	83%	76%	3,316	Network augmentation
KAI CB6/7/9/10	4 Fdr Mesh	Kaiwharawhara	Station Road	Abattoirs West	121%	127%	2,751	Customer initiated and funded project
Within Five Years								
MOO CB08	Radial	Moore Street	52 Mulgrave Street	18 Aitken Street	Less 50%	68%	50	Customer initiated and funded project

Figure 8-35 Distribution Level Issues

Cascade tripping of ring feeders for a loss of a single component feeder is a possibility due to the overcurrent settings applied at the zone substation. Settings are typically set for protection of the feeder breaker and an allowable short time overload of the cables. The sudden loss of a single feeder may result in the transfer of sufficient load to the remaining feeders and should not cause a trip of the feeder protection relays at the zone substation. Each subsequent trip would result in further overload of the remaining feeders. The result is the possible loss of the entire mesh ring and possible equipment damage due to overloading prior to the protection devices clearing.

Figure 8-36 shows the results of the contingency analysis performed on all meshed ring feeders in the Southern Area currently above the security criteria. Scenarios with overloading feeder segments for each

contingency scenario are shown as well as the prospective location and loading. The contingency loading calculation is based on the current sustained peak demand for each feeder.

Meshed Ring	N-1 Case	Feeder	To	From	Contingency Loading	Control
IRA 8/9	IRA CB08 Out	IRA CB09	Moa PT Treatment Plant	8 Ira St	106%	Optimise open points and monitor growth
FRE 3/4/5/6	FRE CB03 Out	FRE CB08	200 Wakefield St	21 Tory St	102%	Optimise open points and monitor growth
FRE 13/14	FRE CB13 Out	FRE CB14	Frederick St CB14	19 College St	109%	Network augmentation
	FRE CB13 Out	FRE CB13	Frederick St CB13	21 Tasman St	120%	
KAI 6/7/9/10	KAI CB06 Out	KAI CB09	Station Road	Abattoirs West	121%	Customer initiated project
	KAI CB07 Out	KAI CB09	Station Road	Abattoirs West	121%	
	KAI CB09 Out	KAI CB09	Station Road	Abattoirs West	121%	
	KAI CB10 Out	KAI CB09	Station Road	Abattoirs West	121%	
UNI 8/10	UNI CB08 Out	UNI CB10	University CB10	Military Rd	115%	Optimise open points and monitor growth
		UNI CB11	University CB11	Chaytor St	114%	
KAR 3/6	KAR CB03 Out	KAR CB06	Karori CB06	Burrows Ave	146%	Network augmentation
	KAR CB06 Out	KAR CB03	Karori CB03	Dasent St	145%	

Figure 8-36 Meshed Ring Feeder Contingency Analysis



8.4.3 Southern Area Sub transmission and Distribution Development Options

This section summarises the options available to meet the development needs described above.

As the distribution network within the Southern Area is highly meshed, the development options for the Wellington CBD are comprised of a combination of the individual solutions required to meet each need. Each individual solution is not mutually exclusive and as such there are options which meet several needs for the same investment.

8.4.3.1 Non-network Solutions

Prior to any investment in any infrastructure being considered, the first step is to implement non-network solutions to defer investment. These options include:

- Open point shifts using existing infrastructure to reduce loading on highly loaded feeders;
- Operational changes to better utilise existing network capacity over construction of redundant capacity; and
- Consideration of the cost effectiveness of demand side management to alleviate localised network constraints.

These non-network solutions will be implemented prior to any network investment. WELL currently monitors feeder loading using SCADA alarm limits to provide indication prior to thermal overload of assets. Where thermal overload limits are at risk of being exceeded, network controllers are able to:

- Initiate shedding of hot water load to provide peak shaving during peak demand periods; and
- Fine tune network open points to optimise feeder loading and feeder customer numbers.

8.4.3.2 Network Investment Options

Common Development Projects

A number of projects within the Wellington CBD will be required to augment the network and improve security of supply. These projects are required irrespective of the development option selected and are as follows:

- A new feeder from Moore Street to reinforce the Moore Street 12/14 ring feeder, interconnecting with feeders from Kaiwharawhara and supplying Westpac Stadium and Centerport. This is dependent on the recovery strategy of the port following the November 2016 Kaikoura earthquake and customer funding being made available;
- Balancing bus section load at a number of zone substations, which will involve physically swapping feeders between the two bus sections;
- The installation of a new 33 kV protection scheme at Evans Bay which will defer replacement of the Evans Bay cables which have a low asset health condition. Although this investment has a condition based driver, it has been included in the network development section because of its impact on the configuration of the 33 kV sub transmission network; and



- Installation of bus-tie changeover schemes at all zone substations in the Southern Area to allow rapid restoration of supply following sub transmission faults.

Southern Area Development Options

Two network development options have been identified and evaluated against the development needs described in Sections 8.4.2.1 and 8.4.2.2.

The two options assessed for the planning period are:

- Option 1: Installation of a new zone substation supplied from Central Park GXP with distribution level interconnections to The Terrace, Frederick Street and Palm Grove; and
- Option 2: Augmentation of the existing sub transmission and distribution infrastructure to alleviate constraints and improve transfer capacity.

Two studies were commissioned to determine costing and feasibility to a higher degree of confidence such that an informed decision can be made as to the recommended development path. These studies were:

- Feasibility and cost estimation of establishing a new zone substation within the CBD;
- Review and cost estimation of the Network Development and Reinforcement Plan, and all component projects for the two options listed above.

Each of the options is described in more detail below.

Option 1: Installation of a New Zone Substation

This option involves installation of a new zone substation, supplied from Central Park GXP. The new zone substation would have distribution feeders inter-connecting with Frederick Street, Kaiwharawhara and Palm Grove. The proposed distribution connectivity is to ensure this option will mitigate the identified issues with an integrated solution.

Load would be permanently transferred from the highly loaded feeders from Palm Grove and Frederick Street to the new zone substation. This would have the effect of alleviating loading constraints at the distribution and sub transmission level at both of these sites.

Figure 8- 37 illustrates the final configuration of Option 1.






Figure 8-37 Proposed Configuration for Option 1

The implementation of the option would be staged to align with the timing of constraints as they arise.

A pre-feasibility study into establishing a new zone substation in the CBD has provided a $\pm 30\%$ cost estimate for the zone substation component of this option. The separate external review of the NDRP has provided more detailed costing ($\pm 30\%$) of all sub transmission and distribution works required in addition to the establishment of the new zone substation. The cost of this network development option is shown in Figure 8-38.

Project Description	Cost (\$M)
Construction of a zone substation within the CBD ($\pm 30\%$) and network reinforcement	22.4
Planned common projects for both options	13.0
Total Southern Area NDRP Investment - Option 1	35.4
Condition-based Asset Renewal Expenditure	9.0
Comparative NPV (total cost less common projects plus renewal expenditure*)	20.9

Figure 8-38 Estimated Cost of Network Development Option 1

*Note: The asset renewal expenditure under Option 1, used in the NPV analysis is \$9 million. This is lower than accounted for in Option 2 (\$12.5 million), as it reduces the criticality of a number of switchboards in the CBD, allowing capital expenditure deferral.

Option 2: Sub transmission & Distribution Level Augmentation

Option 2 involves augmentation of the sub transmission and distribution networks to alleviate the identified issues. It provides for distribution reinforcement projects to improve capacity and security of supply. Sub transmission issues are mitigated through load transfer to adjacent zone substations or by upgrading asset capacity.

This option includes:

- Replacing the sub transmission cables to Frederick Street with new high capacity XLPE cables. These cables will offer sufficient capacity to cater for the expected growth at Frederick Street while also providing redundant capacity for contingency operation.
- Alleviating the issues at Palm Grove in isolation from the rest of the network. Further sub transmission capacity is provided by replacing the Palm Grove transformers with two new 30MVA units (36MVA cyclic). The Palm Grove 2/3/6 feeder ring is to be reconfigured and reinforced to alleviate loading on this distribution ring and improve security of supply to Wellington Hospital and the Newtown area. The existing inter-connections between Palm Grove and Nairn Street are reinforced to provide post-contingency transfer capacity for a sub transmission fault at Palm Grove.

Figure 8-39 provides a visual representation of the end product of this development path.






Figure 8-39 Proposed Configuration for Option 2

The estimated cost of implementation of this network development option is shown in Figure 8-40.

Project Description	Cost (\$M)
Total marginal cost of network reinforcement for capacity	6.5
Planned common projects for both options	13.0
Total Southern Area NDRP Investment - Option 2	19.5
Condition-based Asset Renewal Expenditure	12.0
Comparative NPV (total cost less common projects plus renewal expenditure*)	12.2

Figure 8-40 Estimated Cost of Network Development Option 2

8.4.4 The Southern Area Development Plan

Option 2 is the most cost effective option which mitigates all identified issues while also ensuring a balanced network

It has the benefit of introducing high capacity ties between critical zone substations as well as increasing capacity and replacing aging sub transmission assets. It involves the following major milestones and timing of works to mitigate the identified constraints in the cost effective manner:

- **2018** – Open point shifts to temporarily alleviate distribution level constraints and defer network investment till 2019;
- **2018 - 2020** – Replacement of the Frederick Street gas filled sub transmission cables with new high capacity XLPE cables to improve capacity at Frederick Street;
- **2021 – 2023** – Reinforcement of the Palm Grove 2/3/6 feeder ring; and
- **2025** – Replacement of the transformers at Palm Grove with higher capacity units.

The majority of identified feeder loading risks will be eliminated by the end of the planning period. A number of feeder overloads at Moore Street, Palm Grove and Nairn Street are accepted on the basis of the ability to enact contingency load shifts to an adjacent zone following retrofit of remote switching and telemetry to a number of network critical distribution switching points throughout the network. Frederick and Karori feeder augmentations will be resolved by the allowances included in the summary provided in section 8.4.5.

Condition based asset replacement/refurbishment projects identified in this development plan were discussed further in Section 7.

8.4.5 Summary of the Southern Area Investment

Figure 8-1 shows the investment plan projects in the Wellington Southern area for the planning period from 2018-2028.



Year	Project	Estimated Cost (\$M)	Comments
2018	Evans Bay 33 kV Protection Scheme – Year 1	0.3	Common Project
	Bus-tie changeover implementation - Year 1	0.3	Common Project
	Frederick Street Sub transmission Cable Replacement and Protection Upgrade – Year 1	2.1	NDP Option 2
	Allowance for minor cable reinforcement works	0.3	Common Project
Year Total		3	
2019	Evans Bay 33 kV Protection Scheme – Year 2	0.9	Common Project
	Frederick Street Sub transmission Cable Replacement and Protection Upgrade – Year 2	1.5	NDP Option 2
	Moore Street - New Feeder	1.1	Common Project
	Bus-tie changeover implementation - Year 2	0.4	Common Project
	Allowance for minor cable reinforcement works	0.3	Common Project
Year Total		4.2	
2020	Balance loading on Kaiwharawhara bus	0.1	NDP Option 2
	Frederick Street Sub transmission Cable Replacement and Protection Upgrade – Year 3	0.7	NDP Option 2
	Bus-tie changeover implementation – Year 3	0.3	Common Project
	Allowance for minor cable reinforcement works	0.4	Common Project
Year Total		1.5	
2021	Palm Grove 2/3/6 Ring Reinforcement - Stage 1	1.1	NDP Option 2
	Allowance for minor cable reinforcement works	0.4	Common Project
Year Total		1.5	
2022	Balance loading on Frederick Street bus	0.1	NDP Option 2
	Palm Grove 2/3/6 Ring Reinforcement - Stage 2	1.2	NDP Option 2
	Allowance for minor cable reinforcement works	0.4	Common Project
Year Total		1.7	
2023	Palm Grove 2/3/6 Ring Reinforcement - Stage 3	2.2	NDP Option 2
	Allowance for minor cable reinforcement works	0.4	Common Project
Year Total		2.6	

Year	Project	Estimated Cost (\$M)	Comments
2024	Allowance for minor cable reinforcement works	0.5	Common Project
2025	Replacement of the Palm Grove Transformer - Year 1	0.3	NDP Option 2
	Allowance for minor cable reinforcement works	0.5	Common Project
Year Total		0.8	
2026	Replacement of the Palm Grove Transformer - Year 2	2.7	NDP Option 2
	Allowance for minor cable reinforcement works	0.5	Common Project
Year Total		3.2	
2027	Allowance for minor cable reinforcement works	0.5	Common Project
	Total Investment	19.5	

Figure 8-41 Summary of Southern Area Investment Requirement (\$M in constant prices)

8.5 Northwestern Area NDRP



Porirua City looking North⁵⁷

This section provides a summary of the Northwestern Area NDRP. This section is structured as follows:

- Identified GXP development needs;

⁵⁷ Photography credit: Porirua City Council

- Identified sub transmission and distribution level development needs and options;
- The network development plan for the planning period; and
- A summary of the expected expenditure profile.

Detail of each project in the development plan is described in Appendix C.

8.5.1 GXP Development

The Northwestern Area is supplied from two GXPs, Pauatahanui and Takapu Road. The transformer capacity and the sustained maximum demand are set out in Figure 8.42.

GXP	Installed Capacity (MVA)	Transformer Cyclic N-1 Capacity (Firm Capacity, MVA)	Maximum Demand (MVA)	
			2017	2028
Takapu Rd 33 kV	2x90	116	96	108
Pauatahanui 33 kV	2x20	24	19	22
Total (after diversity)	-	-	115	126

Figure 8-42 Northwestern Area GXP Capacities

Many of the investment needs identified at Transpower GXPs have been detailed in Transpower's Transmission Planning Report.

The development need at each GXP is discussed further below.

Takapu Road

The Takapu Road GXP comprises two parallel 110/33 kV transformers each nominally rated at 90 MVA with a potential N-1 cyclic capacity of 116 MVA. The sustained maximum demand on the Takapu Road GXP in 2017 was 96 MVA. Takapu Road supplies zone substations at Waitangirua, Porirua, Kenepuru, Tawa, Ngauranga and Johnsonville each via double 33 kV circuits.

WELL began execution of a staged programme to replace the aging protection devices on the sub transmission circuits supplied from Takapu Road.

The Ngauranga sub transmission circuits from Takapu Rd GXP are 110 kV lines, operating at 33 kV, installed on steel pylon towers and owned and maintained by Transpower. A number of factors need to be considered in determining the long term viability of this arrangement such as:

- Maintain status quo;
- Transpower's preference to decommission the overhead lines in the future;
- WELL taking ownership of the 110 kV lines; or
- The possibility of undergrounding the lines from Takapu Road.

Pauatahanui

Due to works to transfer the Paraparaumu GXP to a new tee off point on the Bunnythorpe-Haywards 220kV lines, Pauatahanui is now solely supplied from the Takapu Road GXP via two 110 kV circuits. With the removal of Paraparaumu from the 110 kV network, these circuits are significantly over rated for Pauatahanui requirements.

Pauatahanui GXP comprises two parallel 110/33 kV transformers rated at 20 MVA each. The sustained peak demand on the Pauatahanui GXP in 2017 was 19 MVA. This is within the transformer emergency ratings and also the winter cyclic rating of 24 MVA. The Pauatahanui GXP supplies the Mana and Plimmerton zone substations via a single 33 kV overhead circuit connection to each substation. Mana and Plimmerton zone substations are linked at 11 kV providing a degree of redundancy should one of the 33 kV connections be out of service.

Transpower has identified that the Pauatahanui supply transformers are approaching end-of-life and that replacement will be required within the next 5-10 years, which coincides with the site loading exceeding the N-1 rating. At the time of replacement a capacity upgrade may be required, with the future ratings still to be determined. WELL will discuss with Transpower the potential options for alleviating or replacing the Pauatahanui supply transformers.

WELL will also consider an upgrade of the sub transmission differential protection from this site within the planning period.

8.5.2 Sub transmission and Distribution Development Plan

This section describes the identified security of supply constraints and development needs for the Northwestern Area sub transmission and distribution networks.

The Northwestern network consists of 12 sub transmission 33 kV circuits supplying seven zone substations. Each zone substation supplies the respective zone 11 kV distribution network with inter-connectivity via switched open points to adjacent zones. All 11 kV feeders are radial from the zone substations with the exception of the meshed ring feeders supplying the Porirua CBD and the Titahi Bay switching station. The characteristics of each zone substation are listed in Figure 8-43.



Zone Substation	Transformer Firm Capacity (MVA)	Single Incoming Circuit Capacity (MVA)		Peak Season	Sustained Peak Demand (MVA)		Date constraints are binding and season constrained	ICP counts as at 2018
		Winter	Summer		2017	2028		
Existing constraints								
Mana-Plimmerton	16	33	23	Winter	19	22	Existing Winter constraint	6,683
Porirua	20	22	14	Winter	21	23	Existing Winter and Summer constraint (19)	3,597 ⁵⁸
Johnsonville	23	21	14	Winter	22	26	Existing Winter and Summer constraint (17)	8,348
Waitangirua	16	25	19	Winter	16	17	Existing Winter constraint	5,432
Forecasted constraints								
Ngauranga	12	20	14	Winter	10	12	2019 Winter constraint	4,044
Tawa	16	25	17	Winter	15	16	2019 Winter constraint	5,120
Not Constrained								
Kenepuru	23	19	14	Winter	12	13	Not Constrained	2,082

Figure 8-43 Northwestern Area Zone Substation Capacities

The development needs for the Northwestern Area at the sub transmission and distribution level are outlined in the following sections.

⁵⁸ ICP counts for Porirua include Titahi Bay.

8.5.2.1 Sub transmission Development Needs

Sub transmission constraints can be quantified in terms of duration of risk and assessed against the security criteria in Figure 8-1, using a load duration curve. Forecasted constraints are quantified in terms of when the risk is likely to occur based on the forecast peak demand for a given year.

The zone substations that are forecast to be constrained during the planning period are described below.

Mana & Plimmerton

There are two constraints at Mana and Plimmerton zone substations. These are:

- The combined load at the two zone substations presently exceed the N-1 rating of the transformers at peak times; and
- Should the 33 kV circuit supplying Plimmerton zone transformer be out of service, the Plimmerton peak load cannot be supplied from Mana zone substation through the existing 11 kV tie cable and load transfer is required.

The current load at risk at Mana/Plimmerton is shown in Figure 8-44.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Mana-Plimmerton	Winter	16	18.9	2.9
	Summer	16	13.6	0

Figure 8-44 Mana-Plimmerton Combined N-1 Capacity

Post contingency of either the Mana or Plimmerton transformers, the load is served via the 11 kV bus-tie between the two zone substations. The capacity of the bus tie is lower than the sustained peak demand at Mana. This is illustrated in Figure 8-45.

Circuit	Season	Mana-Plimmerton Bus-tie capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Mana	Winter	7	9.8	2.8
	Summer	7	7.8	0.8
Plimmerton	Winter	7	9.1	2.1
	Summer	7	8.1	1.1

Figure 8-45 Mana-Plimmerton N-1 Capacity

Figure 8-46 shows the load duration curve against the N-1 cyclic rating of the 11 kV bus-tie.






Figure 8-46 Mana-Plimmerton Bus-tie Load Duration

The load duration plot shows that the worst case is an outage of the Mana sub transmission circuit where the peak demand at Mana would exceed the available capacity of the bus-tie for approximately 7.7% of the time in a year.

In the short term, WELL can move load between Mana, Plimmerton and Waitangirua, to manage the capacity within ratings.

There is a risk that future step change loading at Mana and Plimmerton will reduce the available transfer capacity and post contingency offload will be less effective.

Figure 8-47 shows the load duration curve against the N-1 cyclic ratings of transformer and sub transmission cable.




Figure 8-47 Mana-Plimmerton Load Duration

The load duration curve shows that at present, demand exceeds N-1 sub transmission capacity for approximately 2.6% of the time in a year during winter. While this is currently within the acceptable security criteria, step change demand expected within the planning period will increase the duration load to greater than the security criteria.

This load duration curve is based on 30 minute periods and is higher than the sustained peak.

Based on the estimated growth scenarios and development growth within the planning period, the load at Mana-Plimmerton can be forecasted for a range of growth and seasonal scenarios as shown in Figure 8-8. The sub transmission capacity constraints are plotted for comparison.




Figure 8-48 Mana-Plimmerton Load Forecast

The load forecast shows that a proportion of load is at risk in the winter periods and from 2021 a summer constraint is likely to occur. The magnitude and timing of the risk will be driven by the load growth due to development of residential subdivisions in the Whitby and Aotea areas.

Porirua

The peak load supplied at Porirua exceeds the n-1 transformer ratings during the winter period, and the 33kV circuit rating during summer. The risk of having further constraints is dependent on planned step change demands due to re-development of the Porirua city centre and a number of residential subdivisions in the Whitby and Aotea areas.

Following a fault on the sub transmission system, load will need to be off-loaded from Porirua to an alternative zone substation.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Porirua A	Winter	20	21.4	1.4
	Summer	14	18.3	4.3
Porirua B	Winter	20	21.4	1.4
	Summer	14	18.3	4.3

Figure 8-49 Porirua Sub transmission Capacity Shortfall

Subdivisions in the Whitby and Aotea areas will involve commercial centres such as shopping precincts and business premises. Porirua City Council has published plans for re-vitalisation of the Porirua city centre, involving a new plaza, re-development of the Porirua civic precinct and a number of other initiatives.

Figure 8-50 shows the load duration curve against the N-1 cyclic ratings of transformer and sub transmission cable.




Figure 8-50 Porirua Load Duration

The load duration curve shows that at present, demand exceeds N-1 sub transmission capacity for approximately 1.9% of the time during winter and 7.8% during summer. A step change demand of 0.6MVA is expected within the next two years which may increase the peak load duration further. Based on the estimated growth scenarios and confirmed step change loads within the planning period, the load at Porirua is forecast to grow as shown in Figure 8-51.




Figure 8-51 Porirua Load Forecast

The shortfall in N-1 capacity could increase to 2-4 MVA by the end of the planning period.

Johnsonville

The sustained peak load supplied by Johnsonville is currently exceeds the cyclic N-1 capacity of the sub transmission circuits. A greater level of constraint exists in summer than winter due to the lower summer rating of the cables.



Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Johnsonville A	Winter	21	22.4	1.4
	Summer	14	15.8	1.8
Johnsonville B	Winter	21	22.4	1.4
	Summer	14	15.8	1.8

Figure 8-52 Johnsonville sub transmission capacity shortfall

Figure 8-53 shows the load duration curve against the N-1 cyclic ratings of transformer and sub transmission cables for Johnsonville. The load duration curves shows that at present the demand exceeds the firm capacity less than 1.7% of the year. This is within the network security standard for a mixed commercial and residential zone substation.




Figure 8-53 Johnsonville Load Duration

Based on the estimated growth scenarios and confirmed step change loaded within the planning period, the load at Johnsonville is forecasted to grow as show in Figure 8-134.




Figure 8-134 Johnsonville Load Forecast

Waitangirua

At present, sustained peak demand at Waitangirua has just exceeded the available N-1 sub transmission capacity, however step change demand in the short term may result in this constraint being further exceeded in 2018.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Waitangirua A	Winter	16	16.2	0.2
	Summer	16	8.7	0
Waitangirua B	Winter	16	16.2	0.2
	Summer	16	8.7	0

Figure 8-55 Waitangirua Sub transmission Capacity Shortfall

Load duration curve shows peak demand during winter period exceeds the N-1 capacity by a small margin; this is within the planning security criteria.




Figure 8-56 Waitangirua Load Duration⁵⁹

Based on the estimated growth scenarios and confirmed step change loads within the planning period, load at Waitangirua is forecast for a range of growth and seasonal scenarios as shown in Figure 8-57.

⁵⁹ Summer Chart was not complete due to missing SCADA data




Figure 8-57 Waitangirua Load Forecast

The magnitude and timing of further loading will be driven by the step change demand due to development at residential subdivisions in Whitby and Aotea.

Ngauranga

The Ngauranga sub transmission circuits from Takapu Rd GXP are repurposed 110 kV lines installed on steel pylon towers, owned and maintained by Transpower.

In late 2016, a temporary load shift has moved approximately 2 MVA of load from Ngauranga to Johnsonville. This was done to alleviate the immediate N-1 risk at Ngauranga but is a temporary measure due to the forecast demand increase at Johnsonville. It is expected that after the N-1 risk at Ngauranga is addressed this load will be shifted back. At present, the duration for which the loading at Ngauranga just exceeds the available N-1 sub transmission cyclic capacity during winter is within the security criteria. It is expected that load growth at Ngauranga will result in exceeding the security criteria within the next two years. The load at risk is shown in Figure 8-58.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2019 (MVA)	Minimum off load for N-1 @ peak (MVA)
Ngauranga 1	Winter	12	12.4	0.4
	Summer	12	10	0
Ngauranga 2	Winter	12	12.4	0.4
	Summer	12	10	0

Figure 8-58 Ngauranga Sub transmission Capacity Shortfall

Based on the estimated growth scenarios and development growth within the planning period, the forecasted load at Ngauranga is shown Figure 8-59. The transformer capacity constraints are plotted for comparison. If current trend continues the substation is expected to exceed its N-1 capacity by winter 2019.




Figure 8-58 Ngauranga Load Forecast

Tawa

At present, maximum demand at Tawa is within available N-1 sub transmission capacity. It is expected that with growth the sustained peak demand could exceed the N-1 cyclic capacity by 2023.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2023 (MVA)	Minimum off load for N-1 @ peak (MVA)
Tawa A	Winter	16	17.3	1.3
	Summer	16	14.2	0
Tawa B	Winter	16	17.3	1.3
	Summer	16	14.2	0

Figure 8-60 Tawa Sub transmission Capacity Shortfall

The forecast sustained peak demand at Tawa is shown in Figure 8-




Figure 8-61 Tawa Load Forecast

8.5.2.2 Distribution Level Development Needs

The most critical distribution level issues are those associated with overload of the meshed ring feeder supplying a high number of consumers or links between zones which can be used for load transfer.

Figure 8-62 below shows where the applicable security criteria for the feeder configurations are exceeded and an estimation of when the constraints bind.

This is utilised to determine whether further contingency analysis of each individual feeder is required. Alongside each feeder the steady state control that has been applied to manage any risks that might arise has been provided.

Feeder	Topology	Zone Substation	Worst case loading from	Worst case loading to	Present	+5 years	Feeder ICP Count	Control
Current								
JOH CB3	Radial	Johnsonville	Johnsonville	11 Burdendale Grove	67%	76%	1,454	Monitor growth
JOH CB6	Radial	Johnsonville	Bannister Avenue No 01	19 Cortina Avenue	85%	89%	1,662	Network augmentation
MAN CB2	Radial	Mana	Mana	Ivey Bay	68%	71%	1,560	Monitor growth
NGA CB4	Radial	Ngauranga	IS133	n96	73%	79%	481	Open point shift
TAW CB11	Radial	Tawa	Tawa	Countdown Takapu Island	67%	70%	514	Monitor growth
POR CB4/5	2 Fdr Mesh	Porirua	Porirua	Lyttelton Ave B	78%	78%	348	Network augmentation
POR CB1/11	2 Fdr Mesh	Porirua	Porirua	Titahi Bay	76%	76%	3,084	Network augmentation
WTA CB5	Radial	Waitangirua	Hicks Close	Spinnaker Drive C	78%	81%	1,515	Network augmentation
WTA CB11	Radial	Waitangirua	Loongana Street	Waihemo Street A	72%	78%	1,404	Monitor growth
Within Five Years								
JOH CB10 ¹	Radial	Johnsonville	Clifford Road A	28 Hawtrey Terrace	62%	67%	995	Monitor growth

Figure 8-62 Distribution Level Issues

Figure 8-63 shows the results of the contingency analysis performed on the meshed ring feeder supplying the Porirua CBD which currently exceeds the security criteria. Overloading feeder segments for each contingency scenario are shown as well as the location of worst case loading. The contingency loading calculation is based on the peak demand for each feeder recorded for 2017.



Meshed Ring	Topology	N-1 Case	Feeder	Worst case loading to	Worst case loading from	Contingency Loading	Mesh ICP Count	Control
POR 1/11	2 Fdr Mesh	POR out 01	POR 11	Titahi Bay ZS	Porirua	141%	2261	Network augmentation
		POR out 11	POR 01	Titahi Bay ZS	Porirua	141%		
POR 4/5	2 Fdr Mesh	POR out 04	POR 05	Lyttleton Ave B	Porirua	118%	348	Network augmentation
		POR out 05	POR 04	7 Titahi Bay Rd	Porirua	116%		

Figure 8-63 Meshed Ring Feeder Contingency Analysis

8.5.3 Northwestern Sub transmission and Distribution Development Options

This section describes the development options available to mitigate the constraints described above.

The development options for the Northwestern Area are comprised of a combination of the individual solutions required to meet each need. Each individual solution is not mutually exclusive and as such there are solutions which meet several needs for the same investment.

The purpose of this section is to describe those development options, establish the overall economic cost of each and identify the optimal staging of investments over the period. As it is impractical to cover all possible combinations of solutions, this section covers four primary development options. Each option has been refined before being presented here to ensure that it is practical. Each result in a different supply risk profile based on the solutions utilised.

8.5.3.1 Non-network Solutions

Prior to any investment in any infrastructure being considered, the first step is to implement non-network solutions to defer significant short term investment. These options include:

- Open point shifts using existing infrastructure to reduce loading on highly loaded feeders;
- Operational changes to better utilise existing network capacity over construction of redundant capacity; and
- Consideration of the cost effectiveness of demand side management to alleviate localised network constraints.

These non-network solutions will be implemented prior to any network investment. WELL currently monitors feeder loading using SCADA alarm limits to provide indication prior to thermal overload of assets. Where thermal overload limits are at risk of being exceeded, network controllers are able to:

- Initiate shedding of hot water load to provide peak shaving during peak demand periods (in the Northwestern Area, ripple injection is at the zone substation level); and

- Fine tune network open points to optimise feeder loading and feeder customer numbers.

8.5.3.2 Network Investment Options

Common Development Projects

A number of projects will be required to replace assets and improve security of supply. These projects are required irrespective of the development option selected and are as follows:

- Installation of communication and protection links between all zone substations in the Porirua basin to provide protection and SCADA communications while also accommodating future IP connectivity;
- Switching to balance sub transmission loading between Mana and Plimmerton. These works are implemented in lieu of a SPS scheme to limit the load at Mana/Plimmerton to within the capacity of the bus-tie to provide for N-1 security;
- A number of isolated distribution level projects are required in areas to reduce the risk of supply outages to areas with high customer counts or high priority customers; and
- Installation of sectionaliser scheme for Tawa/Kenepuru sub transmission circuits.

Northwestern Area Development Options

The development needs in the Northwestern Area can be separated into two independent areas:

1. North of Tawa, the Porirua Basin and up to Plimmerton. This area is supplied from Porirua, Waitangirua, Mana and Plimmerton zone substations (area referred to as the North below); and
2. The Northwestern suburbs between Ngauranga and Tawa. This area is supplied from Ngauranga, Johnsonville, Tawa and Kenepuru zone substations (area referred to as the South below).

For each area studies have shown that there are two distinct methods for mitigating the issues in each:

- a. Augmentation of existing network infrastructure through network upgrades; or
- b. Installation of a new zone substation.

Together the combination of these aspects create four development options for the Northwestern Area. The four options are:

1. Augmentation in both the North (1a) and the South (2a): Replacement of sub transmission assets where required, distribution level augmentation to relieve highly loaded feeders;
2. Installation of a new zone substation in the North (1b) and augmentation in the South (2a): Install a new zone substation in the Pauatahanui area; replace the Ngauranga transformers and shift open points in Johnsonville, Ngauranga and Tawa to relieve highly loaded feeders;
3. Augmentation in the North (1a) and install a new zone substation in the South (2b): Replace the Mana and Plimmerton transformers and install new distribution infrastructure to relieve highly loaded feeders and optimise loading between Porirua, Waitangirua, Mana and Plimmerton; install a new zone substation in the Grenada area; and



4. Installation of a new zone substation in the North (1b) and install a new zone substation in the South (2b): Install two new zone substations, one in the Grenada area and one in Pauatahanui. Optimise loading by shifting open points.

There are a number of benefits that each option offers, which need to be considered against the cost of each option. For example, the installation of a new zone substation at Pauatahanui provides the opportunity to mitigate the identified transmission constraints due to the capacity and age of the supply transformers by either:

- Upgrading the capacity of the Pauatahanui 110/33 kV transformers to provide capacity to the new Pauatahanui zone substation;
- Replacing the existing Pauatahanui 110/33 kV transformers with three-winding units and supplying a new Pauatahanui zone substation at 11 kV; or
- Installing two new 110/11 kV transformers at Pauatahanui to supply a new Pauatahanui zone substation.

Options involving a new zone substation in Grenada (Options 3 and 4) provide the opportunity to potentially decommission the Ngauranga zone substation. All supplied load from Ngauranga could be transferred to the new Grenada zone substation and Johnsonville, such that Ngauranga could be decommissioned.

The benefits and the costs of each option are described in more detail below.

Option 1: Augmentation in both the North (1a) and the South (2a)

This option involves augmentation of the sub transmission and distribution networks in both the north and south areas to alleviate the identified issues.

A number of open point changes are made to optimise loading in the network. The distribution augmentation projects are then implemented to overlay undersized cable segments and improve feeder capacity at Ngauranga, reinforce the distribution ring supplying the Porirua city centre and improve the inter-connectivity and capacity of the Waitangirua distribution network. A number of smaller projects are enacted around these works to alleviate localised distribution level constraints, replace aging assets and improve security of supply.

The demand at Pauatahanui GXP is constrained by the capacity of the 110/33 kV transformers. WELL would need to initiate a project with Transpower to replace these transformers with higher rated units as part of this option.

Figure 8- provides a visual representation describing the final network configuration from development path.






Figure 8-64 Network Configuration Option 1

The estimated cost of this network development option is shown in Figure 8-.

Project Description	Cost (\$M)
Total marginal cost of network reinforcement	11.4
Common Projects for all options (communication & protection links + common cable reinforcements)	3.1
Total NW Area NDRP Investment - Option 1	14.5
Additional condition-based asset renewal projects required under Option 1	5.7
Total cost of Option 1	20.2
Comparative NPV (total cost less common projects plus renewal expenditure)	11.9

Figure 8-65 Estimated Cost of Network Development Option 1

The benefits of this option are:

- Replaces assets nearing end of life, or posing a risk to network resilience;
- Increases capacity into high growth areas and zones with existing capacity constraints; and
- Projects can be separated into many discreet elements and scheduled to provide a more uniform investment profile.

The risks associated with this option are:

- Does not cater for long term growth outside of planning period or growth in excess of forecast; and
- Capacity based asset replacement at some sites where asset condition is generally good, but assets are highly utilised.

Option 2: Installation of a New Zone Substation in the North (1b) and Augmentation in the South (2a)

This option involves establishment of a new zone substation in the Pauatahanui/Whitby area, supplied from Pauatahanui GXP, to provide capacity for future growth in the North and relieve the loading at Waitangirua, Porirua, Mana and Plimmerton. The new zone substation would have distribution feeders inter-connecting with a number of highly loaded feeders within the Porirua basin.

There are three potential sub-options to provide sub transmission supply to this new zone substation:

1. Installation of new 33 kV cabling from Takapu Road. These cables would be terminated directly to two new 33/11 kV 24 MVA transformers. These transformers will feed the Pauatahanui zone substation bus. These works could be a customer initiated project with Transpower and funded through increased connection charges;
2. Installation of two new bays on the 110 kV bus at Pauatahanui GXP. The new 110 kV bays would supply two new 110/11 kV 24 MVA transformers, with an estimated cost of \$3 million. These works would be a customer initiated project with Transpower and funded through increased connection charges; or
3. Replacement of the existing Pauatahanui 110/33 kV transformers with two new 110/33/11 kV transformers with capacity of at least 50 MVA. These transformers would supply both the 33 kV bus at Pauatahanui and the 11 kV bus at the new Pauatahanui zone substation. These works would be a customer initiated project with Transpower and funded through increased connection charges.

The recommended sub-option is to initiate a project with Transpower to replace the existing 110/33 kV transformers at Pauatahanui with two new 110/33/11 kV units.

A number of distribution level works will be enacted to overlay undersized cable segments and improve feeder capacity of Ngauranga, where feeders are connected to the Grenada area, as well as to reinforce the distribution ring supplying the Porirua city centre. Installation of a new zone substation in the Pauatahanui/Whitby area allows for reduction of utilisation at Mana and Plimmerton, potentially negating replacement of the transformers at these stations. Upgrade of the transformers at Ngauranga will be required.

Figure 8- provides a visual representation describing the final network configuration from the development path.




Figure 8-66 Network Configuration Option 2

The benefits of this option are:

- Introduces a new connection point from an independent GXP into the high growth areas in Porirua, Waitangirua, Mana and Plimmerton;
- Alleviates capacity constraints at Waitangirua, Porirua, Mana and Plimmerton.
- Relieves loading constraints due to the capacity of the Pauatahanui GXP 110/33 kV transformers;
- Targeted distribution augmentation projects alleviate issues within the Ngauranga 11 kV network; and



- Defers age based replacement of assets by reducing utilisation and criticality.

The risks associated with this option are:

- Requires significant financial and time investment to establish a new zone substation; and
- The investment profile during the planning period is not uniform, and is instead clustered around two years of investment required for each zone substation project.

The estimated cost of this network development option is shown in Figure 8-.

Project Description	Cost (\$M)
New Pauatahanui Zone Substation & additional network reinforcement	10.9
Common Projects for all options (communication & protection links + common cable reinforcements)	3.1
Total NW Area NDRP Investment - Option 2	14.0
Additional condition-based asset renewal projects required under Option 2*	3.0
Total Cost of Option 2	17.0
Comparative NPV (total cost less common projects plus renewal expenditure)	10.9

Figure 8-67 Estimated Cost of Network Development Option 2

*Note: The asset renewal expenditure under Options 2 and 4, used in the NPV analysis is \$3 million. This is lower than accounted for in Options 1 and 3 (\$5.7 million), as it reduces the criticality of a number of assets in the North, allowing capital expenditure deferral.

Option 3: Grenada Zone Substation and Whitby/Aotea Network Augmentation

This option includes installation of a new zone substation at Grenada. This station will be supplied from Takapu Road GXP and established on a section of land in Grenada North, which has been pre-designated for construction of a new zone substation. This zone substation will have feeders interconnecting with highly loaded feeders from Ngauranga, Johnsonville and Tawa.

A number of distribution level works will be implemented to overlay undersized cable segments and improve feeder capacity at Ngauranga as well as to reinforce the distribution ring supplying the Porirua city centre. Transformer replacement will be required at Mana and Plimmerton by 2020 and Waitangirua by 2021.

To provide subtransmission supply to a new Grenada zone substation, the three options available are:

1. Installation of a 33 kV switching station to provide a 33kV bus to the new zone substation via from the TKR-NGA sub transmission circuits. This tee-off will supply 2x24 MVA transformers at the Grenada zone substation. The incremental cost of these works is expected to be \$4.4 million;
2. Directly tee-off the TKR-NGA sub transmission circuits via fused disconnects or solid links, similar to the Tawa/Kenepuru tee-off. This tee-off will supply 2x24 MVA transformers at the Grenada zone substation. The incremental cost of these works is expected to be \$3.4 million; or

3. Install new sub transmission cabling from Takapu Road. These new cables will supply two new 24 MVA transformers at the Grenada zone substation. The incremental cost of these works is expected to be \$5.4 million.

The recommended option is to install a 33 kV switching station to provide a 33kV bus to the new Grenada zone substation from the TKR-NGA sub transmission circuits.

Installation of a new zone substation in the Grenada area allows reduction in Ngauranga zone substation load to either reduce the utilisation of the Ngauranga transformers or to allow eventual decommissioning.

The demand at Pauatahanui GXP is constrained by the capacity of the 110/33 kV transformers. WELL will need to initiate a project with Transpower to replace these transformers with higher rated units within as part of this option.

The Figure 8- provides a visual representation describing the final network configuration from the development path.






Figure 8-68 Network Configuration Option 3

The benefits of this option are:

- Introduces a new connection point into the high growth areas in Grenada;
- Alleviates capacity constraints at Ngauranga due to Grenada residential developments;
- Targeted distribution augmentation projects to alleviate issues within Waitangirua, Porirua, Mana and Pimmerton 11 kV networks; and
- Offers the opportunity to decommission Ngauranga zone substation, avoiding costly asset renewal at this site.

The risks associated with this option are:

- Requires significant investment to establish a new zone substation
- The investment profile during the planning period is not uniform, and is instead clustered around two years of investment required for each zone substation project; and
- Significant distribution augmentation and asset replacement is still required at Waitangirua, Porirua, Mana and Plimmerton.

The estimated cost of this network development option is shown in Figure 8-.

Project Description	Cost (\$M)
New Grenada Zone Substation & additional network reinforcement	21.6
Common Projects for all options (communication & protection links + common cable reinforcements)	3.1
Total NW Area NDRP Investment - Option 3	24.7
Additional condition-based asset renewal projects required under Option 3	5.7
Total cost of Option 3	30.4
Comparative NPV (total cost less common projects plus renewal expenditure)	16.6

Figure 8-69 Estimated Cost of Network Development Option 3

Option 4: Pauatahanui Zone Substation and Grenada Zone Substation

This option involves installation of two new zone substations, one in Grenada and the other in the Pauatahanui/Whitby area. These new stations provide for the expected growth in the Porirua basin as well as relieving all current constraints.

The new zone substation at Pauatahanui will defer replacement of the transformers at Waitangirua, Mana and Plimmerton outside of the planning period while the new zone substation at Grenada offers the opportunity to partially or completely offload the Ngauranga zone substation. Replacement of the Ngauranga transformers will be driven by condition and may be deferred till the end of the planning period.

A number of smaller projects are enacted around these works to alleviate localised distribution level constraints, replace aging assets and improve security of supply.

Figure 8- provides a visual representation describing the final network configuration from the development path.






Figure 8-70 Network Configuration Option 4

The benefits of this option are:

- Introduces new connection points into the high growth areas in Grenada, Porirua, Waitangirua, Mana and Plimmerton;
- Relieves loading constraints due to the capacity of the Pauatahanui GXP 110/33 kV transformers;
- Defers age based replacement of assets at Ngauranga, Waitangirua, Mana and Plimmerton by reducing utilisation and criticality; and
- Caters for long term network growth in the Northwestern area.

The risks associated with this option are:

- Requires significant investment to establish two new zone substations; and

- The investment profile during the planning period is not uniform, and is instead clustered around two years of investment required for each zone substation project.

The estimated cost of this network development option is shown in Figure 8-.

Project Description	Cost (\$M)
New Pauatahanui Zone Substation	7.2
New Grenada Zone Substation & additional network reinforcement	12.5
Common Projects for all options (communication links + common cable reinforcements)	3.1
Total NW Area NDRP Investment - Option 4	22.8
Additional condition-based asset renewal projects required under Option 4	3.0
Total cost of Option 4	25.8
Comparative NPV (total cost less common projects plus renewal expenditure)	15.0

Figure 8-71 Estimated Cost of Network Development Option 4

8.5.4 The Northwestern Area Development Plan

The most cost effective solution which mitigates all identified issues while also ensuring optimised network capacity and security of supply is Option 2: Installation of a new zone substation in the North (1b) and augmentation in the South (2a).

Option 2 involves the following discrete milestones and timing of works to mitigate the identified constraints in the most feasible and cost-effective manner:

- **2018** – Open point shifts will be enacted to alleviate a number of distribution constraints at Tawa, Porirua and Ngauranga;
- **2019** – Reinforce Porirua CBD ring by increasing meshing. A new cable will be installed between 17 Parumoana Street and 14 Parumoana Street. This project will be initiated by any customer connections which result in the planning criteria of the Porirua CBD ring being exceeded;
- **2020** – Install a new feeder from Porirua zone substation to reinforce the Porirua CBD ring and provide additional supply security and capacity for projected growth due to the Porirua city centre revitalisation initiative;
- **2020-2021** – Replace the transformers at Ngauranga with higher capacity units. The existing transformers are at an advanced age and constrain capacity for growth in the Johnsonville, Newlands, Woodridge and Grenada areas;
- **2020-2021** – Install a new zone substation to supply load in the Whitby and Aotea areas. This new zone substation would consist of a new 11 kV bus in the vacant land adjacent to the Pauatahanui GXP. The existing Pauatahanui 110/33 kV transformers are at an advanced age and constrain capacity for growth. A customer project will be initiated to replace these units with new 110/33/11 kV transformers providing at least 50 MVA of N-1 capacity; and



- **2022-2023** – Open point shifts will be enacted to alleviate a distribution constraint within the Plimmerton distribution network.

The majority of identified feeder overloads will be eliminated by the end of the planning period. Construction of a new zone substation in Grenada, as indicated in previous AMPs, has been deferred in lieu of increasing sub transmission and distribution capacity at Ngauranga by replacing the Ngauranga transformers and reinforcing the distribution network.

The loading issues at Mana / Plimmerton will be mitigated in the short term by demand side management and a separate investigation project is schedule in 2018 to improve capacity transferability between Mana, Plimmerton, Titahi Bay and Waitangirua.

Loading issue at Johnsonville will be addressed by improving tie points with Ngauranga and Tawa.

8.5.5 Summary of the Northwestern Area Investment

Figure 8- shows the investment plan for growth and reinforcement projects in the Northwestern area for the planning period from 2018-2028. All sub transmission protection relay and RTU replacement projects are categorised as asset renewal expenditure, as detailed in Section 7. Further detail of each project is provided in Appendix C.

Year	Project	Estimated Cost	Comments
2018	Reinforce the Porirua CBD Ring - Stage 1	0.2	Common Project
	Takapu Road Communications - Stage 2 (2018)	0.4	Common Project
	Allowance for minor cable reinforcement works	0.3	Common Project
Year Total		0.9	
2019	Allowance for minor cable reinforcement works	0.3	Common Project
	Titahi Bay cable reinforcement works	1.0	Common Project
Year Total		1.3	
2020	New Pauatahanui Zone Substation – Stage 1	0.5	NDP Option 2
	Reinforce the Porirua CBD Ring - Stage 2	1.0	Common Project
	Replace the Ngauranga Transformers – Stage 1	0.5	NDP Option 2
	Allowance for minor cable reinforcement works	0.3	Common Project
Year Total		2.3	
2021	New Pauatahanui Zone Substation – Stage 2	1.5	NDP Option 2
	Replace the Ngauranga Transformers – Stage 2	3.0	NDP Option 2
	Allowance for minor cable reinforcement works	0.3	Common Project
Year Total		4.8	

Year	Project	Estimated Cost	Comments
2022	New Zone Substation distribution links to Waitangirua and Mana/Plimmerton – Stage 1	2.0	NDP Option 2
	Allowance for minor cable reinforcement works	0.5	Common Project
Year Total		2.5	
2023	New Zone Substation distribution links to Waitangirua and Mana/Plimmerton – Stage 2	1.7	NDP Option 2
	Allowance for minor cable reinforcement works	0.5	Common Project
Year Total		2.2	
2024	Allowance for minor cable reinforcement works	0.5	Common Project
	New Zone Substation distribution links to Waitangirua and Mana/Plimmerton – Stage 3	1.0	NDP Option 2
Year Total		1.5	
2025	Allowance for minor cable reinforcement works	0.5	Common Project
2026	Allowance for minor cable reinforcement works	0.5	Common Project
2027	Allowance for minor cable reinforcement works	0.5	Common Project
	Total Investment	17.0	

Figure 8-72 Summary of Northwestern Area Growth Investment Requirement
(\$M in constant prices)



8.6 Northeastern Area NDRP



The Hutt Valley⁶⁰

This section provides a summary of the Northeastern Area NDRP. This section is structured as follows:

- Identified GXP development needs;
- Identified sub transmission and distribution level development needs and options;
- The network development plan for the planning period; and
- A summary of the expected expenditure profile.

8.6.1 GXP Development

The Northeastern area is supplied from four GXPs. Gracefield and Upper Hutt provide sub transmission supply at 33 kV while Melling and Haywards GXPs provide sub transmission supply at 33 kV and 11 kV. The transformer capacity and the maximum system demand are set out in 8-73.

GXP	Installed Capacity (MVA)	Transformer Cyclic N-1 Capacity (Firm Capacity, MVA)	Maximum Demand (MVA)	
			2017	2028
Gracefield 33 kV	2x100	89	62	70

⁶⁰ Photography credit: Hutt City Council)

GXP	Installed Capacity (MVA)	Transformer Cyclic N-1 Capacity (Firm Capacity, MVA)	Maximum Demand (MVA)	
			2017	2028
Haywards 33 kV	1x20	20	15	18
Melling 33 kV	2x50	52	36	35
Upper Hutt 33 kV	2x40	37	32	36
Haywards 11 kV	1x20	20	17	20
Melling 11 kV	2x25	30	25	28
Total (after diversity)	-	-	180	199

Figure 8-73 Northeastern Area GXP Capacities

Gracefield

Currently there are two transformers at Gracefield, which provide 33 kV supply to four WELL zone substations (Wainuiomata, Gracefield, Seaview and Korokoro). There are no capacity and security constraints at Gracefield as the sustained peak demand at this GXP is below the N-1 supply transformer capacity.

Haywards

Haywards supplies Trentham zone substation via a 33 kV outdoor bus and an 11 kV switchboard, which is fed by a 20 MVA 110/11 kV transformer in parallel with a 5 MVA 33/11 kV transformer. The loss of either of the 110/33 kV or 110/11 kV supply transformers has a significant impact on system security.

Transpower has identified the need to replace the existing transformers at Haywards due to their condition, with is scheduled to completed by late 2019. Outages required for routine maintenance and similar activities require back-feed switching at the distribution level due to the atypical configuration of the supply to the Haywards 33 kV and 11 kV buses.

Transpower have indicated that the preferred solution is to install two three-winding 60/30/30 MVA transformers to provide N-1 security for both 11 kV and 33 kV supplies. The final configuration of the new transformers has been confirmed and this requires minor modifications for the Wellington Northeastern network.

Upper Hutt

The Upper Hutt GXP comprises two parallel 110/33 kV transformers nominally rated at 37 MVA each, supplying a 33 kV bus that feeds zone substations at Brown Owl and Maidstone through underground 33 kV fluid-filled cables.

Transpower currently has completed a project to replace the existing Upper Hutt GXP 33 kV outdoor bus with an indoor switchboard. WELL will look to upgrade all sub transmission differential protection on the



Brown Owl and Maidstone circuits and interface the new protection and RTUs to the recently commissioned Transpower equipment.

Melling

The Melling GXP comprises a conventional arrangement of two parallel 110/33 kV transformers nominally rated at 50 MVA each, supplying a 33 kV switchboard that feeds the zone substations of Waterloo and Naenae. A separate 11 kV switchboard is supplied by a parallel arrangement of two 110/11 kV transformers nominally rated at 30 MVA each.

The capacity of the 110/11 kV transformers is restricted due to the limit imposed by the protection scheme. Transpower propose to resolve this protection limitation to increase the cyclic capacity of the transformers.

WELL's own demand forecast shows that the cyclic capacity of the transformers is sufficient for the level of growth anticipated during the planning period. However, the increased capacity from the resolution of the protection imposed capacity limit will allow greater flexibility for post-contingency operation.

8.6.2 Sub transmission and Distribution Development Plans

This section describes the identified security of supply constraints and development needs for the Northeastern Area sub transmission and distribution networks.

8.6.2.1 Sub transmission Development Needs

The Wellington Northeastern network consists of nine sub transmission 33 kV circuits supplying nine zone substations. Each zone substation supplies the respective 11 kV distribution network with inter-connectivity via switched open points to adjacent zones. The Haywards and Melling GXP 11 kV switchboards directly feed into the distribution network. The characteristics of each zone substation are listed in Figure 8-.



Zone Substation	Transformer Firm Capacity (MVA)	Single Incoming Circuit Capacity (MVA)		Peak Season	Sustained Peak Demand (MVA)		Date constraints are binding and season constrained	ICP counts as at 2018
		Winter	Summer		2017	2028		
Existing constraints								
Korokoro	23	16	12	Winter	20	22	Existing Winter and Summer constraint (13)	3,777
Forecasted constrains								
Wainuiomata	20	21	14	Winter	18	20	2022 Summer constraint (15)	6,709
Not Constrained								
Waterloo	23	23	14	Winter	16	18	Not Constrained	5,810
Trentham	23	23	17	Winter	15	18	Not Constrained	5,172
Gracefield	23	20	15	Winter	11	13	Not Constrained	2,597
Seaview	22	18	13	Winter	14	15	Not Constrained	2,845
Naenae	23	22	18	Winter	16	18	Not Constrained	6,289
Maidstone	22	19	14	Winter	15	15	Not Constrained	4,436
Brown Owl	23	22	16	Winter	16	18	Not Constrained	6,312

Figure 8-74 Northeastern Area Zone Substation Capacities

Notes to Figure 8-

- 1: The capacity of the Korokoro sub transmission cables is currently being investigated including 3 potential pinch points.
- 2: The total number of ICPs supplied from Korokoro zone substation also includes those previously supplied from Petone.
- 3: N-1 capacity at Wainuiomata zone substation is constrained by the rating of the relocated 20 MVA transformer from Petone.



Korokoro

The peak load supplied at Korokoro currently exceeds the N-1 cyclic capacity of the sub transmission cables as shown in Figure 8-.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2017 (MVA)	Minimum off load for N-1 @ peak (MVA)
Korokoro 1	Winter	16.6	20.2	3.6
	Summer	12.6	15.3	2.7
Korokoro 2	Winter	18.2	20.2	3.6
	Summer	12.6	15.3	2.7

Figure 8-75 Korokoro Sub transmission Capacity Shortfall

The peak demand at Korokoro is expected to increase to 22.4 MVA by the end of this AMP planning period, increasing the capacity shortfall to approximately 6 MVA. Following a fault on the sub transmission system, WELL restores supply to consumers through partially off-loading Korokoro to an alternative zone substation. Available distribution level transfer capacity is sufficient at most times to back-feed sufficient load to avoid overloading the remaining transformer, however the key constraint is on the sub transmission circuit which is currently going through a thermal rating investigation. In addition, all required switching points are manually operated, thus the restoration time will be dependent on the speed of field response.

Figure 8- shows the load duration curve against the N-1 cyclic ratings of transformer and sub transmission cable.




Figure 8-76 Korokoro Load Duration

The load duration curve shows that a significant proportion of load is at risk during summer. The loading exceeds the N-1 cyclic ratings of the sub transmission cables for approximately 13.1% of the time in summer and 7.2% of the time in winter.

Based on the estimated growth scenarios and development within the planning period, the sustained peak load at Korokoro is forecasted as shown in Figure 8-




Figure 8-77 Korokoro Load Forecast

Wainuiomata

The sustained peak demand supplied by Wainuiomata is currently within the available N-1 capacity of the zone substation and sub transmission circuits. This is illustrated in Figure 8-.

Circuit	Season	Constraining N-1 Cyclic capacity (MVA)	Sustained Peak Demand @ 2020 (MVA)	Minimum off load for N-1 @ peak (MVA)
Wainuiomata 1	Winter	21	19.2	0
	Summer	14.2	14.3	0.1
Wainuiomata 2	Winter	21	19.2	0
	Summer	14.2	14.3	0.1

Figure 8-78 Wainuiomata Substation Constraints

The organic growth at Wainuiomata is forecast to increase the sustained peak demand in summer period to 14.3MVA in 2020. There are also a number of step change projects including new subdivisions and retirement village to be developed within the supplied zone. Load growth in Wainuiomata is expected to exceed the N-1 ratings of the sub transmission circuit in 2020 as illustrated in Figure 8-. WELL is monitoring the load growth and have been in discussion with the local council to better assess the situation, to ensure appropriate solution is implemented for the area.




Figure 8-79 Wainuiomata Load Forecast

8.6.2.2 Distribution Level Development Needs

The most critical distribution level issues are those associated with overload radial feeders supplying critical loads. Figure 8- shows where the applicable security criteria for the various feeder configurations are breached and an estimation of when the constraints bind.

Feeder	Topology	Zone Substation	Worst case loading from	Worst case loading to	Present	+5 years	Feeder ICP Count	Control
Current								
BRO CB8	Radial	Brown Owl	3 Norbert Street	4 Shanly Street	74%	78%	1,397	Network augmentation
GRA CB8	Radial	Gracefield	Coal Research	DSIR Computer	68%	65%	7	Monitor growth
MEL CB4	Radial	Melling	Firths Melling	Melling Railway Station	67%	70%	1,303	Monitor growth
MAI CB6	Radial	Maidstone	12 Brown Street	Leisure Centre	73%	69%	1,012	Monitor growth
WAT CB5	Radial	Waterloo	C327	Trafalgar Street Kiosk	74%	74%	1,727	Monitor growth
HAY CB2722 ¹	Radial	Haywards (GXP)	HAY Load Control	Fergusson Drive A	82%	82%	1,499	Network augmentation
Within 5 Years								
MAI CB11	Radial	Maidstone	32 Lane Street	Japsen Green	44%	67%	811	Network augmentation and Open Point Shift
NAE CB2	Radial	Naenae	Owen Street No 03	Belmont Kiosk	56%	67%	1,009	Monitor growth

Figure 8-80 Distribution Level Issues

Notes to Figure 8-

1: HAY2722 was reinforced during 2016 and the new capacity is reflected in this table.

The identified highly loaded feeders supplied from Maidstone, Waterloo and Haywards are predicted to decline in load over the planning period and may not require mitigation.

8.6.3 Northeastern Network Development Plan

More work will be undertaken to develop a comprehensive Northeastern development plan in 2018.

For budgeting purposes, an allowance has been included for various distribution level works. This allowance has been provisioned from 2019 onwards and will be subject to any consumer driven step change load growth in the area and to mitigate the constraints at Korokoro. The allowance is estimated based on the average distribution level reinforcement costs for a year and provides for:

- Overlay of approximately 400 m of undersized 11 kV cable including trenching, traffic management and reinstatement costs; and
- Installation of approximately 600 m of new distribution links between zones at 11 kV.

All legacy growth and reinforcement projects planned for the Northeastern area and detailed in previous AMPs have been completed or are deferred in lieu of a consolidated strategy which will be provided by the forthcoming Northeastern area NDRP.

Figure 8- shows the investment plan for growth and reinforcement projects in the Northeastern Area for the planning period.

Year	Project	Estimated Cost	Comment
2018	Reinforcement to alleviate constraints at Korokoro – Stage 1	0.2	Common Projects
2019	Reinforcement to alleviate constraints at Korokoro – Stage 2	0.3	Common Projects
	Trentham 33kV VRR Scheme	0.3	Common Projects
Year Total		0.6	
2020	Allowance for minor cable reinforcement works	0.2	Common Projects
2021	Allowance for minor cable reinforcement works	0.2	Common Projects
2022	Allowance for minor cable reinforcement works	0.5	Common Projects
2023	Allowance for minor cable reinforcement works	0.5	Common Projects
2024	Allowance for minor cable reinforcement works	0.5	Common Projects
2025	Allowance for minor cable reinforcement works	0.5	Common Projects
2026	Allowance for minor cable reinforcement works	0.5	Common Projects
2027	Allowance for minor cable reinforcement works	0.5	Common Projects
	Total Investment	4.2	

Figure 8-81 Summary of Northeastern Area Investment Requirement
(\$M in constant prices)



8.7 Customer Initiated Projects and Relocations

These projects have been aggregated in the budget in accordance with the categories discussed below. Overall, the budgeted expenditure for 2018 is \$6.8 million. Consumer and developer confidence and the Chorus UFB roll out activity remains high compared with recent years.

8.7.1 New Connections

For the fifth consecutive year the number of residential building consents issued in the Wellington region has risen, driven by the growth in apartments within the Wellington CBD and subdivision growth along the northern belt. Figure 8- shows the number of building consents issued for new houses and apartments over the last seven years. This is expected to decline over time.




Figure 8-82 Number of Building Consents Issued in the Wellington Region

8.7.2 Substations

Budgeted spend of \$4.2 million for 2018 includes a \$2.0 million allowance for two large individual development projects in Upper Hutt (MPI and Rivera). Excluding this, the remaining forecast spend of \$2.2 million is in line with the past three years.

8.7.3 Subdivisions

While small and infill subdivisions remain at similar levels to previous years, developers continue a trend seen in 2016 where appetite for large scale residential (>100 lots) subdivisions is increasing, particular in the northern areas of Wellington and Porirua cities. This is partially offset by industrial property development which has slowed, and the shortage of vacant sites that can be easily converted to meet tenancy needs. The budget allocation for subdivisions in 2018 is \$1.2 million.

8.7.4 Capacity Changes

Expenditure associated with transformer upgrades or downgrades is included within the customer substation area of the customer connection forecasts.

8.7.5 Relocations

An allowance in 2018 of \$2.1 million for relocation and undergrounding work, initiated from NZTA and TLAs, as well as other customer initiated relocations, has been made. Transmission Gully and

redevelopment of a major SH2 intersection are critical projects in this category as well as costs associated with the Chorus UFB roll out.

8.7.6 Consumer Connections

The total forecast consumer connection capital expenditure for 2018 to 2028 is presented in Figure 8-83.

Consumer Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Substation	4,258	4,289	4,356	4,356	4,708	4,732	4,756	4,779	4,803	4,827
Subdivision	1,235	1,125	1,252	2,210	2,802	2,830	2,773	2,787	2,801	2,815
High Voltage Connection	131	133	136	139	141	144	147	150	153	156
Residential Consumers	1,111	1,127	1,154	1,170	1,198	1,215	1,244	1,262	1,292	1,310
Public Lighting	100	100	100	100	100	100	100	100	100	100
Total	6,835	6,774	6,998	7,975	8,949	9,021	9,020	9,078	9,149	9,208

Figure 8-83 Consumer Connection Capital Expenditure Forecast
(\$K in constant prices)

8.7.7 Asset Relocations

The forecast asset relocation capital expenditure, primarily related to roading projects, is presented in Figure 12-4.

Programme	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Roading Relocations	2,151	1,648	1,714	1,731	1,748	1,766	1,784	1,801	1,819	1,838
Total	2,151	1,648	1,714	1,731	1,748	1,766	1,784	1,801	1,819	1,838

Figure 8-84 Asset Relocation Capital Expenditure Forecast
(\$K in constant prices)



8.8 Summary of the Capital Expenditure Forecasts

From the details in the sections above, WELL's network development and growth capital expenditure forecast is summarised in the table in Figure 8-85.

Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Southern Area	3,000	4,200	1,500	1,500	1,700	2,600	500	800	3,200	500
Northwestern Area	900	1,300	2,300	4,800	2,500	2,200	1,500	500	500	500
Northeastern Area	200	600	200	200	500	500	500	500	500	500
System Growth & Reinforcement Total	4,100	6,100	4,000	6,500	4,700	5,300	2,500	1,800	4,200	1,500

Figure 8-85 Capital Expenditure Forecasts – 2018 to 2028
(\$K in constant prices)

This page is intentionally blank





Section 9

Emerging Technology

9 Emerging Technology

This chapter sets out WELL's development plan for emerging technologies over the next 10 years. It is consistent with views of the Business New Zealand Energy Council who have highlighted three major themes for change in the energy industry being:

- Digitalisation;
- Decarbonisation; and
- Decentralisation.

The purpose of this development plan is to describe how WELL will adapt to the potential impact and opportunities from new technology in order to maintain a safe, flexible and secure network.

Emerging technologies and other factors driving changes in the energy sector will have varying impacts on the electricity network, such as:

- Increased demand due to electrification. A drive for de-carbonisation (reduction in greenhouse gas emissions) leads to electrification of some processes and consequent increases in electricity demand;
- Reduced demand due to energy efficiency with the adoption of new energy efficient processes and replacement of older equipment with new energy efficient equipment reduces electricity demand;
- Supply quality challenges causing issues such as voltage fluctuations, low power factors and high harmonic distortion levels predominately on LV circuits at customer connection points caused by emerging technology type load connections;
- New consumer behaviours seen by the adoption of new technologies with digital interfaces that allow a higher level of interaction and for customers to actively participate in the electricity market and take advantage of consumer level load management;
- Distributed energy resources improving economics of new technologies make it easier for customers to develop distributed energy resources;
- Energy cost reduction as new technologies adopted by consumers and interfaced to the network will provide cost effective and reliable energy solutions to consumers and necessitate optimising asset utilisation and applying demand side management by networks, to avoid incurring significant costs to manage the impact of uncertainties.; and
- Regulatory change bringing new requirements, policies or asset management practices introduced by the regulators in relation to emerging technologies.

Such changes and their impacts bring a level of uncertainty which will need to be addressed at the distribution network level. This requires distribution companies to play an active role in co-ordination with consumers, equipment suppliers, retailers and the national grid operator.

The underlying investment plans in this AMP are based on historical load forecast techniques. Changes in customer requirements have the potential to significantly alter these loadings and therefore the forward investment required on the network. This becomes more of a problem on the LV network where changes have the greatest impact for consumers. Improving visibility of usage and demand in the LV network will enable WELL to better manage the LV assets that most consumers are connected to.



An increase in EV uptake, in line with government targets, may start to seriously impact parts of the LV network in the next 5-10 years resulting in power quality and asset performance issues if not managed effectively. Effective management will ensure WELL can avoid or lessen large network reinforcement requirements so the network is capable of delivering on these demands. The impact will also depend on the concurrent uptake in other technologies such as solar PV.

Figure 9-1 shows the traditional model of energy transfer where transmission companies (such as Transpower) deliver electricity from generators to network operators (such as WELL). The network operator then distributes electricity to consumers via substations and the distribution network, with limited and often no information available on the stress and strain points on the LV (400V) network or on the actual real-time usage by individual consumers.




Figure 9-1 Traditional Network Operations

Figure 9-2 shows the future of the same model where consumers start to invest in emerging technologies such as PV, battery storage systems and EVs. This leads to a potential two-way power flow between network operators and consumers. Lack of visibility of stress and strain points on the LV network and usage patterns of consumers could lead to network reinforcement requirements should uncontrolled usage be allowed to occur. In order to defer such reinforcement requirements, the network operator will require greater visibility of the network and a better understanding of consumer demands.




Figure 9-2 Potential Future of the Electrical Network

Depending on the mix of new technology that occurs across the network, there is also an increased risk of stranding network assets. WELL's view is that this will generally not be the case in the Wellington region. There may be small portions of the network where underutilisation may pose to be a risk to capital recoveries over the lifetime of assets but this will not be the case for the majority of the network. WELL's response to these challenges will set it on a potential transformation path to becoming a Distribution System Operator (DSO), providing consumers with a platform to manage emerging technologies. This will enable WELL to integrate new technologies into the network, allowing power flows in both directions and ultimately providing greater long term benefits to consumers.

WELL's strategy to manage this path to becoming a DSO is to:

- Leverage connections from being part of the CK Infrastructure Group to monitor trends globally and similarly leverage connections to New Zealand organisations such as other EDB's, the EEA and ENA to understand national trends;



- Undertake collaboration pilot projects with retailers, consumers and platform providers to understand how the individual pieces of new technology work and how these should be controlled⁶¹ and optimised. These pilot projects are currently funded out of existing allowances but may require further investment in future years;
- Trial new cost reflective tariffs to understand how consumers will respond to price signals and then evolve these tariffs as an important tool to help manage the new technology challenge.
- Signal an increase in funding required in moving to a DSO with greater visibility and control of the network, especially at the 400V level. This has the potential to defer traditional network investment that will be required above the levels signalled in the remainder of the AMP;
- Participate and/or lead a full open collaboration trial in 2018 and 2019 with stakeholders to generate a business case to move to a DSO; and
- Define and set new network policies and connection requirements in regards to new technology adoption to realise new opportunities and control adverse impacts.

This DSO strategy is consistent with the broader innovation goals and detailed DSO plans discussed below in Section 9.1.1. Sections 9.1.2 to 9.1.8 also provide a summary of areas for emerging technologies with development plans under each section. This will ensure that WELL will have the capacity to work on these initiatives while delivering existing business-as-usual work programmes. The programme is also structured to give room for WELL to adapt as the technology evolves.

9.1 WELL's Innovative Goals

WELL's primary assets have a designed long service life therefore the investment approach considers the enduring need of the assets that are developed. The advent of new technologies comes with features that improve at a faster pace than that which electricity network companies normally have operational familiarity with. Therefore the investment planning approach has to factor in the risk of investments becoming redundant if superseded by new technology. Emerging technologies also present opportunities to develop innovative solutions for improving safety, reliability of supply, unnecessary cost expenditure and asset efficiency.

WELL therefore sets innovative goals to take advantage of these opportunities. The response to emerging technologies is transformational innovation that evolves the network into a platform that can support a DSO model as well as delivering other benefits to traditional network operations.

The primary focus of WELL's new technology advances is to:

- Enable the transformational innovations to be adopted by the network and be adaptive and responsive to the uncertainties in this fast moving development era;

⁶¹ Including management of potentially large amounts of data.

- Adopt new technology that improves safety, reliability of supply, unnecessary cost expenditure, asset efficiency and the ability to satisfy legislative requirements;
- Minimise and manage network risks from the adverse impacts of emerging technologies;
- Develop cost effective, environmentally friendly, innovative solutions that defer or reduce network investment expenditure as opposed to traditional network solutions; and
- Enable a seamlessly integrated data exchange platform for the industry and consumers to take advantage of opportunities offered by adopting these new technologies.

9.1.1 Transformation to a DSO

9.1.1.1 DSO Development Plan

WELL's DSO development plan will focus on laying the foundations to prepare for a successful transition to a DSO through innovation projects that help to develop DSO capabilities across the business. WELL expects that the transition to a DSO will not be trivial and will be a long-term goal. It requires investment, including initiatives outlined in this development plan that enable new customer choices, promote competition, and offer cost-effective solutions. Consistent with the strategy discussed earlier, the overall development path to a DSO includes the following items (below) as well as other enabling projects discussed in section 9.1.2 to 9.1.8.

- Develop a DSO transformation roadmap that links the development efforts in the next sections;
- Evaluate requirements for retrofitting existing primary plant with smart sensors and communication capabilities to ensure network equipment is ready for flexible operation;
- Work together with retailers to investigate distributed energy resources and trial load balancing on selected locations:
 - LV feeder balancing
 - HV/LV feeder load balancing between substations: dynamic support between adjacent substations to meet load conditions, which support deferring of primary network reinforcement
 - Zone substation feeder group load balancing
- Investigate and trial an Advanced Network Management (ANM) platform for export constraint management starting with a few micro-grids (see section 9.1.7);
- Tariff design will be a vital lever influencing customer behaviour that supports efficient operation of the market. The tariff will also ensure electricity prices provide enough flexibility to avoid cross-subsidisation given that the customer will engage with the network in different dimensions – consumption, generation, storage provision, voltage control, load balancing and demand response;



- Use of new technologies as alternatives to conventional solutions (such as upgrade in capacity of primary plant) to achieve much greater efficiency of the network;
- Power quality and load balancing: distributed energy resources enabled by emerging technologies⁶² will add to the complexities of the multi-directional flow of electricity. This will pose power quality challenges however the connected devices can also be configured and controlled with a higher degree of flexibility to manage power quality and load balancing. This calls for new market model and operating platforms (network control and trading);
- Integration of corporate information technology (IT)⁶³ and operational technology (OT)⁶⁴ will be required: Historically IT and OT reside in different parts of the organisation however it is vital to integrate these to achieve successful implementation of new technologies and faster business process turnaround. This will provide business capacity to manage the complexity introduced by a smart network configuration and high level of flexibility that customers are coming to expect: and
- Greater deployment of technologies will change the skills required of our workforce.

Figure 9-3 details the expected expenditure on DSO transformation related investigation and development projects.

⁶² The interface of most customer devices and the network will be driven by inverter technologies.

⁶³ Information technology mostly refers to software applications for commercial decision making, planning, business processes management and resource allocation. This category includes ERP, EIM, MWFM, CIS, EPM, DRMS, AMI, etc.

⁶⁴ The operations side is responsible for execution, monitoring and control of the electric system, making sure the network is operating within the allowed ranges of reliability, quality and cost set by the regulations and parameters of the corresponding agencies. This category includes SCADA, OMS, EMS, GIS, etc.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Retailer Load Balancing Platform	-	-	50	50	100	300	500	500	100	100
System Operator Export Constraint Platform	-	-	-	-	50	100	100	300	300	300
Capital Expenditure Total	0	0	50	50	150	400	600	800	400	400
Overall Emerging Technology Development Plan	10	20	20	20	50	20	20	20	50	20
DSO Transformation Road Map	-	10	90	100	-	-	-	-	-	-
Operational Expenditure Total	10	30	110	120	50	20	20	20	50	20

Figure 9-3 Expenditure Forecast for DSO Transformation
(\$K in constant prices)

9.1.2 Electric Vehicles (EVs)

The low number of EVs present in Wellington means there has been minimal impact on WELL's network to date. With the government setting a goal of reaching approximately 64,000 EVs on New Zealand's roads by the end of 2021, and this number doubling every subsequent year⁶⁵, this situation is set to change. By proportion of population for the Wellington region, this represents up to 6,000 EVs by 2021 and more than 40,000 EVs by 2028 (assuming a sustained adoption rate).

The ability to monitor and manage EV charging is a fundamental part of WEL's DSO development plan and will be essential for responding to this emerging technology.

To proactively build knowledge on how EV charging might impact the network, WELL has already:

- Developed an EV tariff encouraging EV owners to charge EVs overnight (9 pm to 7 am) at a reduced rate with the aim of moving demand away from peak periods; and
- Run an internal trial with staff using EVs from the corporate fleet after hours to provide information on usage patterns and network demand.

Key observations gathered so far include:

⁶⁵ <http://www.transport.govt.nz/ourwork/climatechange/electric-vehicles/>



- EVs are not typically connected to a separate meter so the cheaper rate (EV tariff) applies to the entire household use. As domestic consumption is generally low during the day, the new EV tariff will have little impact on revenue. The benefit is in encouraging consumers to shift demand to off-peak periods;
- EV charging during off-peak periods is expected to raise network utilisation which will increase further with wider EV adoption. In addition, EVs retain a residual charge in their batteries which could be injected back into the network and further suppress the evening peak. This has the added benefit of potentially deferring investment to expand network capacity;
- The update of EVs is expected to be evenly distribution across the transmission and sub-transmission network. At the LV connection point, there is potential for uneven network distribution due to uneven distribution of EVs across socio-economic groups and locations. Figures 9-4 and 9-5 show the impact of varying rates of EV penetration compared to existing load and voltage profiles. The demand model illustrated is based on a standard 200kVA distribution transformer with no demand side management in place. Based on this scenario, transformer, switchgear and conductor upgrades will be required to meet the additional load growth and excessive voltage drop with unmanaged EV charging. This will translate into a higher EV ownership cost for consumers.




Figure 9-4 Distribution Transformer Load Profile by EV Penetration Rate




Figure 9-5 End of Line LV Voltage Profile by EV Penetration Rate

- While there has been an increased uptake of commercial charging stations over the past three years, the density and distribution of these charging stations on the network of has not yet raised peak demand. However, the time of use of these stations appears to raise off-peak demand and reduce the duration of the low demand period.



Public Electric Vehicle Charger (Upper Hutt)

Buses

The Wellington trolley bus system has recently been decommissioned. It is being replaced by a new electric bus fleet which will have on-board batteries designed to be charged at designated locations.

WELL's network will need some reinforcement to accommodate the proposed charging points which are a combination of:

- Fast opportunity chargers to charge the buses en-route. These fast opportunity chargers introduce short duration heavy loads (between 250 kVA to 500 kVA each) which will coincide with peak network load times. This would mean limited load diversity and the need for additional load capacity installed on the network. The benefit of fast opportunity chargers is that their locations will be distributed across the network rather than at a central/single location; and
- Slow trickle chargers to charge the buses overnight in the depot. Unlike fast opportunity chargers the slow trickle chargers normally have a smaller output capacity. Overnight charging has the benefit of utilising spare capacity in the network during off peak periods.



Electric Bus using a Pantograph Fast Opportunity Charger

9.1.2.1 EV Development Plan

WELL's EV development plan aims to enable and support the adoption of EV's in the Wellington region. To assess and respond to the potential impact of EVs WELL will, within this AMP planning period:

- Undertake an EV adoption rate and usage pattern study to provide a baseline for mid to long term forecasts and readjust the asset investment plan accordingly;
- Work with the bus operators to understand the likely distribution of charging points along bus routes and the capacity and load characteristics of charging stations. WELL will develop tariffs to incentivise appropriate behaviour;
- Include network reinforcement allowances to address the potential impact from a higher EV adoption rate at locations with capacity issues;
- Work with key customers, councils and service providers to proactively identify locations that may form suitable connection points for commercial charging stations and assess the capacity to connect and any network upgrades that may be needed. This will allow a fast turnaround for connection applications. Sharing the information with potential developers will provide the ability to influence the choice of connection points and ultimately improve network utilisation;

- Continue the current tariff and network studies to forecast EV impact (the potential of EVs injecting power back into the network will be analysed as part of the energy storage investigations). The pilot project with a local partner for user pattern analysis will be vital in developing the knowledge base and understanding of remote control options on charging capacity.
- Assess a possible joint venture and partnership opportunities with local EV distributors to create a cost effective and sustainable business model to enhance the effectiveness of the demand side management platform.

Figure 9-6 details the expected expenditure on EV related investigation and development projects.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Network Reinforcement Allowance due to EV Uptake	-	-	300	300	500	500	1,000	1,000	1,000	1,000
Capital Expenditure Total	-	-	300	300	500	500	1,000	1,000	1,000	1,000
EV Take Home Trial	5	5	5	5	-	-	-	-	-	-
EV Impact Study	-	10	10	10	10	10	10	10	10	10
Public Transportation EV Investigation	10	10	10	20	20	20	-	-	-	-
Commercial EV Charging Station Study	-	-	20	20	20	20	20	20	20	20
EV Charger Metering and Control Platform Investigation	10	10	30	30	-	-	-	-	-	-
Operational Expenditure Total	25	35	75	85	50	50	30	30	30	30

Figure 9-6 Expenditure Forecast for EV related investigations
(\$K in constant prices)

9.1.3 Distributed Generation (DG)

Distributed generation (DG) refers to electrical generation and storage performed by a variety of small, grid-connected devices. Examples of DG connected to the WELL network include:

- Photovoltaic (PV) solar generation. There are currently 969 PV installations connected to the WELL network with 3,141 kVA capacity and a predicted cumulative net injection of less than 200 kVA. While PV installations are the most common form of small-scale distributed generation they currently have minimal impact on the network and demand profile.





A Typical Rooftop PV Installation

- **Wind.** There are eight wind generation sites connected to the WELL network with a total capacity of 60,715 MVA. The greatest contribution to the installed capacity comes from Meridian Energy's Mill Creek wind farm, which is connected via dedicated 33 kV feeders to the Wilton GXP 33 kV bus. This allows for the direct exporting of power to the national grid and therefore has no significant impact on the WELL network (assuming the 220/33 kV transformers at Wilton GXP remain available).
- **Hydro.** There are three small-scale hydro plants connected to the WELL network with a total installed capacity of 1,348 kVA. These plants have minimal network impact.
- **Waste-to-energy:** There are two landfill sites which utilise gas from waste for power generation. With a total installed capacity of 4.2 MVA, they are designed to export surplus energy to the network.
- **Diesel:** There are nine diesel generations sites with an installed capacity of 62.85 MVA in the Wellington region, the largest being a 10 MVA installation at Wellington Hospital. Diesel generation serves as backup at these sites or for peak lopping and is not designed for back feed operation.

The improving economics and choices of emerging technologies such as DGs provides opportunities for customers to reduce electricity consumption from the network, and to participate in the energy market. At the same time, risks from over-generation could cause a steep ramping up in energy demand and add more complexity for WELL in balancing load and demand on the network.

The following charts have been developed for illustration purpose only. Figures 9-7 and 9-8 show projected PV capacities and Figure 9-10 shows the impact of different levels of PV adoption and potential over-generation, combined with the load growth forecast over the same period.




Figure 9-7 Projected PV Installed Capacity




Figure 9-8 Projected PV Output Capacity






Figure 9-10 Impact of Different Levels of PV Adoption

Issues for WELL with regard to DG connections to the network include:

- Modern DGs utilise electronic inverters and can pose power quality issues (such as harmonics and voltage fluctuations). To maximise the amount of DGs on the network, greater visibility and control of the LV network is required and this aligns with the DSO development plan. WELL is updating its policy for DG connections in order to address back feed risks, voltage issues and reverse power flow. This DG connection policy will be informed by the new inverter connection policy being developed by the EEA.
- Other impacts from a higher DG installed capacity in the network are over voltage, fault current contribution, islanding protection and upstream equipment overloading due to excessive reverse power flow during high output – low demand period.
- Development of the demand response market by Transpower provides incentives to building owners that have standby generation to respond to signals from the System Operator. As activity on the DG market increases, it is expected that the demand profile may be distorted, and there may be a need to augment network capacity to accommodate power flows from distributed generation when it exceeds the local load and network capacity.
- Enhanced control and trading platforms are also starting to enable small scale-diesel generators to participate in the market. WELL does not anticipate disconnections with the continuing development of DG but the role of the distribution network may evolve to one where distribution control will provide hierarchical supervision of flexible DG connections.

9.1.3.1 DG Development Plan

Within the next ten years the network impact from DG connections, specifically from domestic and commercial scale PV generations is likely to increase. WELL has allowed for the following investigations and pilot trial projects to explore the development requirements and take advantage of opportunities

delivered by DGs. This includes being able to positively influence connection choices that support network utilisation. WELL will:

- Complete network studies to establish DG hosting capacity for low voltage network feeders resulting in:
 - A simpler and faster turnaround for processing DG connection applications up to the network DG hosting capability; and
 - An ability to inform prospective DG connection applicants so that they can make informed decisions about the size and location for their DG installation.
- Identify partners to trial control systems that allow the Network Control Room to operate connected DG to meet network needs, which will:
 - Support feeder offloading, and balancing supply and demand in micro-grids; and
 - Establish appropriate demarcations for micro-grids based on the capacity and controllability of relevant DG installations.
- Identify potential savings that can be made in primary plant investment for capacity and reliability improvements by connecting DG on network feeders;
- Undertake a PV behaviour and performance investigation for systems installed in the Wellington region;
- Review and adopt the EEA's new DG connection guideline and assess new inverter technologies and features;
- Review the current DG connection application process to identify if it is possible to simplify the application process and technical requirements;
- Undertake a fault study and assess the impact on the network from more DG connections and
- Initiate DG adoption rate modelling and forecast DG impact on power flow direction, harmonics and voltage bands.

Figure 9-11 details the expected expenditure on DG related investigation and development projects.



Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
DG remote control solutions	-	-	-	50	50	100	100	100	200	200
Capital Expenditure Total	-	-	-	50	50	100	100	100	200	200
DG connection modelling and impact assessment	10	10	10	10	30	30	30	30	30	30
New guideline and inverter review and adoption	10	10	-	10	-	10	-	10	-	10
DG application business process and technical requirements review	-	10	10	10	10	10	10	10	10	10
PV performance in Wellington region	-	-	30	-	-	30	-	-	-	30
Operational Expenditure Total	20	30	50	30	40	80	40	50	40	80

Figure 9-11 Expenditure Forecast for DG Related Investigations
(\$K in constant prices)

9.1.4 Energy Storage

Energy storage mechanisms include batteries, compressed air, pumped water and various forms of heat storage. These have the ability to increase the flexibility of a power system because they can store and release energy on demand. This section has a particular focus on batteries as these are the most readily accessible storage mechanism and the one for which the most significant technology advances are occurring. As such batteries are the most likely form of energy storage to impact the WELL network.

WELL has partnered with Wellington City Council (WCC) and Contact Energy (Contact) to trial rooftop solar power systems coupled with battery storage. One initiative of the trial is investigating whether enabling customers to run a micro grid that is islanded from the network makes Wellington more resilient.

Contact and WELL can control the batteries and view the meter data captured. This data includes the solar output, battery state of charge and household usage. The batteries can be activated during a fault or peak demand periods to reduce loading on the network. Early results from the trial (still in progress) confirm the effectiveness of battery storage for the targeted objectives. Other findings are that coordinated charging and discharging can benefit the network by reducing peak demand, and avoid large output variations from distributed generation.

The rate of installation of batteries for energy storage in Wellington is expected to rise as the unit cost for batteries falls. Installation rates will also be influenced by the results of research to improve battery capacity and capability, and as tariffs (feed-in and time-of-use charges) are refined.

The combination of increased availability of distributed storage batteries with a large EV uptake and vehicle to grid technology will have a significant impact on the network.

9.1.4.1 Energy Storage Development Plan

WELL's energy storage development plan aims to advance the current trial projects and build operational knowledge for consumers considering an investment in battery storage. The following projects have been scheduled within this AMP period:

- Review and monitor battery banks installed under the trial project;
- Work with trial partners to refine tariffs (covering off-peak charging and feed-in) and introduce a new pricing plan to encourage battery installations at specific locations to support the network;
- Expand the scope of battery trials by:
 - Increasing the number of participants and widening their distribution across the network;
 - Quantifying the existing storage capacity including EV batteries; and
 - Developing concepts for coordinated control of battery storage and distributed generation.
- Identify potential savings from grid scale battery applications which prove an avenue for deferment of investment in primary plant;
- Explore other benefits from installing battery banks, including outage reduction, auxiliary service offers, phase balancing, voltage support, etc.; and
- Consider energy storage solutions in customer-initiated projects.

Figure 9-12 details the expected expenditure on energy storage related investigation and development projects.



Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Battery Storage Remote Control Interface	-	30	30	30	30	30	30	30	30	30
Capital Expenditure Total	-	30	30	30	30	30	30	30	30	30
Battery Trial Project with Contact Energy	5	5	-	-	-	-	-	-	-	-
Vehicle to Grid technology Investigation	-	-	10	10	10	10	10	10	10	10
Battery storage adoption rate and network impact analysis	-	-	10	10	5	5	5	5	5	5
Grid Scale Battery investigation	-	5	30	30	-	-	-	-	-	-
Battery Storage Analysis for Customer Initiated Projects	5	5	10	10	10	10	10	10	10	10
Operational Expenditure Total	10	15	60	60	25	25	25	25	25	25

Figure 9-12 Expenditure Forecast for Energy Storage Investigations
(\$K in constant prices)

9.1.5 Smart Network

Smart network refers to a network made up of elements that:

- (i) 'Are aware of themselves', i.e. can measure their operating parameters;
- (ii) Can communicate these parameters (including the element physical attributes) with other network elements; and
- (iii) Are controllable from local logic or from remote signals.

These elements will be required to develop a full DSO operating system.

Smart network elements are able to adjust local load and effect network reconfiguration in response to network conditions and need. This capability can be used to isolate faulted network sections or implement demand response. Building blocks for smart networks include:

- Distributed energy resources (DER);
- Smart meters which provide opportunities for a variety of applications: ability to monitor real-time loading data, broken neutral (as a safety feature), load control, outage prediction, and dynamic pricing (revenue risk) to enable demand side management. Most ICPs now have smart meters but these are currently only being used for one-way communication, i.e. sending information to the retailer, and thus the full potential of these devices is not being utilised;

- Control logic nodes (these may be integrated into the traditional primary or secondary plant) that are programmed with logic to analyse the network state and decide the next state to transition to in terms of loading and configuration;
- Controllable switches to allow for load adjustment and network reconfiguration;
- Micro grids: small sections of network that can maintain supply if disconnected from the rest of the network with autonomous voltage control and load balancing; and
- The traditional SCADA system which has visibility of the 11 kV feeders loading and switch states, and controls reach into zone substations. The existing technology is not economically viable for a lower level smart network so the flexibility is currently limited to the main nodes on the HV network.

Opportunities for smart network technologies include:

Micro-grids which enable mass participation in the electricity market over a peer-to-peer trading platform. The key to an effective peer-to-peer trading platform is the right people getting paid at the right time with the right amount. This will also require information system technology improvements to enable the trading platform such as Blockchain technology which can then enable community energy trading in microgrids.

Reduced durations of low demand period and high durations of peak demand periods implies reduced outage windows, lead to more complicated outage planning if using traditional outage planning approaches. By leveraging smart networks to create outage windows when needed and by controlling distributed generation and flexible loads, the complexity and risk of maintenance outages could be reduced.

AMI coupled with the “Internet of Things” (both IoT for consumer’s devices and IoT for industrial machines) provides a platform for automated load response to network conditions and may lead to a greater need for network resilience than reliability. This is due to appliances/industrial machines having logic to understand local processes and energy needs and therefore being able to automatically moderate the amount of power drawn by the household/industrial plant.

With smart networks, assets can be designed and operated on the basis that outages will not interrupt supply if services can be restored before batteries are depleted. This supports a change in priorities from planning for redundancy and achieving very low failure rates in our network to ensuring more rapid supply restoration; shifting the emphasis from reliability to resilience.

9.1.5.1 Smart Network Development Plan

The development plan will include both primary and secondary assets. The initial effort will be in developing a knowledge base through small scale trials to evolve the network into a smart network. WELL will identify, procure and configure appropriate:

- Distribution management systems that integrate existing tools (or features currently offered by the tools) including SCADA and GIS, and procure new features for interfacing with smart meters;
- Smart meter data to improve GIS data quality and LV network model accuracy;
- Smart meter trial projects at selected sites:



- Install smart metering and control logic at the berm substation level for the transformer and the LV feeders and
- Provide communication channels between metering points and the distribution management system⁶⁶.
- Smart RMUs equipped with feeder automation devices for the targeted feeders;
- Industry partners and suppliers to explore the use of smart meters (already installed at the ICPs) as a potential replacement for the ripple control system; and
- Smart meter data to improve outage planning, outage response, network planning and safety investigations.

Figure 9-13 details the expected expenditure on smart network related investigation and development projects.

⁶⁶ Over IP protocol or multi-cast radio instead of the expensive point-to-point RTU based system.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Smart Network Automation Investigation and installation	20	100	100	100	100	100	100	100	100	100
Smart Network and Distribution Management Interface Project	-	-	-	150	150	150	100	100	50	50
Smart meter data for outage planning and safety improvement	-	-	50	50	50	50	50	50	50	50
Capital Expenditure Total	20	100	150	300	300	300	250	250	200	200
Smart Meter Trial at selected sites	5	10	30	30	50	50	50	50	50	50
Smart Meter Application Investigation	10	10	20	20	20	-	-	-	-	-
Investigate network data improvement by smart meter data	-	-	30	30	30	-	-	-	-	-
Operational Expenditure Total	15	20	80	80	100	50	50	50	50	50

Figure 9-13 Expenditure Forecast for Smart Network Investigations
(\$K in constant prices)



9.1.6 Energy Efficiency

Initiatives for energy efficiency involve approaches that increase demand on the electricity network (such as switching from other energy sources to electricity e.g., heat pumps displacing log burners) and other approaches that reduce the demand (such as adopting energy efficient appliances). More efficient appliances reduce energy consumption and can often be set to respond to network pricing signals.

Initiatives undertaken by the Energy Efficiency and Conservation Authority (EECA) are raising the awareness of consumers about improvements in energy efficiency. This is expected to result in demand pattern changes and WELL will be tracking the net impact of these changes.

Some of the energy efficiency initiatives that will impact the network include:

- Heating: electric heaters and heat pump technology replacing coal for industrial process heat (increasing demand) and heat preservation such as insulation and heat recovery (reduce demand).
- Lighting: the local authorities in the WELL network area have started adopting energy efficient street lights and WCC has observed 66% energy saving on their trial installations⁶⁷.
- Systems optimisation through recalibrating existing equipment which can lead to a reduction in energy consumption (e.g., air-conditioning, process speed, etc.).
- Energy management/ process optimisation, (e.g. controlled cold store access or machine running sequence optimisation).

Transport electrification is another key area of improvement in energy efficiency and is discussed separately in section 9.1.2

9.1.6.1 Energy Efficiency Development Plan

The energy efficiency development plan will focus on processes and policies to encourage and support adoption of energy efficient equipment when developing assets as well as better operational practices. WELL intends to:

- Survey customers on:
 - The potential for conversion to electricity from other energy sources to inform demand forecasting;
 - How energy efficiency drivers influence adoption of distributed generation to inform initiatives on distributed generation; and
 - Adoption trends of inverter driven appliances and overall energy consumption trends.

⁶⁷ https://wellington.govt.nz/~/_/media/your-council/meetings/committees/transport-and-urban-development-committee/2014/08/report8attachment1.pdf

- Develop a process to use information from smart meters to:
 - Improve energy auditing; and
 - Balance load on network feeders.
- Revise power quality policies and standards to ensure continuous improvement in power quality parameters at the point of common coupling by taking advantage of features in modern load control devices, such as inverters, harmonic filters and power factor correction units; and
- Work with the regional council, city councils and NZTA to understand the LED street lighting installation plan and assess its potential impact on the electrical network.

Figure 9-14 details the expected expenditure on energy efficiency related investigation and development projects.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Power quality improvement project	-	-	-	100	100	100	300	300	300	300
Capital Expenditure Total	-	-	-	100	100	100	300	300	300	300
Customer survey and efficiency investigation	10	10	10	10	10	10	10	10	10	10
Smart Meter data analysis on energy trend	-	10	20	-	-	-	-	-	-	-
LED street light road map and impact assessment	10	10	10	-	-	-	-	-	-	-
Operational Expenditure Total	20	30	40	10	10	10	10	10	10	10

Figure 9-14 Expenditure Forecast for Energy Efficiency Investigations
(\$K in constant prices)



9.1.7 Network Real-time Technology

Network real-time technology refers to secondary systems that enable a network operator to view the network from a central point and automate the protection, control and communications functions, i.e. collect information on system state and execute operational actions (switching or changing set points) at the instance the decision point is reached (real-time).

The objectives of network real-time technology include safe network operation, increased reliability and improved asset utilisation. The technologies include Supervisory Control and Data Acquisition (SCADA), Distribution Management System (DMS), Outage Management System (OMS), Work Order Management (WOM), Field Mobility Dispatcher (Mobile switching), Energy Management System (EMS), and Power Control System (PCS). An advanced distribution management system (ADMS) integrates these features into a single solution.

WELL is currently using a GE PowerOn Fusion network DMS and OMS that supports the achievement of safe, secure, efficient network operations through:

- Automated workflows that have increased operational efficiency since adoption of the solution;
- Full HV network visibility through SCADA and hand-dressing functions to improve situational awareness; and
- Increased proportion of live equipment switching done through SCADA, which minimises staff exposure to dangerous voltages therefore improving safety.

The GIS holds complete detail of assets including the LV network. Asset location information from GIS used in combination with real-time system information from SCADA supports planning and a rapid response to outages. This has resulted in a more efficient work flow in day to day business operations.

Network real-time technology provides the platform for building smart network solutions (as discussed in 9.1.5). The market now offers integrated solutions that include:

- SCADA for real-time network visualization and a network analysis platform.
- OMS incorporating mobile workforce management (MWFM) for improving outage response and restoration times;
- Fault detection, isolation and restoration (FDIR) using pre-programmed automated switching sequences to maintain supply and minimise impact of faults;
- EMS for distributed energy resource (DER) control;
- An integrated network model for design, planning, protection, reliability studies and operations;

- Standardization with majority of industry applications and easy integration with legacy and third party software; and
- Advanced analytics⁶⁸ to inform operators of the impact of load and generation scenarios ahead of real-time (such as system constraints), and for configuring other automation subsystems (such as alarm levels, automated switching sequences).

The network real-time technologies function over a communications platform that may be one, or a hybrid, of traditional RTU driven point-to-point systems, multi-cast radio and/or segregated secure tunnel via public wireless data network.

9.1.7.1 Network Real-time Technology Development Plan

This development plan outlines WELL strategies for network real-time technology and development of the necessary capability to transition to a distribution system operator, DSO. Key projects include:

- Evaluating commercially available software packages and the ability to tailor selected features for the network to:
 - Assess how existing systems can be integrated systems;
 - Compare with other integrated packages from the market; and
 - Configure network existing information to make ready for integration into an ADMS system:
 - complete detailed network modelling of sub-transmission, distribution and LV networks,
 - ensure common asset references in all databases: SCADA, GIS and Powerfactory for easier data interchange,
 - assess the possibility of setting up pilot ADMS by integrating existing tools and covering a small section of the network (one zone substation) as a proof of concept.
- Identify partners to develop a retail market peer-peer trading platform:
 - Feasibility study of the trial peer-peer trading platform to assess operability in the network context and test features that include wholesale market interactions and consumer participation; and
 - Identify features that need to be developed to realise full operation and scalability.

⁶⁸ Advanced Analytics include: Distribution State Estimation, Volt/VAR Optimization (VVO), Conservative Voltage Reduction (CVR), Fault Location, Isolation & Service Restoration (FLISR), Outage Prediction, Load Forecasting, Unified AC & DC Power Flow, Distributed Generation Modelling, Protection, Load Shedding, etc.



- Investigate and field trial the latest protection equipment to provide more accurate and timely warnings regarding distance to fault, high impedance earth fault, equipment condition abnormality and cyber security breaches.

Figure 9-15 details the expected expenditure on network real-time technology related investigation and development projects.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
ADMS Development	20	50	30	100	650	650	300	-	-	-
New Protection System Investigation and field trial	50	50	100	100	100	200	200	200	200	300
Capital Expenditure Total	70	100	130	200	750	850	500	200	200	300
Market trading platform feasibility study	-	-	30	100	50	50	-	-	-	-
Operational Expenditure Total	-	-	30	100	50	50	-	-	-	-

Figure 9-15 Expenditure Forecast for Network Real-time Technology Investigations
(\$K in constant prices)

9.1.8 Digitisation and Data Transformation

Distributed energy resources and smart grids demand new capabilities and trigger the need for new data-driven business models and regulatory frameworks. Digitisation enables a process to be fundamentally reconfigured, for example, combining automated decision making with self-service can eliminate manual processes. This will be a fundamental element to providing an effective DSO platform.

WELL's existing asset base is made up of a combination of legacy assets from the pre-digital age and recent additions to the network that are digitally enabled (for example, switchgear with digital interfaces, numeric protection relays, and IP based communication links to key sites). With current levels of digitisation WELL can only exploit a limited proportion of the device capabilities until full digital integration can be realised.

The smart devices on the network, network remote control and automation systems (working on digital computing and communications platforms), allow for real-time operation of the network and its connected resources, and collection of network data to improve situational awareness and services. Current market developments include:

- Technology firms with internet based service offerings redefining consumer expectations. Customers are coming to expect a similar level of flexibility and responsiveness from all other service providers; and
- A wealth of meter data from the advanced metering assets. This data is currently owned by the retailers and open access will enable network operators to utilise the information. It is envisaged that access should be a commercial arrangement between network operators and the retailers.

Challenges for adoption of digital technologies include:

- Regulation and tariffs more suited to the existing network and business models;
- Legal frameworks around access to customer data from the smart meters and current capability to make use of the data; and
- A significant proportion of corporate knowledge is still in non-digital form and needs to be transformed into data formats that support enhanced analytics.

Data collection and exchange is growing rapidly, creating both digital threats and opportunities. Digitisation alters the capabilities and tools that a network operator needs to succeed. It greatly lowers entry barriers for technology and other digitally savvy competitors (that do not traditionally participate in the electricity market) and is also a catalyst for raising customer expectations around products and services not previously offered by utilities.

Network opportunities unlocked by digitisation include:

- Continuous refinement of network usage patterns. Smart meters provide energy suppliers with the exact details of each customer's generation and consumption from which tailored products can be developed, such as demand-response programs;



- Productivity tools for employees that support enhanced workflow management, e.g. field workforce access to maps, asset data, work management tools and real-time expertise; and
- Back office automation and data-driven decision making. This includes: data-driven asset strategies such as preventive and condition-based maintenance, and the ability to plan confidently for transformative enhancements in reliability, safety, customer experience, compliance, and revenue management.

Successful digital transformations also benefit from:

- A cultural shift from the traditional investment in expensive long-life assets to a state where success depends on exploiting new capabilities driven by rapid scaling of innovations; and
- An organisational structure with supporting governance principles and a change management strategy that offers room for digital innovation.

WELL's current circumstance is that of having an asset base with a significant portion of legacy, digitally incapable assets and limited industry knowledge to learn from. The approach will be a hybrid of being an 'industry leader' for aspects that it is better placed to develop knowledge on and a 'smart follower' to learn from the experience of others.

9.1.8.1 Digitisation and Data Transformation Development Plan

While digital transformation must encompass all business functions and employees, WELL will embark on a development plan with manageable small steps. The plan is to:

- Develop a digital transformation strategy around WELL's existing value drivers and strengths, including the product portfolio (energy, voltage control, load balancing and demand response), technical competence of people, and service delivery;
- Work with a retail partner to trial a mobile service that allows customers to view the state of the network supplying them, the energy balance position and energy price, to point out opportunities for them to either store energy, run their appliances or export energy to the network;
- Run a trail with WELL's IT security partner to assess potential cybersecurity risks (such as targeted cyber-attacks) from vulnerabilities created by the range of connected assets;
- Review the data life cycle (collection, archiving, storage and access requirements on key business activities and software packages) to optimise current practice by improving data flow performance, data quality and resiliency;
- Implement a new data management and analytic software for improved situation awareness, reporting and speed of access; and
- Develop a framework for measuring digital transformation maturity as feedback to the transformation process covering customer relations, mobile workforce capabilities, and engineering and asset operations.

Figure 9-16 details the expected expenditure on digitisation and data transformation related investigation and development projects.

Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Data Access Platform for Retailer and Customer concept development and trial	0	0	100	100	100	50	50	50	50	50
Data cyber security and resiliency improvements	0	50	50	50	50	50	50	50	50	50
Data reporting and analytic engine development	0	250	150	50	50	50	50	50	50	50
Capital Expenditure Total	0	300	300	200	200	150	150	150	150	150
Data Transformation Strategy	-	0	50	50	-	-	-	-	-	-
Data life cycle, business process review and improvement	30	30	30	30	30	30	30	30	30	30
Operational Expenditure Total	30	30	80	80	30	30	30	30	30	30

Figure 9-16 Expenditure Forecast for Digitisation and Data Transformation Investigations
(\$K in constant prices)



9.2 Summary of Emerging Technology Investment Plan

Emerging technologies will continually present opportunities and challenges that require WELL to evolve. To ready the network and organisation for a future enabled by emerging technologies, WELL will implement strategies to keep abreast of emerging technology, concepts and solutions and their practical applications. WELL will increase its research and trials, as outlined in the emerging technology development plans (above), to gain sufficient knowledge on the impact and potential of these technologies.

The Wellington network has unique features that WELL is best placed to develop knowledge on while also being realistic about its capacity to build the knowledge base needed. Where necessary WELL will lean on industry collaboration to draw useful learnings from the experience of others. WELL will identify innovation partners and work with them to develop the proof of concepts and actively participate in industry forums to share learnings and learn from others.

Figure 9-17 shows the spread of investments over the next ten years required to assess the impact of emerging technologies and to develop capabilities WELL needs to transform into a DSO.




Figure 9-17 Spread of Investment in Emerging Technologies

The total capital expenditure forecast for the emerging technology related development plan over the next 10 years is shown in Figure 9-18.



Expenditure Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Transformation to DSO	-	-	50	50	150	400	600	800	400	400
Electric Transportation	-	-	300	300	500	500	1,000	1,000	1,000	1,000
Distribution Generation	-	-	-	50	50	100	100	100	200	200
Energy Storage	-	30	30	30	30	30	30	30	30	30
Smart Network	20	100	150	300	300	300	250	250	200	200
Energy Efficiency	-	-	-	100	100	100	300	300	300	300
Real-time Technology and Safety Innovation	70	100	130	200	750	850	500	200	200	300
Digitisation and Data Transformation	-	300	300	200	200	150	150	150	150	150
Capital Expenditure Total	90	530	960	1,230	2,080	2,430	2,930	2,830	2,480	2,580
Transformation to DSO	10	30	110	120	50	20	20	20	50	20
Electric Transportation	25	35	75	85	50	50	30	30	30	30
Distribution Generation	20	30	50	30	40	80	40	50	40	80
Energy Storage	10	15	60	60	25	25	25	25	25	25
Smart Network	15	20	80	80	100	50	50	50	50	50
Energy Efficiency	20	30	40	10	10	10	10	10	10	10
Real-time Technology and Safety Innovation	-	-	30	100	50	50	-	-	-	-
Digitisation and Data Transformation	30	30	80	80	30	30	30	30	30	30
Operational Expenditure Total	130	190	525	565	355	315	205	215	235	245

Figure 9-18 Expenditure Forecast Summary (Emerging Technologies Development Plans)
(\$K in constant prices)



Section 10

Support Systems

10 Support Systems

WELL invests in non-network assets to support the distribution of electricity to consumers. These assets include information systems, plant and machinery and land and buildings. This section describes the approach taken and the investment requirements for these systems over the planning period.

10.1 WELL Information Systems

The following information describes the key repositories of asset data used in the asset management process, the type of data held in the repositories and what the data is used for. Areas where asset data is incomplete are identified and initiatives to improve the quality of this data are discussed.

Figure 10-1 shows where asset information is stored within WELL's systems.

	Physical Assets	Equipment Ratings	Asset Condition	Connectivity	Customer Service
SCADA / PoF		✓		✓	✓
GIS	✓	✓		✓	✓
Project Wise	✓	✓			✓
Power Factory		✓		✓	
Station Ware	✓	✓			
SAP PM	✓		✓		✓
GenTrack				✓	✓
SAP (Financial)					✓

Figure 10-1 Asset Data Repositories

10.1.1 Asset Information and Operational Systems

The information systems WELL uses to manage its asset information are described below.

10.1.1.1 SCADA

A GE PowerOn Fusion Supervisory Control and Data Acquisition (SCADA) system is used to assist real time operational management of the WELL network. The SCADA system provides operation, monitoring and control of the network at 11 kV and above. Low voltage (400 volts or below) outage reports are recorded by the GE PowerOn Fusion Calltaker system utilised by the Outage Manager at the WELL Contact Centre. The Calltaker system electronically interfaces with the Field Service Provider's dispatch system to dispatch field staff for fault response.



Main Network Control Room

WELL is planning to develop additional functions to further enhance the PowerOn Fusion platform, as well as investigating development options for offline operator nodes to improve system resiliency and cyber security.

WELL is also currently investigating upgrade options for two other systems related to the SCADA:

- WELL currently uses TrendSCADA, a proprietary data historian tool interfaced with the GE PowerOn Fusion system, for network operations and planning purposes. There are a number of shortfalls with this product, such as limitations in the resolution of data that can be stored, limited ability to retrieve large datasets and a limited suite of analysis tools. The investigation will consider alternative products, such as OSI-Soft PI, which is widely used by other electricity distribution companies and which may offer greater benefits to the business and improve user-friendliness; and
- WELL currently controls load using the Foxboro SCADA system. This system is currently at the end of its economic life and is due for replacement. Replacement options being investigated include an integrated part of the GE PowerOn Fusion system or a standalone package.

10.1.1.2 Geographic Information System (GIS)

The GIS provides a representation of the system's fixed assets overlaid on a map of the supply area. WELL uses the GE Smallworld GIS application for planning, designing and operating the distribution system and this is the primary repository of network asset information.

The GIS links to WELL's maintenance management system (SAP PM), GenTrack and the Field Service Provider's systems to ensure it is updated with the latest asset data and asset condition information. Asset information is updated nightly between the systems.

GIS provides a useful tool for engineering decision by making it easy to:

- Analyse asset population; and
- Carry out geospatial analysis of connectivity, SAP PM defects, maintenance and test history, and asset performance.

A project is underway to replace the existing GIS with a newer version which provides better system performance, data accuracy and improved functionality.




Figure 10-2 Screen Shot of Smallworld GIS system

The existing GIS currently includes SIAS, a web based GIS viewer that is available for staff and external contractors. WELL plan to upgrade SIAS within the next five years with a newer GE GIS platform to provide additional web based GIS functionality.

10.1.1.3 ProjectWise

WELL stores all Grid exit point, substation, system drawings, and historic asset information diagrams in ProjectWise in PDF and CAD format.

10.1.1.4 DigSILENT Power Factory

The DigSILENT Power Factory is used to model and simulate the electrical distribution network and analyse load flows for development planning, contingency planning, reliability and protection studies. The Power Factory database contains detailed connectivity and asset rating information. To ensure ongoing accuracy, the model is manually updated every quarter to include recently commissioned network assets and augmentations. Model updates are regularly distributed to design consultants to ensure consistency for commissioned studies.

10.1.1.5 Cymcap

CYMCAP (cable ampacity and simulation tool) is used to model the ratings of underground cables at all voltages for existing cables in service and new developments.

10.1.1.6 LVDrop

LV Drop is used to model low voltage electrical networks to ascertain voltage drops and loading of conductors and transformers. LV Drop contains all the relevant LV cable, conductor, transformer and ADMD information and ratings. It is used for new subdivision reticulation designs and forms part of the customer connections and planning process.

WELL plans to upgrade LVDrop to the latest version in 2018.

10.1.1.7 DigSILENT Station Ware

DigSILENT Station Ware is a centralised protection setting database and device management tool. It holds relay and device information, parameters and settings files. Station Ware is accessible remotely, via the Citrix environment, to allow input and modification by approved design consultants. Protection settings are uploaded to the Station Ware database for review and approval. The settings are then distributed to commissioning personnel for application in the field.

WELL plans to update the relay database to include the latest relay setting templates in 2018.

10.1.1.8 SAP PM Asset Management System

WELL uses the SAP Plant Maintenance (SAP PM) to plan its maintenance activities and capture asset condition data for both preventative and corrective works. This system allows WELL to issue maintenance workpacks to service providers electronically. Maintenance results are returned electronically via a web interface. Asset data is synchronised with GIS, which allows maintenance tasks to be grouped spatially to increase efficiency.

10.1.2 GenTrack

GenTrack is used to manage ICP and revenue data, and deliver billing and connection services. GenTrack is populated and synchronised with the central ICP registry. It interfaces with the GIS and PowerOn Fusion systems to provide visibility of consumers affected by planned and unplanned network outages. GenTrack also interfaces with the SAP financial system for billing.



10.1.3 SAP Financial Systems

SAP is the financial and accounting application used by the business as its commercial management platform. It is an integrated finance system for billing, fixed asset registers, payroll, accounts payable and general accounting.

10.2 Identifying Asset Management Data Requirements

Asset management data requirements are defined in WELL's asset maintenance standards. The asset management data requirements are then updated when new needs are identified within the business or through changing regulatory requirements.

Asset management data requirements and processes are also specified in the Field Service Agreement with Northpower who input/manage the asset information in the SAP PM information system.

10.3 Data Quality

Robust and timely asset information is needed to drive asset management activities such as development, maintenance, refurbishment and replacement. As the GIS is the central repository for WELL's network asset information, it needs to be complete, accurate and up to date to make good asset management decisions.

Initially asset data is entered into the relevant information systems at the time the asset is created. The asset data will be updated, as required, throughout the life of the asset in systems such as Station Ware and transferred to the GIS during nightly updates between the systems.

Processes are in place to establish one 'source-of-truth' for each category of information and synchronisation of data between the various information systems.

To ensure data quality, WELL continually:

- Updates data on missing or discovered assets and nameplate information stored in GIS;
- Identifies and fixes network connectivity in GIS; and
- Implements measures to improve the quality of the maintenance data reported from the field.

Data quality is managed by implementing controls such as mandatory fields, fixed selection lists when inputting data, and continually checking and verifying the data in the major systems (GIS, SAP PM). User training is provided to ensure users understand what information is required, why particular information is captured and its use within the overall asset management process. Figure 10-3 lists areas where there are limitations in the availability or completeness of asset data.



System	Limitation	Control in Place
GIS	Equipment name plate information missing for some assets	Name plate data collected as part of inspection process and GIS data is updated following inspections Periodic reporting of asset categories to identify where gaps exist and follow up with the GIS updating process to correct gaps on inspected equipment
	LV connectivity is incomplete in some places	Project to continually improve LV connectivity and create accurate representation of LV feeders and open points
GIS/GenTrack	ICP connections to transformers	Historically some ICPs were not connected to the correct transformers in GIS and there is a mismatch between the GenTrack system and GIS. This is progressively being corrected and new processes are in place to ensure new ICPs are connected to the correct transformer (physical connection in the field is correct)
SAP PM	Some required data not collected for early records	Data entry into SAP PM now has mandatory fields to ensure all relevant data is captured at the time of entry into the system Historic entries being reviewed to fill in gaps
	Condition Assessment (CA) scores incorrect for early inspections arising from misunderstandings of new Field Inspectors	Standardised CA scoring and field training is in place Annual re-inspection will provide correct information from second pass
Power Factory	Historical network augmentations or customer connections may not be captured in the model	Network Planning team updates the model to reflect new and updated system components on project completion Project Managers are required to submit relevant information in a timely manner at the completion of projects to allow the models to be updated to reflect actual state
Station Ware	Not all station protection relay settings have been captured in Station Ware	Settings are updated at the time of projects being undertaken, or audited as required to undertake protection and network studies. Settings are intended to be updated following relay testing where the technician can enter as-left settings following the testing
PowerOn Fusion v5.2	Not all network branches have ratings assigned to them in PowerOn Fusion, leading to possible system overload	The NCR utilises a spreadsheet of ratings based on operational scenarios. Alarm limits based on these ratings are assigned as required.

Figure 10-3 Overview of Asset Data Gaps and Improvements

10.4 Information Systems Plan

The major planned changes in network support information systems over the next five years are shown in Figure 10-4. These are separate to the SPP discussed in Section 11.

System	Change & Year	Benefit	Cost (\$K)
GIS	Upgrade for core version 4.0 to 4.3 (2018)	Allows future upgrade to 5.0 Allows GIS platform to be installed for deployment of Network Viewer.	500
	SIAS upgrade to Network Viewer (2018)	Allows better web based functionality, and can be directly read by the B4UDig automated plan release system.	650
PowerOn Fusion v5.2	Upgrade Stage 2 (2018)	Functional enhancements to improve the user experience, geographical data and OMS tools	300
PowerOn Advantage V6.X	New ADMS Platform (2021/2022)	Existing version will be no longer supported by the Vendor, new platform with functional enhancements, user experience and third party software interface	1500
Load Control Master Station	Replacement Foxboro Master Station (2019)	Replacement of legacy master station, improve functionality and enable modern platform interface	710
Power Factory DigSILENT	Version 2018 (2018)	Additional licence, improve functionality, user experience and system stability	85
LV Drop	Version 8.X	Improve functionality and model accuracy	45

Figure 10-4 Overview of Major System Improvements

10.5 Plant and Machinery Assets

Leased vehicles are typically replaced every three years in accordance with WELL's Motor Vehicle Policy. In 2017 WELL extended the Deuar pole-testing licence and purchased new Trimble test devices as part of the non-network CAPEX programme. This licence arrangement will continue to be reviewed annually. Other test equipment and tools are replaced as required, for example power quality and partial discharge test sets. There are no other material investments planned for non-network plant and machinery.

10.6 Land and Building Assets

WELL expects minimal investment or costs associated with the non-network land and buildings it owns. Costs include grounds maintenance and council rates on undeveloped sites.



10.7 Non-Network Asset Expenditure Forecast

Routine Expenditure	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Software and Licenses	1,408	1,064	1,044	1,172	1,078	1,058	1,039	1,028	1,018	1,018
IT Infrastructure	545	419	404	436	430	420	409	402	394	394
Total Non-network CAPEX	1,952	1,483	1,448	1,608	1,508	1,478	1,448	1,430	1,412	1,412
System Operations and Network Support	4,703	4,698	4,698	4,698	4,698	4,698	4,698	4,698	4,698	4,698
Business Support	11,923	11,923	11,923	11,923	11,923	11,923	11,923	11,923	11,923	11,923
Total Non-network OPEX	16,626	16,621	16,621	16,621	16,621	16,621	16,621	16,621	16,621	16,621

Figure 10-5 Non-Network Expenditure Forecast
(\$K in constant prices)

This page is intentionally blank





Section 11
Resilience

11 Resilience

11.1 WELL's Resilience Framework

This section describes WELL's approach and investment plan relating to resilience and focuses mainly on managing and mitigating events beyond normal circumstances and under emergency situations. WELL's approach for providing consumers with a safe, reliable and cost effective electricity supply under normal circumstances was described in Section 6. Changes due to growing demand from increased population or industry is covered by the Network Development Plan in Section 8.

As a lifeline utility, WELL must ensure that it is able to function to the fullest possible extent, even though this may be at a reduced capacity, during and after an emergency; this can include one off events such as storms, earthquakes, and equipment failures.

This section has the following structure:

- Emergency response and contingency planning;
- High impact low probability (HILP) events;
- Business as usual resilience work;
- Earthquake readiness SCPP application;
- Future resilience work.

11.2 Emergency Response and Contingency Planning

WELL has emergency response procedures and contingency plans in place to mitigate and respond to the impact of a potential HILP event as discussed below.

11.2.1 Civil Defence

The Ministry of Civil Defence and Emergency Management (MCDEM) is responsible for emergency management on a national scale. Emergency management is governed through the Civil Defence Emergency Management (CDEM) Act 2002 which sets out the requirements for each resilience group, including local Emergency Management groups, Lifeline Utilities and Emergency Services as well as producing and maintaining the national components of the CDEM framework.

11.2.2 Wellington Regional Emergency Management Office (WREMO)

The Wellington Regional Emergency Management Office (WREMO) was formed in 2012 and is a semi-autonomous organisation that coordinates civil defence and emergency management services on behalf of the councils in the Wellington region. While there is not an emergency response the emergency management office concentrates on identifying potential local hazards and implementing measures to reduce risks as well as promoting awareness of these risks and assisting other regional groups when this is requested.



11.2.3 Wellington Lifelines Group (WeLG)

The Wellington Lifelines Group is a working group comprised of the lifeline utilities operating within the region and representatives from local and regional government. Lifeline utilities are defined by the CDEM Act as businesses providing essential services to the community including:

- Transport infrastructure (road, sea and air);
- Water supply and reticulation systems;
- Sewerage and storm water drainage systems;
- Electricity transmission, generation and distribution networks; and
- Telecommunications network providers.

WELL is classified as a Lifeline Utility under the CDEM Act and as such has the following responsibilities:

- Ensuring it is able to function to the fullest possible extent even though this may be at a reduced level during and after an emergency;
- Having a plan for functioning during and after an emergency;
- Participation in CDEM strategic planning; and
- Providing technical advice on CDEM where required.

The CDEM Amendment Act 2016 places additional emphasis on ensuring that lifeline utilities provide continuity of operation where their service supports essential emergency response activities.

In November 2012 WeLG published a report on the likely restoration times for lifeline utilities based on the scenario of a magnitude 7.5 earthquake on the Wellington fault, centred in the harbour area. This report was partly in response to questions arising after the Christchurch earthquakes as to how Wellington would fare in a similar event. The report set out the time required after an event for each lifeline utility to restore services to a defined level in different areas around the region. Dependencies between utilities were not accounted for but these were often mentioned among the assumptions. A key difference identified in the report between the Canterbury and Wellington regions was the number and vulnerability of transport access routes in the Wellington region and the extensive recovery times anticipated. It is expected that some of this will be alleviated by the Transmission Gully route which is currently under construction.

Through 2017 and extending into 2018 WeLG has been conducting another project on regional disaster response. A key component of this project has been consideration of the interdependencies between lifeline utilities and how these are likely to affect the restoration process. This project has involved detailed modelling of the likely damage to each lifeline utility network based on GNS modelling of the Wellington fault and regional geography.

11.2.4 WELL Contingency Plans

To comply with the responsibilities as a lifeline utility as set out in the CDEM act, WELL has created a number of plans detailing the actions to be taken in a range of situations.



11.2.4.1 Emergency Response Plans (ERPs)

As part of the Business Continuity Framework Policy, WELL has a number of ERPs to cover emergency and high business impact situations. The ERPs require annual simulation exercises to test the plans and procedures and provide feedback on potential areas of improvement. All ERPs are periodically reviewed and revised. Learnings from natural disasters in New Zealand such as the Christchurch earthquakes and the Wellington June 2013 storm have been incorporated into these plans.

11.2.4.2 Civil Defence and Emergency Management (CDEM) Plan

WELL has prepared the CDEM Plan to comply with the relevant provisions of the CDEMA Act 2016. It provides information for the initiation of measures for saving life, relieving distress and restoring electricity supply.

This CDEMA Plan follows the four 'Rs' approach to dealing with hazards that could give rise to a civil defence emergency:

- Reduction - identifying risks and developing plans to reduce these risks;
- Readiness - developing emergency operational contingency plans;
- Response - actions taken immediately before, during or after an emergency; and
- Recovery - rehabilitating and restoring to pre-disaster conditions.

11.2.4.3 Crisis Management Plan (CMP)

The CMP defines the structure of the Crisis Management Team and the roles and responsibilities of staff during a crisis. The CMP contains detailed contact lists of all key stakeholders who may contribute to, or be affected by, the crisis.

11.2.4.4 Major Event Management Plan (MEMP)

The MEMP defines a major event and describes the actions required and the roles and responsibilities of staff during a major event. A focus of the MEMP is how the internal and external communications are managed. It contains detailed contact lists of all key stakeholders who may contribute to, or be affected by, the major event. Should the event escalate to a crisis, it is then managed in accordance with the CMP.

11.2.4.5 Business Recovery Management Plan (BRMP)

The BRMP covers, any event that interrupts the occupancy of WELL's corporate offices in Petone and clearly states how such a business interruption would be recovered and escalated to a crisis if required. This includes the mobilisation of the Business Recovery Event Centre at the WELL disaster recovery site at Haywards. This site has meeting and office spaces, as well as functional SCADA terminals and communications equipment, along with the necessary IT equipment, to allow network operations to continue with only a short interruption. Several other key business processes can also be operated from this site should the Petone corporate offices be unavailable.

This plan was put into practice after the November 2016 earthquake which rendered the corporate office in Petone unsafe to conduct business from, and required all corporate business functions to relocate to Haywards substation and operate from there until the end of January 2017.



11.2.4.6 Information Technology Recovery Plan (ITRP)

The ITRP is in place so that WELL's IT systems can be restored quickly following a major business interruption affecting these systems. The level of recovery has been determined based on the business requirements.

11.2.4.7 Major Event Field Response Plan (MEFRP)

The MEFRP covers WELL's field contractors so they are prepared for, and can respond appropriately to, a HILP event. The MEFRP designates actions required and responsibilities of WELL and field contractor coordination during an event. It focuses on systems and communications (internal and external) to restore supply. A major event field response can escalate to the MEMP if required.

11.2.4.8 Emergency Evacuation Plan (EEP)

The purpose of the EEP is to ensure that the Network Control Room (NCR) is prepared for, and responds quickly to, any incident that requires the short or long term evacuation of the NCR and re-establishment at the disaster recovery site. This plan was also utilised after the November 2016 earthquake which rendered the corporate office in Petone unsafe and required all corporate business functions to relocate to Haywards.

11.2.4.9 Pandemic Preparedness Plan

The purpose of the Pandemic Preparedness Plan is to manage the impact of a pandemic-related event by:

- Protecting employees as far as possible from spread of disease;
- Creating a safe working environment; and
- Maintaining essential business functions with reduced staffing levels if containment is not possible.

The Pandemic Preparedness Plan is reviewed annually by the WELL QSE Manager.

11.2.4.10 Other Emergency Response Plans

WELL has other emergency response plans including:

- Priority notification procedures to key staff and contractors;
- Total Loss of a Zone Substation Plan;
- Network Spares Management Policy
- Loss of Transpower Grid Exit Point Plan (Transpower Plan);
- Emergency Load Shedding Plan;
- Participant Outage Plan (as required under the Electricity Industry Participation Code 2010); and
- Call Centre Continuance Plan.

In addition, contingency plans are prepared as necessary detailing special arrangements for major or key customers.



11.3 High Impact Low Probability (HILP) Events

The WELL network is designed with a certain amount of resilience built into it to account for isolated equipment failures and regularly occurring adverse events. However, as with all infrastructure, the network is susceptible to potential HILP events which could cause a major unplanned outage for a prolonged period.

Due to the geography of the region and weather patterns, the Wellington region is at risk from both earthquakes and severe storms, with earthquakes having the most potential to cause widespread damage throughout the region. Other possible HILP events include an upstream supply failure, communications failure, cyber security breach or information security breach or loss.

HILP events are unpredictable, generally uncontrollable and prohibitively expensive to avoid, if at all possible. WELL's design standards align with industry best practice and take the weather and seismic environment of the region into account. These design standards do not however cater for weather conditions or seismic events that are beyond what is deemed 'normal' for the region.

WELL's management of unforeseen events is split into two areas, mitigation of the risk through network planning, design and asset maintenance and then response during and after an event to restore power quickly without compromising contractor or public safety.

11.3.1 Identification and Planning for HILP Events

Some of the methods used by WELL to identify HILP events are:

- Transmission risk reviews – participation in the Connection Asset Risk Review project undertaken by Transpower. This was a HILP study for the Wellington CBD to identify risks on the transmission circuits and substations, and to develop mitigation measures;
- Distribution risk reviews – as part of the network planning process, HILP events are identified. Examples of such events include the simultaneous loss of subtransmission circuits causing a complete loss of supply to a zone substation, or the destruction of a zone substation. Contingency plans have been drawn up to mitigate such events; and
- Environmental risk reviews – understanding and identification of the risk posed by natural disasters such as earthquake and tsunami. Studies are undertaken on behalf of WELL by GNS and other external providers.

11.3.2 Strategies to mitigate the impact of HILP events

WELL applies the following strategies to mitigate the impact of potential HILP events, as well as drawing on the experience of others (such as learnings from Orion following the Canterbury earthquakes):

- Identification – understand the type and impact of HILP events that the network may experience;
- Reduction – minimise the consequence of the HILP event through further investment in resilience (subject to additional funding being made available);
- Readiness – reduce the impact of an HILP event where appropriate, by improving network resilience (subject to additional funding being made available);
- Response – develop plans to respond to HILP events in terms of business processes; and



- Recovery – including the use of contingency plans to invoke a staged and controlled restoration of network assets and supply capability.

The mitigation of potential HILP events is supported by a number of plans and initiatives across the business described in the following sections.

11.3.3 Specific HILP Events

A discussion on the following HILP events is covered below;

- Major storm events;
- High impact asset failure;
- Upstream supply failure; and
- Major earthquake.

11.3.3.1 Major Storm Events

The Wellington region is very susceptible to high winds and severe storms, which have the potential to cause a significant amount of widespread damage to the overhead network. For this reason WELL uses a relatively high wind loading when designing overhead lines when compared with other network companies. This susceptibility is also a factor in the high proportion of the Wellington network that has been constructed with underground cables.

A major cause of outages on overhead sections of the WELL network is lines being struck by vegetation and windblown debris. It can be especially difficult to identify where strong wind gusts have caused vegetation that does not normally get close to a line to come into contact, or where debris has been blown clear of the line before a patrol can be completed.

In June 2013, Wellington experienced a severe storm of a magnitude similar to the “Wahine” storm of 1968. Wind gust speed remained above 100km/h for approximately 24 hours, peaking at over 200km/h. The storm caused significant damage to the WELL network and at its peak resulted in 30,000 homes and businesses being without power. Damage to network assets affected customers in both rural and urban areas with wind gusts uprooting trees and carrying debris into overhead lines, damaging poles and conductors.





Storm Damage - June 2013

The affected areas were widespread and outages were prolonged as the conditions made it difficult to patrol and repair lines. Blocked roads and traffic congestion resulted in travel time delays. To address the significant workload, 150 additional staff from other regions were brought in to assist with the restoration efforts.



Contractors Working to Repair Storm Damaged Lines - June 2013

11.3.3.2 High Impact Asset Failure

WELL network's system security standard is designed to provide a supply resilience of N-1 at zone substation level, meaning that the network can operate at full capacity after the failure of a single asset. This is generally achieved by having dual sub transmission circuits and power transformers. Resilience

within the 11 kV network is provided by the use of meshed rings or tie points between radial feeders, to minimise the effect of equipment failure and improve the restoration after an event.

Due to the constrained nature of many WELL sites and the sub transmission routes that have been constructed sharing the same route, an event affecting one component has the potential to affect the other and lead to a total outage at that site. This is mitigated through different means depending on the type of asset, such as physical barriers between transformers at some sites, or separation between overhead lines where space allows.

Where an event leads to a total loss of supply at a zone substation, it is generally possible to restore the majority of the load through network switching to supply the area from a different zone substation. However this is not possible for all substations or at all times in the year. Higher loadings, or substations located at the extremities of the network and without strong ties to other zones, result in areas that are unable to be supplied in the event of a total zone substation outage.

Areas that are unable to be supplied in the event of a zone substation outage are mostly at the extreme ends of the network with Wainuiomata, Mana-Plimmerton and north of Upper Hutt being the most obvious examples. These substations also supply two of the main water treatment plants providing potable water to the region at Te Marua and Wainuiomata treatment and pumping stations. Both plants have backup power supplies that can cover their emergency requirements but require network supply to operate at full capacity.

There are also locations where a single asset failure could spread and result in the total loss of one or more zone substations. This is partially mitigated through physical separation of the assets and laying of cables in separate conduits. By separating the buried assets, the potential causes of damage to multiple circuits are largely limited to external forces such as cable strikes or earthquakes.

11.3.3.3 Upstream Supply Failure

WELL takes supply from Transpower at Grid Exit Point (GXP) substations. There are nine GXPs in the Wellington region supplying WELL at either 33 kV or 11 kV, with some GXPs supplying at both voltages. While the loss of any of these substations will result in the loss of supply to one or more zone substations and a significant number of consumers, Central Park substation is the most significant. Central Park is a highly loaded substation and would have the largest impact in terms of both load lost and consumers without supply.

Central Park substation supplies seven zone substations with a combined total of 51,428 customer connections and a peak demand of approximately 190 MVA. There is very limited capacity for the shifting of load onto the Wilton GXP with approximately 17 MVA able to be transferred to Moore St, Kaiwharawhara and Karori substations. The area supplied by Central Park contains the majority of the Wellington CBD and includes a number of high priority and regionally critical sites.

The Central Park site is constrained by the limited available space as well as the construction standards at the time of construction which increases the likelihood of a failure in one area spreading to adjacent areas or equipment. Large Transpower sites such as Penrose or Haywards are often 300-400 m across while Central Park is barely over 50m with no fire separation between two of the transformers or between bus sections in the 33 kV switchroom.





Central Park Substation

Although a total outage of this substation is unlikely, this site supplies the majority of the CBD load in the national capital city and there is no alternate supply in the event of a failure of the site. The potential loss of the majority of Wellington city load is an unacceptable risk and there is ongoing work between WELL and Transpower looking at potential solutions to improve the resilience of the site.

11.3.3.4 Major Earthquake

The Wellington Region contains numerous known fault lines with the potential to cause a severe shaking event; the three most well studied of these are the Wellington, Ohariu and Wairarapa fault lines. These are shown below in a map of the region created by GNS science which looked to increase knowledge of the earthquake risk in the Wellington region.






Figure 11-1 Wellington Region Fault Lines⁶⁹

The Wellington fault line runs from Long Gully through Thorndon, along the edge of Wellington Harbour and roughly along State Highway 2 to Kaitoke. The Ohariu fault runs up the Ohariu valley, through Porirua and past Mana along the northern edge of the Pauatahanui inlet. The Wairarapa fault runs along the Rimutaka ranges and ruptured in 1855 resulting in an earthquake with a magnitude of 8.2, making it the most powerful earthquake recorded in New Zealand.

How often do earthquakes occur along the fault?



The last time the Wellington Fault ruptured through the Wellington region, causing a major earthquake, was around 300 - 500 years ago. Geoscientists estimate the Wellington Fault will cause a major earthquake every 500-1000 years. However other faults around the Wellington region are also active and capable of generating major earthquakes, for example the Ohariu Fault, and the Wairarapa Fault which last ruptured in 1855 causing a great earthquake that severely affected Wellington. The frequency of large earthquakes affecting the Wellington Region is therefore much higher, with an average return time of about 150 years for a very strong or extreme ground shaking quake.

⁶⁹ Field Trip 1; Wellington Fault: Neotectonics and Earthquake Geology of the Wellington-Hutt Valley Segment. GNS Science (the stops on the picture refer to the stops made during the field trip).



A rupture of any of these faults would lead to a severe earthquake in the region with a level of damage expected to be similar to or exceeding that of the February 2011 Christchurch earthquake. It is expected that large sections of the network will be without power immediately after a major event but that the majority of this will be able to be restored once equipment inspections and line patrols have been completed. After the initial restoration work, fault finding and repair work will have to be carried out on the remaining damaged areas of the network.

11.3.3.5 November 2016 Kaikoura Earthquake

Two minutes after midnight on 14 November 2016 multiple fault lines ruptured from Culverden to Kaikoura in the north-east of the South Island.



Figure 11-5 Cracked concrete at Wellington's port⁷⁰

The Wellington region was affected by this earthquake with several buildings damaged beyond repair and a number of other buildings remaining unoccupied, including the WELL headquarters at 75 The Esplanade in Petone, while decisions were being made on whether it was practical to carry out repairs. Schools were closed after the earthquake and many businesses were forced to relocate either temporarily or permanently.

There was significant disruption to the electrical network as a result of this earthquake with approximately 28,000 customers losing supply. Due to the earthquake affecting mostly the overhead network almost all outages were able to be restored within 18 hours, with sustained outages being largely confined to CentrePort where earthquake damage was most pronounced. It was not until ten months after the earthquake that the port was able to operate at full capacity again. Road and Rail links between Picton and Christchurch were severed by the earthquake, resulting in severely restricted travel and transport through the upper South Island. The rail link was reopened on 14 September 2017 and State Highway 1 was reopened in a limited fashion on 15 December 2017.

⁷⁰ Photo taken from Radio New Zealand website - <https://www.radionz.co.nz/news/national/318540/detailed-planning-for-demolition-of-quake-hit-building>






Figure 11-2 November 14 Earthquake Restoration Profile

Restoration work was enabled by the availability of the disaster recovery site at Haywards substation, with network control being relocated to this site in the early morning after the earthquake. Restoration work was also accelerated due to a forecast heavy storm that was expected to strike the following day.

Restoration work was simplified by the damage being concentrated in the Hutt Valley and the majority of outages occurring on the overhead network due to line clashes from shaking rather than network wide damage that is typically experienced in major storm events. There were also some faults in the 33 kV sub transmission network and transformers that tripped due to shaking although this did not impact customers due to the N-1 construction of the network at the 33 kV level.

11.4 Business as Usual Resilience Work

11.4.1 Seismic Strengthening of Substation Buildings

Following changes to the Building Code post the Christchurch earthquakes, a number of WELL's substation buildings require reinforcement to ensure they comply with the minimum standards set by local authorities.

WELL's Substation Building Seismic Policy includes the following key elements:

- Network substations must provide a satisfactory level of resilience against major seismic activity;
- Timely restoration of power is required following a disaster;
- To have no buildings which are earthquake-prone following an assessment and the necessary remedial works; and
- WELL-owned buildings should not present a safety issue to people, property or members of the public.

A key target from the policy is to have all substation buildings constructed prior to 1976 (when significant changes were made to design requirements) subjected to an independent seismic assessment within three

years. This was completed at the end of 2016. Each building was evaluated using the Initial Evaluation Process (IEP) as set out in the NZ Society for Earthquake Engineering Recommendations for the Assessment of the Structural Performance of Buildings in an earthquake. Changes under the Building Act of 2004 require older buildings to have the performance capacity of at least one third of the New Building Standard (NBS), and a building with a seismic strength calculated < 34% is categorised as 'earthquake prone'. A building with a seismic strength calculated between 34% and 66% is categorised as 'earthquake risk.'

Under the 2014 DPP decision, additional resilience expenditure was not included in the allowances set by the Commission. As a result, the current programme of substation building reinforcement has been included in the plan as a prolonged programme keeping within the remediation timeframes required by legislation.

WELL has nearly 500 substation buildings with the age profile as shown below.




Figure 11-3 Substation Buildings Age Profile (by Year Built)

328 substation buildings were identified as needing to be assessed. Two were subsequently decommissioned. These include all 279 substation buildings constructed prior to 1976, all zone substation buildings and all key distribution substation buildings.

Local councils also conduct assessments of selected buildings within their region to ensure compliance with their earthquake prone buildings policies.

WELL used independent local structural consultants to undertake the IEPs and subsequent Detailed Seismic Assessments (DSAs). Figure 11-4 shows the status and local authority location of the assessed buildings.



Building Status	Wellington City Council	Lower Hutt City Council	Upper Hutt City Council	Porirua City Council	Total
Confirmed not earthquake prone	208	68	17	22	315
Buildings left to strengthen that are confirmed earthquake prone by DSAs	7	7	0	4	18
IEPs Completed but no percentage NBS yet assigned	10	1	1	0	12
Total	225	76	18	26	345

Figure 11-4 Building Assessment by Council Area

Based on this assessment, 22 pre-1976 sites were initially identified as requiring strengthening. This number was increased to 27 after further assessments were done on some buildings constructed post 1976. Nine of these sites have had strengthening works completed in 2016-2017. The remaining 18 sites will be strengthened over the next 5 years.

11.4.1.1 Sites Strengthened in 2017

The four sites completed in 2017 were prioritised on the basis of network criticality, public safety and building special features (brick façade, age or similar).

Substation ID	Substation	% NBS before strengthening	% NBS after strengthening
S0003	Tory St	8%	>33%
S0009	Ghuznee St	20%	>33%
S1469	Jackson St	26%	>33%
S1461	Marchbank St	21%	>33%

Figure 11-5 WELL Buildings Strengthened in 2017

The seismic strengthening completed at Tory St Substation involved strengthening the façade and installing steel bracing inside the substation. This strengthening work was completed with very little effect on the exterior appearance of the building as shown by the images of the strengthened substation below.



Exterior (L) and Interior (R) of Tory Street Substation

11.4.2 Unreinforced Masonry (URM) Buildings

The Hurunui/Kaikoura Earthquakes Recovery (Unreinforced Masonry Buildings) Order 2017 requires owners of unreinforced masonry (URM) buildings to secure street-facing parapets and facades if issued with a notice to this effect from the council. The parapets and facades must be secured within this time frame to reduce the risk of falling masonry.

Due to the prioritisation previously carried out, which highlighted these types of building as having a high risk to public safety, the URM ruling has had very little effect on WELL's seismic strengthening programme already underway.

WCC has advised WELL of two sites where unreinforced masonry requires strengthening, these being the Tory Street and Newtown Substations. URM strengthening has been completed at both sites although the Newtown Substation requires further seismic strengthening works. This will be undertaken in 2019.

11.4.3 Above Ground Pole Foundations

Following the successful use of temporary overhead lines in Christchurch to restore supply in an emergency situation, WELL began identifying routes that could benefit from this method of supply restoration. The aim is to enable some preparatory work to be undertaken in anticipation of an event. This method is preferred because of the large number of underground services which make it difficult to bury poles.

For this reason, as part of the project to identify and plan line routes within Wellington City, Linetech Consulting were also engaged to design a foundation that could be used to install a pole on the surface without disturbing the existing underground services.

Two above ground pole foundation designs have been produced (a small and a large foundation). Both consist of a flat base with a clamp to hold the butt of the pole and braces that clamp the pole at ground level. The frame is stabilised by concrete blocks. The smaller foundation is for lightly loaded poles (with in-line spans) while the larger foundation is for greater loadings.

The initial design was made to accommodate a range of pole types by way of adjustable clamping. Testing of this first prototype identified some challenges with aligning and clamping the bottom of the pole, resulting in a clamping redesign to specifically fit with a pre-stressed concrete pole.



Large Foundation Being Prepared for Testing

Both foundations were tested with the redesigned clamping, to their full capacity - top loads of 4.5kN for the small foundation and 35kN for the large foundation. Testing of both foundations was completed successfully with no damage to the foundations.

An opportunity to field test the smaller foundation occurred in September 2017. Slips resulting from heavy rain forced a road closure in Upper Hutt and a WELL pole needed to be moved before works to repair the road could commence. The designer of the foundation was on site for this work to assist the contractors and record any potential design alterations required.



Road Damage and Proximity of WELL pole (Field Test Site)

Due to restrictions on the machinery that could be used in this situation, a concrete pole was not able to be used. The solution was to reuse the existing pole wooden pole with its base cut down to match the shape of

a concrete pole that would fit the redesigned clamping. This pole was moved successfully and the field trial provided insights for improving the usability of the foundation.



Above Ground Pole Foundation

Although these above ground pole foundations are primarily a resilience project, they provide additional BAU benefits where installation of a pole is made difficult or impractical due to ground conditions or other buried services.

11.5 WELL's Earthquake Readiness SCPP Application

The Commission is expected to approve WELL's proposed new investment of \$31.24 million for earthquake readiness initiatives in March 2018. This includes further critical spares for the network which will significantly improve WELL's response capabilities.

After the November 2016 earthquake, the government asked key infrastructure providers what could be done to improve the region's readiness to respond to a second significant earthquake based on the earthquake series experienced in Christchurch (2010-11). This initial list produced by WELL was subsequently expanded into the SCPP application currently under assessment with the Commission.

The SCPP application is premised on the likely result of a major earthquake (a direct magnitude 7.5 rupture on the Wellington Fault) being the immediate loss of up to 60% of the region's electricity supply (similar to what happened in Christchurch).



It is estimated that power supply to some consumers could be lost for between 30 and 90 days. This estimated outage period is further supported in a report by Opus⁷¹ which concluded that the greater Wellington region could be split into seven 'islands', with five of these 'islands' being within the WELL network area. The 'islands' are expected to have no road access between them for an extended period, with some roads being closed for up to four months. The impact of these transport disruptions is shown with the 'islands' overlaid on a map of WELL's planning areas (Figure 11-6).




Figure 11-6 Affected Transport Links After a Major Earthquake

The duration of power outages will likely be increased by these severed transport links as most equipment required for repairs is not stocked within the region. The SCPP submitted to the Commission was developed to ensure that WELL would be better prepared to respond to such an eventuality.

⁷¹ "Restoring Wellington's transport links after a major earthquake" Wellington Lifelines Group, March 2013.

11.5.1 Proposed Expenditure on Earthquake Readiness

In developing the application, an economically robust business case for investment in readiness initiatives to reduce the impact of an earthquake has been created. Economic justification for HILP events can be difficult given the lack of certainty and accurate information supporting the probability of when an event will occur. The business case shows there is a net benefit to consumers from the proposed investments, using a conservative estimate of the value of benefits. WELL considers the long-term interests of consumers are best served by the investment in readiness initiatives being made as soon as possible⁷².

The approach to the development of the proposal was to:

- Define the need by identifying the network areas susceptible to failure, building vulnerabilities, and risks of limited access to our communications and data systems;
- Identify the readiness options that enable WELL to promptly start restoration efforts following an event;
- Estimate the costs and benefits of each option; and
- Select preferred options based on their effectiveness, technical feasibility, and their expected benefits.

A summary of the initiatives proposed under the resilience SCPP is shown in Figure 11-7 below.

Risk Being Addressed	Proposed Initiatives	Capex	Opex	Total
33 kV cable faults	Emergency hardware	4,740	670	5,410
Loss of transformers and switchgear	Mobile substations and switchboard	4,730	-	4,730
11 kV cable and equipment faults	Critical emergency spares	4,940	-	4,940
Damage to equipment in buildings	Seismic reinforcement of critical substations	10,400	-	10,400
Loss of data and communication links	Additional data centres and improved communication systems	5,260	500	5,760
TOTAL		30,070	1,170	31,240

**Figure 11-7 – Summary of Proposed Initiatives
(\$K in constant prices)**

The first three initiatives were chosen based on the net benefit value they provide relative to other options, a total of \$28 million. The benefit used for this calculation is the improvement in restoration times each option offers against the current state. These improvements are a combination of reductions in repair time for

⁷² The full business case is available on the WELL website – refer to Earthquake Readiness Business Case - December 2017.pdf

some categories of equipment (utilising mobile and portable substation options) and having a supply of emergency spares.

The majority of benefits from holding spare overhead line and cable equipment arise from a reduction in the time it would take to transport spare equipment to where it is required (overcoming the delay caused by regional transport links being broken in a disaster situation). Spare equipment will also be made available to other distribution companies should the need arise as a result of large scale damage to their networks. This means a reduction in risk that goes wider than the Wellington region.

The initiative to seismically reinforce significant substations is primarily driven by WELL's aim to bring all zone substation (and other important buildings) up to 67% of the New Building Standard (NBS). The strategy to strengthen buildings was employed by Orion in the years prior to the Christchurch earthquake and damage to substation equipment as a result of building failure was avoided.

The initiative to add three data centres and improve the communications systems recognises that restoration efforts can only begin if there are adequate communication links and access to critical systems and tools. Communication is an essential component of the prompt restoration of supply. Its value is demonstrated by the cost of delays in restoring supply (based on the initial 60% loss of supply) being set at around \$110 million per day⁷³.

11.5.1.1 SCPP Expenditure Forecast

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	2,530	2,210	38	0	0	0	0	0	0	0
Zone Substations	1,078	1,381	6,249	0	0	0	0	0	0	0
Distribution Poles and Lines	-	-	-	0	0	0	0	0	0	0
Distribution Cables	1,133	1,115	1,241	0	0	0	0	0	0	0
Distribution Substations	1,809	2,160	2,553	0	0	0	0	0	0	0
Distribution Switchgear	244	244	243	0	0	0	0	0	0	0
Other Network Assets	-	580	-	0	0	0	0	0	0	0
Total	6,794	7,690	10,324	0	0	0	0	0	0	0
Non Network Assets	1,363	3,023	872	0	0	0	0	0	0	0
Total	8,156	10,713	11,196	0	0	0	0	0	0	0

Figure 11-8 SCPP Expenditure Forecast
(\$K in constant prices)

⁷³ Based on the value of unserved energy as defined by the Electricity Industry Participation Code – refer to Earthquake Readiness Business Case - December 2017.pdf

11.6 Future Resilience Work

Analysis completed while creating the SCPP application identified a number of areas where resilience in the network needs to be addressed but which fall outside the SCPP readiness and response criteria. These being:

- Central Park as a potential single point of failure; and
- The vulnerability of the sub transmission fluid-filled cables.

The current AMP forecast does not include an allowance for this work which may require WELL to consider a full CPP application. Our intention is to continue to analyse these events in conjunction with WeLG and other lifeline utilities discussed in Section 11.2.3.

11.6.1 Central Park

There is a significant risk posed by a potential loss of supply to Central Park GXP. A longlisting exercise was completed with Transpower and the initial analysis of options generated through this showed that the most effective means of reducing this risk would likely be the construction of a smaller “Central Park 2” substation which will replicate a portion of the existing site at a nearby location. The Central Park 2 substation construction would coincide with the decommissioning of one transformer bank at the current site. This transformer would be supplanted by the transformer at the new site. The new site would also contain a 33 kV bus section with one supply to each of the connected WELL zone substations. This substation would be operated as an extension of the existing GXP, although physically separated.

This option will be more cost effective than the construction of a full size GXP and will effectively mitigate the risk presented by this single point of failure.

Other options looked at involved the construction of new GXPs or zone substations supplied from Wilton or through a new undersea cable crossing the harbour. These options were significantly more costly than the preferred Central Park 2 substation option.

11.6.2 Sub transmission Fluid Filled Cables

The majority of the sub transmission cable in the WELL network is fluid (oil or gas) pressurised cable, installed between 1960 and 1980. Fluid filled cables are particularly prone to damage in an earthquake as well as being expensive and time consuming to repair, requiring skills that are not available within the region.

The condition of these cables is individually monitored and assessed against asset health and criticality criteria. These cables are manageable from an operational point of view for the planning period as indicated in Section 7. Exposure to a significant earthquake event however, may result in cable damage without causing a fault on the cable, such as fluid leaks, which would have a negative impact on the reliability of the network. Repairing a fluid leak is a difficult task as the means of locating the leak are limited when there is no associated cable fault, resulting in leaks having a high cost to locate and repair, as well as ongoing costs while fluid is being lost. Due to these repair difficulties and the high likelihood of a fault causing damage in an earthquake scenario, repair of these cables may not be a viable solution. Some of this risk can be mitigated through the purchase of overhead line equipment for the construction of emergency line routes.

Current best practise is to replace cables with XLPE insulation into ducts, rather than direct burial as is the case with older cables. This means that modern cable installations are significantly more resilient to



earthquake damage. A programme of widespread cable replacement could have significant resilience benefits and would also present the opportunity to create interconnected rings at the sub transmission level which would further improve the security of the system. The cost of replacing all cables early is prohibitive from a cost benefit perspective. For this reason, WELL’s approach is to replace the cables when required for BAU purposes but future proof the system by building sub transmission rings to improve resiliency and allow greater load transfer between substations.

The estimated cost of this future resilience work is set out in Figure 11-8.

Future Resilience Work	Purpose	Cost	Note
Central Park 2 substation	Single point of failure	\$40m	Initial estimates from options development with Transpower
Sub transmission cable	Vulnerability of fluid-filled cable to earthquake damage	\$80m	Marginal cost of constructing sub-transmission rings in Lower Hutt and Wellington

Figure 11-9 Cost of Future Resilience Projects

While the items planned for purchase as part of this SCPP programme will provide an improvement to restoration times, there may still be significant outages in many areas of the network, depending on the scale of any earthquake occurring.

These two future resilience works were not included within the SCPP application to ensure the application remained focused on addressing areas where the preferred solution could be implemented within the three year timeframe. As such these works were outside the scope of the SCPP and the level of investment required is beyond what can be funded within the DPP allowances. If these construction programmes are to be completed, an application for a full CPP will be produced with the intention of it coming into effect at the conclusion of the readiness SCPP.

As discussed in Section 7, WELL has an aging network of 11kV cables with some sections approaching their end of life and thus becoming more prone to earthquake damage. Further condition monitoring is being introduced in 2018 which will help predict end of life for the cables and may also drive a significant future replacement programme, either for BAU or resiliency reasons.



This page is intentionally blank





Section 12

Expenditure Summary

12 Expenditure Summary

This section provides an overview of WELL's forecast capital and operational expenditure over the planning period in order to implement this AMP.

12.1 Capital Expenditure 2018-2028

12.1.1 Consumer Connections

The total forecast consumer connection capital expenditure for 2018 to 2028, as discussed in Section 8, is presented in Figure 12-1.

Consumer Type	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Substation	4,258	4,289	4,356	4,356	4,708	4,732	4,756	4,779	4,803	4,827
Subdivision	1,235	1,125	1,252	2,210	2,802	2,830	2,773	2,787	2,801	2,815
High Voltage Connection	131	133	136	139	141	144	147	150	153	156
Residential Customers	1,111	1,127	1,154	1,170	1,198	1,215	1,244	1,262	1,292	1,310
Public Lighting	100	100	100	100	100	100	100	100	100	100
Total	6,835	6,774	6,998	7,975	8,949	9,021	9,020	9,078	9,149	9,208

Figure 12-1 Consumer Connection Capital Expenditure Forecast
(\$K in constant prices)



12.1.2 System Growth

The total forecast capital expenditure for system growth and security of supply for 2018 to 2028, as discussed in Section 8, is presented in Figure 12-2.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	2,100	1,500	700	-	-	-	-	-	-	-
Zone Substations	600	2,700	1,400	4,500	100	-	-	300	2,700	-
Distribution Poles and Lines	-	-	-	-	-	-	-	-	-	-
Distribution Cables	1000	1,900	1,900	2,000	4,600	5,300	2,500	1,500	1,500	1,500
Distribution Substations	-	-	-	-	-	-	-	-	-	-
Distribution Switchgear	-	-	-	-	-	-	-	-	-	-
Other Network Assets ⁷⁴	490	530	960	1,230	2,080	2,430	2,930	2,830	2,480	2,580
Total	4,190	6,630	4,960	7,730	6,780	7,730	5,430	4,630	6,680	4,080

Figure 12-2 System Growth Capital Expenditure Forecast
(\$K in constant prices)

⁷⁴ Other Network Assets includes the capital expenditure required for emerging technologies.

12.1.3 Asset Replacement and Renewal

The total forecast capital expenditure for asset replacement and renewal for 2018 to 2028 as discussed in Section 7 is presented in Figure 12-3. This includes provision for replacements that arise from condition assessment programmes during the year.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	250	250	350	350	300	1,175	2,925	300	300	300
Zone Substations	2,050	900	2,000	1,250	1,250	250	250	250	250	250
Distribution Poles and Lines	7,000	6,709	6,710	6,522	7,531	7,825	8,475	10,917	9,801	10,547
Distribution Cables	200	200	250	250	2,750	2,750	3,250	3,750	4,750	6,250
Distribution Substations	2,100	2,100	2,300	3,000	2,625	3,500	3,500	3,500	3,500	3,500
Distribution Switchgear	3,305	3,178	3,291	3,450	2,350	3,350	3,850	3,850	3,850	3,850
Other Network Assets	2,968	3,812	3,677	3,675	2,940	2,200	2,200	2,200	2,200	2,200
Total	17,873	17,149	18,578	18,497	19,746	21,050	24,450	24,767	24,651	26,897

Figure 12-3 System Asset Replacement and Renewal Capital Expenditure Forecast
(\$K in constant prices)

12.1.4 Asset Relocations

The forecast asset relocation capital expenditure, primarily related to roading projects, is presented in Figure 12-4.

Programme	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Roading Relocations	2,151	1,648	1,714	1,731	1,748	1,766	1,784	1,801	1,819	1,838
Total	2,151	1,648	1,714	1,731	1,748	1,766	1,784	1,801	1,819	1,838

Figure 12-4 Asset Relocation Capital Expenditure Forecast
(\$K in constant prices)



12.1.5 Reliability, Safety and Environment

Asset management expenditure that is not directly the result of asset health drivers is categorised into quality of supply and other reliability, safety and environmental expenditure. Quality of supply projects target poorly performing feeders. Other reliability, safety and environmental projects include the seismic programme and other resilience work. The total forecast capital expenditure for these categories is presented in Figure 12-5.

Programme	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Worst Performing Feeders	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Total Quality of Supply	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Seismic Programme (BAU)	1,320	2,130	1,010	470	600	-	-	-	-	-
Streamlined CPP	6,794	7,690	10,324	-	-	-	-	-	-	-
Total Other Reliability, Safety and Environment	8,114	9,820	11,334	470	600	-	-	-	-	-

Figure 12-5 Reliability, Safety and Environmental Capital Expenditure 2018-2028
(\$K in constant prices)

12.1.6 Non-network Assets

The forecast capital expenditure for non-network assets is presented in Figure 12-6.

Routine Expenditure	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Software and Licenses	1,408	1,064	1,044	1,172	1,078	1,058	1,039	1,028	1,018	1,018
IT Infrastructure	545	419	404	436	430	420	409	402	394	394
Streamlined CPP	1,363	3,023	872	-	-	-	-	-	-	-
Total Non-network Assets	3,316	4,506	2,320	1,608	1,508	1,478	1,448	1,430	1,412	1,412

Figure 12-6 Non-Network Asset Capital Expenditure Forecast
(\$K in constant prices)

12.1.7 Capital Expenditure Summary

Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Consumer Connection	6,835	6,774	6,998	7,975	8,949	9,021	9,020	9,078	9,149	9,208
System Growth	4,190	6,630	4,960	7,730	6,780	7,730	5,430	4,630	6,680	4,080
Asset Replacement & Renewal	17,873	17,149	18,578	18,497	19,746	21,050	24,450	24,767	24,651	26,897
Asset Relocations	2,151	1,648	1,714	1,731	1,748	1,766	1,784	1,801	1,819	1,838
Regulatory, Safety & Environment (other)	8,114	9,820	11,334	470	600	0	0	0	0	0
Quality of Supply	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
Subtotal - Capital Expenditure on Network Assets	41,773	43,531	45,609	37,933	39,473	40,925	41,647	41,245	43,268	42,992
Non-Network Assets	3,316	4,506	2,320	1,608	1,508	1,478	1,448	1,430	1,412	1,412
Total – Capital Expenditure on Assets	45,089	48,037	47,929	39,541	40,981	42,403	43,095	42,675	44,680	44,404

Figure 12-7 Capital Expenditure Forecast – 2018 to 2028
(\$K in constant prices)

12.2 Operational Expenditure 2018-2028

A breakdown of forecast preventative maintenance expenditure by asset category is shown in Figure 12-8. This budget is relatively constant and is set by the asset strategies and maintenance standards that define inspection tasks and frequencies.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	116	116	116	116	116	116	114	114	114	114
Zone Substations	293	272	261	271	266	271	261	271	291	266
Distribution Poles and Lines	441	439	437	434	433	431	429	428	427	428
Distribution Cables	200	200	200	200	200	200	200	200	200	200
Distribution Substations	435	435	435	435	435	435	435	435	435	435
Distribution Switchgear	728	728	727	727	727	727	727	727	727	727
Other Network Assets	280	280	278	278	278	278	278	278	278	278
Total	2,493	2,470	2,454	2,461	2,455	2,458	2,444	2,453	2,472	2,448

Figure 12-8 Preventative Maintenance by Asset Category – 2018 to 2028
(\$K in constant prices)

The forecast corrective maintenance expenditure by asset category is shown in Figure 12-9. This excludes capitalised maintenance, which is incorporated into Figure 12-3. These forecasts are based on historical trends and forecast asset replacements; however year on year variances across the different asset categories will occur depending on the nature of the corrective maintenance that is required in any given year.

Asset Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Subtransmission	-	-	-	-	-	-	-	-	-	-
Zone Substations	163	165	166	168	170	173	174	177	172	172
Distribution Poles and Lines	832	824	763	764	858	866	874	880	880	880
Distribution Cables	169	175	181	187	194	200	207	215	222	222
Distribution Substations	938	940	937	980	977	974	971	968	968	968
Distribution Switchgear	545	538	530	523	516	509	502	495	495	495
Other Network Assets	258	290	241	321	328	355	388	385	385	385
Total	2,905	2,932	2,818	2,943	3,043	3,077	3,116	3,120	3,122	3,122

Figure 12-9 Corrective Maintenance by Asset Category – 2018 to 2028
(\$K in constant prices)

The total forecast operational expenditure for 2018 to 2028 is shown in Figure 12-10.

Category	2018/19	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
Service interruptions & emergencies maintenance	3,894	3,898	3,897	3,898	3,897	3,897	3,897	3,898	3,898	3,876
Vegetation management	1,651	1,652	1,652	1,652	1,652	1,653	1,652	1,653	1,653	1,645
Routine & corrective maintenance and inspection ⁷⁵	7,048	7,337	7,800	8,044	8,003	8,079	8,077	8,187	8,320	8,402
Asset replacement & renewal maintenance	1,568	1,583	1,605	1,626	1,650	1,673	1,692	1,703	1,567	1,660
Subtotal –Operational Expenditure on Network Assets	14,161	14,470	14,954	15,220	15,202	15,302	15,318	15,441	15,438	15,583
Non-network Operational Expenditure	16,626	16,621	16,621	16,621	16,621	16,621	16,621	16,621	16,621	16,621
Total – Operational Expenditure	30,787	31,091	31,575	31,841	31,823	31,923	31,939	32,062	32,059	32,204

Figure 12-10 Operational Expenditure Forecast – 2018 to 2028
(\$K in constant price)

⁷⁵ Routine & corrective maintenance and inspection expenditure also allows for emerging technology & SSCP Opex costs.



Appendices

Appendix A Assumptions

Area	Possible impact and variation to plan	Assumption	Reason for assumption
Demand and Consumption	Growth at higher levels may bring forward network reinforcement investment, or conversely a decrease in demand growth may lead to deferral of reinforcement investment.	<p>Growth in peak demand will continue to be lower than the national average and will remain steady through the forecast period.</p> <p>Overall consumption of electricity (kWh volume) is forecast to continue decreasing for one more year before stabilising.</p>	Measured system loadings and load analysis indicate minor maximum demand growth in some areas but energy volumes declining across the network as a whole. Low to moderate levels of growth in the housing sector.
Capital Expenditure - Resilience	Investment levels may change in response to legislative changes or in response the final decision of the Commission regarding the SCPP application.	Allowance has been made for seismic building reinforcement in order to meet legislative requirements. Assumption has also been made that the SCPP application under review with the Commission will be approved.	Draft decision from the Commission on 1 Feb 2018 indicated approval for the full funding request.
Capital Expenditure - Customer Driven	Investment levels may increase or decrease in response to changes in demand for new connections from customers.	The capital expenditure proposed for customer initiated projects will remain within forecast levels.	Overall customer market in residential sector is steady though building consents do show an increase. Ability to recover upstream costs for larger investments or uneconomic supplies.
Capital Expenditure - Network Driven	Investment levels may increase or decrease in response to changes in known asset condition and possible increased requirements for asset replacement that cannot be accommodated in present plans, or catastrophic plant failure requiring a high one-off cost.	The capital expenditure proposed for asset integrity and performance will continue at forecast levels, which assume a steady operating state.	The overall condition and rate of aging of network assets is well known, steady and no "step change" in expenditure is expected. The strategy for overhead line assets has been updated in 2017 to include a greater focus on predictive analysis. Further work on predictive analysis of overhead conductors and underground cables will continue in 2018.

Area	Possible impact and variation to plan	Assumption	Reason for assumption
Operational Expenditure - Routine Inspection and Maintenance	Any material change to the annual maintenance programme or costs associated with them may lead to an increase, or decrease in the Opex costs associated with inspection and maintenance.	The inspection and maintenance expenditure proposed will remain within forecast levels for the next four years. Managing mature network assets, the routine of inspection and servicing is not likely to change significantly, although the re-negotiation of the Field Services Agreement (FSA) in 2019 may change the associated costs.	The inspection programme is defined by comprehensive maintenance standards covering all asset classes. Rates are set in the FSA and even though this will be re-negotiated with the new agreement in 2019, it is anticipated to be largely similar to current costs.
Operational Expenditure - Reactive Maintenance	A change in the rate of failure of network equipment could lead to an increase in reactive maintenance requirements and costs. A change to the field service provider could lead to a higher cost of maintenance.	The reactive maintenance expenditure proposed will remain within forecast levels for the next year. Aging assets may lead to higher levels of reactive maintenance required longer term and a change of the FSA may result in changes to the associated reactive maintenance expenditure.	Reactive maintenance rates defined in FSA, which are expected to be maintained at similar levels in the new contract.
Inflation	Capital and Operational Expenditure forecasts have been inflated for future years to take into account changes in CPI, the cost of labour and materials. Should inflation vary from the assumed value forecast amounts may increase or decrease.	The assumptions used to prepare the financial information disclosed in nominal New Zealand dollars in the Report on Forecast Capital Expenditure set out in Schedule 11a and the Report on Forecast Operational Expenditure set out in Schedule 11b is based on increases in costs due to annual forecast inflation and price escalation of 2.0% pa across the planning period.	The rates used are based on the midpoint of the RBNZ's target inflation range.
Quality targets	Any increase in quality targets, or alteration in the assessment method, may lead to increased level of investment to maintain network performance.	Network reliability performance targets for 2015/16 to 2019/20 were set by the Commission's 2014 DPP Determination. It is assumed that the targets will increase in the 2020 Determination due to the changes in the HSW Act.	The targets adopted in this plan align with the Commission's 2014 determination until 2020 and reflect WELL's intention to maintain network reliability at current levels. Future targets will be dependent on the impact of the HSW Act and the changing work practices that have made a material change in the amount of work that is undertaken de-energised.

Area	Possible impact and variation to plan	Assumption	Reason for assumption
Regulatory environment	A change to the regulatory environment may lead to increased or decreased ability to recover on investments.	The regulatory environment will continue to incentivise shareholders to invest in the network to ensure a sustainably profitable business. New requirements relating to the HSW Act will not significantly alter costs.	<p>The expected impact of the 2014 DPP reset has been assessed, providing stability through to 2020.</p> <p>As WELL is committed to implementing best practice in workplace health and safety, compliance with the HSW Act will not materially increase costs.</p>
Transmission Network	A change to the configuration or capability of the transmission system could lead to a requirement for increased levels of investment on the network to provide capacity or security in the absence of grid capability.	The transmission grid, and grid exit point connections, will remain unchanged apart from agreed projects.	Asset Plans from Transpower indicate no changes to the grid that will significantly impact WELL during the planning period, other than those identified in Section 8 and the Section 11.
Transmission Pricing	Changes to the methods of transmission pass-through pricing may lead to increased expenditure as grid alternative options become more attractive in a non-pass-through environment.	The transmission pricing methodologies will remain largely unchanged and the transmission pass-through pricing will remain in place.	Transmission pricing is regulated as a pass-through cost and our expectation that this will remain as a pass-through cost with the net effect to the business remaining the same. The outcome of current consultation by the Electricity Authority on TPM is yet to be determined.
Economy	An increase in the cost of raw materials and imported equipment could cause an increase in investment costs, or lead to deferral of projects to remain within budgets.	The commodity markets will remain stable during the forecast period limiting equipment price rises. GDP growth in the area supplied by WELL is likely to be modest for the foreseeable future.	Assumptions of regional GDP growth are supported by observations of demand on the network and local business activities.

Area	Possible impact and variation to plan	Assumption	Reason for assumption
Business cycle	The evolution of a business and its operating environment can impact on strategic decision making and overall approach.	The business cycle is expected to change due to the introduction of new technologies and appropriate investment forecasts have been included into this plan.	The changes to consumer behaviour due to the penetration of new technologies have been based on the worldwide trend of lower costs associated with such technologies making them more accessible.
Technology	Increased levels of network reinforcement may be required to accommodate sudden load increases at consumer premises resulting from demand side technologies, or significantly reduced loads may be seen that could defer investment if load reduction technologies are introduced by consumers.	There will be changes that will result in a rapid uptake of new technology by consumers which could result in higher expenditure on network reinforcement. This reinforcement will be deferred by enabling new technologies on the network and by moving towards becoming a Distribution System Operator.	At demand side, displacement or disruptive technologies such as electric vehicles, vehicle-to-grid and distributed generation will begin to gain penetration into Wellington. Trends in the area of disruptive technology are being closely monitored and plans forecast to prepare for these changes are in Section 9.
Public Safety	Assets in the public domain may require higher than average rates of replacement, or increased level of isolation from the public leading to higher costs, or reallocation of work programmes.	Compliance with requirements for public safety management will not adversely impact upon the existing network assets located in the public domain.	Implementation of a public safety management system in the business, including compliance with NZS 7901 and promoting a culture of incident reporting and safety awareness.

Appendix B Update from 2017 Plan

During the past year, WELL has continued the review of its asset management strategy and practices. Progress against the gaps identified in the 2017 AMP, along with material changes to network development and lifecycle asset management plans, is shown in the table below.

2017 AMP Section	Item	Description
3.7.1.4	Use of System Agreement	Revise Use of System Agreement in line with the model agreement prepared by the Electricity Authority and commence negotiations with retailers using the network.
		On Hold: This work is on hold pending the Electricity Authority's current consultation on Default Distribution Agreements. The Authority will provide an update on the proposal in 2018.
5.10.1	Seismic Reinforcement of Equipment and Buildings	Ongoing assessment of nominated substation buildings in accordance with the seismic assessment programme.
		In Progress: All pre-1976 buildings have been assessed. A work programme is in place to strengthen buildings identified as being earthquake prone by the end of 2022. There are now 18 buildings left to be addressed on this programme.
5.9.13	Resilience of Central Park to HILP events	Additional risk controls to be implemented during 2016 as part of the plan agreed between WELL and Transpower. A list of potentially high cost solutions will be discussed with stakeholders as part of resiliency work planned in 2016.
		In Progress: Engagement with business leaders in 2016 resulted in the resilience of Central Park forming a central component of the resilience project as discussed in Section 11.

2017 AMP Section	Item	Description
5.10.2.2	33kV Overhead Emergency Corridors	Completion of designs for the remaining overhead sub-transmission routes and consultation with WCC to gain approval for these routes.
		In Progress: Wellington city routes have been developed with initial scoping of additional routes in other network areas. Development of emergency corridors in Northeastern and Northwestern network areas will continue in 2018. Field trial of the surface foundation has been completed and manufacturing drawings are being produced. Mass production will begin in 2018.
5.10.2	Resiliency Business Case	Develop a business case assessing options to improve the readiness of the network to High Impact Low Probability events.
		In Progress: WELL has completed a business case identifying options to improve readiness in the event of a major disaster in the region. This formed the basis of the SSCP application. Projects will be completed over the next three years.
6.2	Asset Lifecycle Planning	Continued development of asset lifecycle plans to risk-based asset strategies for all asset categories.
		In Progress: Further developments of the asset fleet strategies for overhead networks have been completed in 2017, with work on the 11kV cable fleet strategy set to occur in 2018.
6.5.1	Sub-transmission Health and Criticality Analysis	A project will be initiated in 2016 to remove the Evans Bay 1 circuit from service in 2017.
		In Progress: A detailed study in 2016 identified a range of options for resolving the health of the Evans Bay 1 circuit. The rate of leakage is being closely monitored and is currently manageable, and removal from service is now planned for 2020, following the completion of the Evans Bay 33kV protection project.
6.5.1	Sub-transmission Health and Criticality Analysis	Work will occur in 2017 to locate and repair an oil leak on the Johnsonville A circuit.
		Complete: The leak on the Johnsonville 1 circuit has been located, and repair work was successfully undertaken in 2017.

2017 AMP Section	Item	Description
6.5.2	Zone Substation Transformer Health and Criticality Analysis	The Evans Bay transformers are anticipated to be replaced to be replaced with new transformers by 2022.
		In Progress: The business case for the replacement of these transformers was prepared, presented and approved at both CIC and the Board in 2017.
6.5.2	Zone Substation Transformer Health and Criticality Analysis	An acoustic wall design will be investigated in 2017 to deal with noise levels at the substation.
		Update: An acoustic wall design will be investigated when the units are upgraded to deal with the noise levels at the substation.
6.5.2	Zone Substation Circuit Breaker Health and Criticality Analysis	Reyrolle Type C circuit breakers at Gracefield are to be replaced over the next two years.
		Update: Reyrolle Type C circuit breakers are to be replaced by the end of 2018. The replacement Reyrolle LMVP switchgear has been ordered in 2017.
6.5.2	Zone Substation Circuit Breaker Health and Criticality Analysis	Further testing after PD mitigation work has identified circuit breakers with high PD that was previously masked. Mitigation works are planned for 2017.
		Update: PD mitigation work will take place in early 2018. Apart from the PD the switchgear is in good condition but has high criticality due to location in Wellington CBD.
6.5.2	Zone Substation Circuit Breaker Health and Criticality Analysis	The switchboard at Kaiwharawhara has shown intermittent PD without consistent location, the PD will continue to be monitored.
		Update: Testing in 2017 identified PD within the CB17 compartment. Test results are being evaluated in conjunction with a PD specialist to develop plans to address the CB in 2018.
6.5.6	Ground Mounted Switchgear Health and Criticality Analysis	Magnefix units with low grease level in the termination may be a sign of heating at the termination. These units are prioritised for re-termination.
		Update: Magnefix units with low grease are prioritised for grease top-up.
6.5.8.3	Load Control Replacement Strategy	WELL is reviewing its load control strategy, which may recommend additional investment in load control assets.

2017 AMP Section	Item	Description
		In Progress: A draft strategy has been developed for the future of the overall load control system on the network. Work to refine and gain approval for this strategy will continue in 2018.
7.1.8	Non-Network Solution Policy	Introducing a new tariff structure to incentivise consumers to use new technologies in a way that smooths peak demand.
		Update: Special EV tariff implemented and investigation into battery storage tariff initiated.
7.1.9.1	Connection Policy	Update standards by developing a distributed generation connection guideline.
		Update: Interim DG connection guideline implemented awaiting publication of the EEA "Guideline for the Connection of Small-Scale Inverter Based Distributed Generation".
7.3	Network Development and Reinforcement Plan	An external review of the Network Development and Reinforcement Plan for the Northeastern Area was planned for 2017.
		Update: Network asset data gathering initiated to inform the NDRP update and review. The update and external review is now planned for 2018.
7.4.1.1	Central Park GXP	Long term plan to address single point of failure risks at Central Park.
		Update: Work with Transpower to implement fire detection and suppression initiated. Formally engaged Transpower for Central Park 2 investigation.
7.6.1	GXP development	Upgrade all subtransmission differential protection on the Brown Owl and Maidstone circuits.
		Update: Protection upgrade scheduled for 2018/19.
7.6.3	Northeastern Network Development Plan	More work will be undertaken to develop a comprehensive Northeastern development plan.
		Update: Network asset data gathering initiated to inform the NDRP update and review. The update and external review is now planned for 2018.
8.1.1.1	SCADA	Investigating the introduction of new software to replace the TrendSCADA data historian tool.

2017 AMP Section	Item	Description
		Ongoing: Investigation into potential alternative software is ongoing.
8.1.1.1	Automatic Load Control System	Undertake further investigation and planning into the replacement for the Foxboro automatic load control system.
		Ongoing: Investigation into potential alternative software is ongoing.
8.5	Deuar pole-testing license	Extending the Deuar pole-testing licenses.
		Complete: The Deuar pole-testing licenses have been extended.

Figure B-1 Progress Against Actions Identified in 2017 AMP

Comparisons between forecast expenditure from the 2017 AMP and the actual expenditure for the 2017/18 regulatory year are shown below in Figure B-2 for operational expenditure and Figure B-3 for capital expenditure.

Expenditure Category	2017/18 Forecast from 2017 AMP	2017/18 Actuals	Variation
Service Interruptions and Emergencies	3,972	4,429	+457
Vegetation Management	1,480	1,863	+383
Routine and Corrective Maintenance and Inspection	8,901	9,564	+663
Asset Replacement and Renewal	840	802	-38
System Operations and Network Support	4,830	5,020	+190
Business Support	11,458	11,691	+233
Operational expenditure	31,481	33,369	+1,888

Figure B-2 Comparison of Operational Expenditure Against 2017 AMP Forecasts (\$K, forecast in nominal dollars)

Operating expenditure was approximately 6% higher than forecast mainly due to increased vegetation and routine and corrective maintenance expenditure which includes a programme to inspect customer owned poles as a public safety initiative. The expenditure on Service Interruptions and Emergencies has been higher than forecast due to the high number of force majeure events over the course of the year.

Expenditure Category	2017/18 Forecast from 2017 AMP	2017/18 Actuals	Variation
Consumer Connection	7,330	10,261	+2,931
System Growth	2,652	704	-1,948
Asset Replacement and Renewal	21,512	21,656	+144
Asset Relocations	1,734	4,240	+2,506
Reliability, Safety and Environment	3,164	2,029	-1,135
Expenditure on Non-network Assets	1,991	579	-1,412
Capital Expenditure	38,383	39,469	+1,086

Figure B-4 Comparison of Capital Expenditure against 2017 AMP Forecasts (\$K, forecast in nominal dollars)

Significant variations between forecast capital expenditure and actual expenditure were as follows:

- A variation of \$2.9 million in Consumer Connection expenditure due to a general uplift in development activity across the region;
- A variation of \$1.9 million in System Growth expenditure due to a deferral of expenditure for the Frederick Street sub transmission cable project to undertake further seismic impact studies;
- A variation of \$2.5 million in Asset Relocations driven by the timing of work required for a large NZTA project and a greater than expected level of make-ready work under the UFB rollout; and
- Approximately \$1.0m of Reliability, Safety and Environmental expenditure which was deferred due to resource constraints from contracting parties (which has since been resolved) meaning that line work was prioritised to occur on regulatory poles instead of line rebuilds.

Appendix C Schedules

Company Name **Wellington Electricity Lines Limited**
 AMP Planning Period **1 April 2018 – 31 March 2028**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
		for year ended 31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28
7												
8												
9	11a(i): Expenditure on Assets Forecast											
		\$000 (in nominal dollars)										
10	Consumer connection	10,261	7,111	7,189	7,575	8,805	10,078	10,362	10,568	10,849	11,153	11,449
11	System growth	704	4,359	7,036	5,369	8,535	7,635	8,879	6,362	5,533	8,143	5,073
12	Asset replacement and renewal	21,656	18,595	18,199	20,109	20,422	22,237	24,180	28,647	29,599	30,049	33,443
13	Asset relocations	4,240	2,238	1,749	1,855	1,911	1,969	2,029	2,090	2,152	2,217	2,285
14	Reliability, safety and environment:											
15	Quality of supply	1,025	2,715	1,602	2,192	1,689	1,858	1,560	1,128	1,158	1,181	1,205
16	Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
17	Other reliability, safety and environment	1,004	8,442	10,421	12,268	519	676	-	-	-	-	-
18	Total reliability, safety and environment	2,029	11,157	12,023	14,460	2,208	2,534	1,560	1,128	1,158	1,181	1,205
19	Expenditure on network assets	38,890	43,461	46,195	49,369	41,881	44,453	47,010	48,796	49,292	52,743	53,455
20	Expenditure on non-network assets	579	3,450	4,782	2,511	1,775	1,698	1,698	1,697	1,709	1,721	1,756
21	Expenditure on assets	39,469	46,911	50,977	51,880	43,656	46,151	48,708	50,493	51,001	54,465	55,211
22												
23	plus Cost of financing		182	183	184	185	186	218	223	225	227	232
24	less Value of capital contributions	11,776	6,417	6,069	6,277	7,020	7,761	6,766	6,765	6,809	6,862	6,906
25	plus Value of vested assets											
26												
27	Capital expenditure forecast	27,693	40,676	45,091	45,787	36,822	38,577	42,160	43,950	44,417	47,830	48,537
28												
29	Assets commissioned	30,474	40,676	45,091	45,787	36,822	38,577	42,160	43,950	44,417	47,830	48,537
30												
31												
32												
		\$000 (in constant prices)										
33	Consumer connection	10,261	6,835	6,774	6,998	7,975	8,949	9,021	9,020	9,078	9,149	9,208
34	System growth	704	4,190	6,630	4,960	7,730	6,780	7,730	5,430	4,630	6,680	4,080
35	Asset replacement and renewal	21,656	17,873	17,149	18,578	18,497	19,746	21,050	24,450	24,767	24,651	26,897
36	Asset relocations	4,240	2,151	1,648	1,714	1,731	1,748	1,766	1,784	1,801	1,819	1,838
37	Reliability, safety and environment:											
38	Quality of supply	1,025	2,610	1,510	2,025	1,530	1,650	1,358	963	969	969	969
39	Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
40	Other reliability, safety and environment	1,004	8,114	9,820	11,334	470	600	-	-	-	-	-
41	Total reliability, safety and environment	2,029	10,724	11,330	13,359	2,000	2,250	1,358	963	969	969	969
42	Expenditure on network assets	38,890	41,773	43,531	45,609	37,933	39,473	40,925	41,647	41,245	43,268	42,992
43	Expenditure on non-network assets	579	3,316	4,506	2,320	1,608	1,508	1,478	1,448	1,430	1,412	1,412
44	Expenditure on assets	39,469	45,089	48,037	47,929	39,541	40,981	42,403	43,095	42,675	44,680	44,404
45												
46	Subcomponents of expenditure on assets (where known)											
47	Energy efficiency and demand side management, reduction of energy losses											
48	Overhead to underground conversion											
49	Research and development											
50												

	for year ended	Current Year CY 31 Mar 18	CY+1 31 Mar 19	CY+2 31 Mar 20	CY+3 31 Mar 21	CY+4 31 Mar 22	CY+5 31 Mar 23	CY+6 31 Mar 24	CY+7 31 Mar 25	CY+8 31 Mar 26	CY+9 31 Mar 27	CY+10 31 Mar 28
Difference between nominal and constant price forecasts												
		\$000										
Consumer connection		-	276	415	577	830	1,129	1,341	1,548	1,771	2,004	2,241
System growth		-	169	406	409	805	855	1,149	932	903	1,463	993
Asset replacement and renewal		-	722	1,050	1,531	1,925	2,491	3,130	4,197	4,832	5,398	6,546
Asset relocations		-	87	101	141	180	221	263	306	351	398	447
Reliability, safety and environment:		-	-	-	-	-	-	-	-	-	-	-
Quality of supply		-	105	92	167	159	208	202	165	189	212	236
Legislative and regulatory		-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment		-	328	601	934	49	76	-	-	-	-	-
Total reliability, safety and environment		-	433	693	1,101	208	284	202	165	189	212	236
Expenditure on network assets		-	1,688	2,664	3,760	3,948	4,980	6,085	7,149	8,047	9,475	10,463
Expenditure on non-network assets		-	134	276	191	167	190	220	249	279	309	344
Expenditure on assets		-	1,822	2,940	3,951	4,115	5,170	6,305	7,398	8,326	9,785	10,807
11a(ii): Consumer Connection												
	for year ended	Current Year CY 31 Mar 18	CY+1 31 Mar 19	CY+2 31 Mar 20	CY+3 31 Mar 21	CY+4 31 Mar 22	CY+5 31 Mar 23					
		\$000 (in constant prices)										
<i>Consumer types defined by EDB*</i>												
Substation		3,973	4,258	4,289	4,356	4,356	4,708					
Subdivision		4,011	1,235	1,125	1,252	2,210	2,802					
High Voltage Connection		1,049	131	133	136	139	141					
Residential Customers		1,150	1,111	1,127	1,154	1,170	1,198					
Public Lighting		78	100	100	100	100	100					
<i>*include additional rows if needed</i>												
Consumer connection expenditure		10,261	6,835	6,774	6,998	7,975	8,949					
less	Capital contributions funding consumer connection	9,232	5,126	5,081	5,249	5,981	6,712					
Consumer connection less capital contributions		1,029	1,709	1,694	1,750	1,994	2,237					
11a(iii): System Growth												
Subtransmission		294	2,100	1,500	700	-	-					
Zone substations		204	600	2,700	1,400	4,500	100					
Distribution and LV lines		-	-	-	-	-	-					
Distribution and LV cables		115	1,000	1,900	1,900	2,000	4,600					
Distribution substations and transformers		21	-	-	-	-	-					
Distribution switchgear		-	-	-	-	-	-					
Other network assets		70	490	530	960	1,230	2,080					
System growth expenditure		704	4,190	6,630	4,960	7,730	6,780					
less	Capital contributions funding system growth	-	-	-	-	-	-					
System growth less capital contributions		704	4,190	6,630	4,960	7,730	6,780					

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
for year ended	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23
11a(iv): Asset Replacement and Renewal	\$000 (in constant prices)					
Subtransmission	305	250	250	350	350	300
Zone substations	1,130	2,050	900	2,000	1,250	1,250
Distribution and LV lines	10,076	7,000	6,709	6,710	6,522	7,531
Distribution and LV cables	1,798	200	200	250	250	2,750
Distribution substations and transformers	4,304	2,100	2,100	2,300	3,000	2,625
Distribution switchgear	3,315	3,305	3,178	3,291	3,450	2,350
Other network assets	728	2,968	3,812	3,677	3,675	2,940
Asset replacement and renewal expenditure	21,656	17,873	17,149	18,578	18,497	19,746
less Capital contributions funding asset replacement and renewal						
Asset replacement and renewal less capital contributions	21,656	17,873	17,149	18,578	18,497	19,746
	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
for year ended	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23
11a(v): Asset Relocations	\$000 (in constant prices)					
<i>Project or programme*</i>						
Asset Relocations	4,240	2,151	1,648	1,714	1,731	1,748
[Description of material project or programme]						
[Description of material project or programme]						
[Description of material project or programme]						
[Description of material project or programme]						
<i>*Include additional rows if needed</i>						
All other project or programmes - asset relocations						
Asset relocations expenditure	4,240	2,151	1,648	1,714	1,731	1,748
less Capital contributions funding asset relocations	2,544	1,291	989	1,028	1,039	1,049
Asset relocations less capital contributions	1,696	860	659	686	692	699
	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
for year ended	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23
11a(vi): Quality of Supply	\$000 (in constant prices)					
<i>Project or programme*</i>						
Reliability improvement Projects	1,025	2,610	1,510	2,025	1,530	1,650
[Description of material project or programme]						
[Description of material project or programme]						
[Description of material project or programme]						
[Description of material project or programme]						
<i>*Include additional rows if needed</i>						
All other projects or programmes - quality of supply						
Quality of supply expenditure	1,025	2,610	1,510	2,025	1,530	1,650
less Capital contributions funding quality of supply						
Quality of supply less capital contributions	1,025	2,610	1,510	2,025	1,530	1,650

Company Name **Wellington Electricity Lines Limited**
 AMP Planning Period **1 April 2018 – 31 March 2028**

SCHEDULE 11b: REPORT ON FORECAST OPERATIONAL EXPENDITURE

This schedule requires a breakdown of forecast operational expenditure for the disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. EDBs must provide explanatory comment on the difference between constant price and nominal dollar operational expenditure forecasts in Schedule 14a (Mandatory Explanatory Notes). This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10	
	for year ended	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28	
9	Operational Expenditure Forecast	\$000 (in nominal dollars)											
10	Service interruptions and emergencies	4,429	4,051	4,137	4,218	4,304	4,389	4,476	4,566	4,658	4,752	4,819	
11	Vegetation management	1,863	1,718	1,753	1,788	1,824	1,860	1,899	1,936	1,975	2,015	2,045	
12	Routine and corrective maintenance and inspection	9,564	7,333	7,786	8,443	8,881	9,013	9,280	9,464	9,784	10,142	10,446	
13	Asset replacement and renewal	802	1,631	1,680	1,737	1,795	1,858	1,922	1,982	2,035	1,910	2,064	
14	Network Opex	16,658	14,733	15,356	16,187	16,804	17,120	17,577	17,948	18,454	18,818	19,375	
15	System operations and network support	5,020	4,893	4,986	5,085	5,187	5,291	5,397	5,504	5,615	5,727	5,841	
16	Business support	11,691	12,405	12,653	12,906	13,164	13,427	13,696	13,970	14,249	14,534	14,825	
17	Non-network opex	16,711	17,298	17,638	17,991	18,351	18,718	19,092	19,474	19,864	20,261	20,666	
18	Operational expenditure	33,369	32,031	32,994	34,178	35,155	35,838	36,670	37,422	38,317	39,079	40,041	
19		\$000 (in constant prices)											
20	for year ended	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28	
22	Service interruptions and emergencies	4,429	3,894	3,898	3,897	3,898	3,897	3,897	3,897	3,898	3,898	3,876	
23	Vegetation management	1,863	1,651	1,652	1,652	1,652	1,652	1,653	1,652	1,653	1,653	1,645	
24	Routine and corrective maintenance and inspection	9,564	7,048	7,337	7,800	8,044	8,003	8,079	8,077	8,187	8,320	8,402	
25	Asset replacement and renewal	802	1,568	1,583	1,605	1,626	1,650	1,673	1,692	1,703	1,567	1,660	
26	Network Opex	16,658	14,161	14,470	14,954	15,220	15,202	15,302	15,318	15,441	15,438	15,583	
27	System operations and network support	5,020	4,703	4,698	4,698	4,698	4,698	4,698	4,698	4,698	4,698	4,698	
28	Business support	11,691	11,923	11,923	11,923	11,923	11,923	11,923	11,923	11,923	11,923	11,923	
29	Non-network opex	16,711	16,626	16,621	16,621	16,621	16,621	16,621	16,621	16,621	16,621	16,621	
30	Operational expenditure	33,369	30,787	31,091	31,575	31,841	31,823	31,923	31,939	32,062	32,059	32,204	
31	Subcomponents of operational expenditure (where known)												
32	Energy efficiency and demand side management, reduction of energy losses												
33	Direct billing*												
34	Research and Development												
35	Insurance	1,122	1,008	1,008	1,008	1,008	1,008	1,008	1,008	1,008	1,008	1,003	
37	* Direct billing expenditure by suppliers that direct bill the majority of their consumers												
39		\$000											
40	for year ended	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28	
42	Service interruptions and emergencies	-	157	239	321	406	492	579	669	760	854	943	
43	Vegetation management	-	67	101	136	172	208	246	284	322	362	400	
44	Routine and corrective maintenance and inspection	-	285	449	643	837	1,010	1,201	1,387	1,597	1,822	2,045	
45	Asset replacement and renewal	-	63	97	132	169	208	249	290	332	343	404	
46	Network Opex	-	572	886	1,233	1,584	1,918	2,275	2,629	3,012	3,381	3,792	
47	System operations and network support	-	190	288	387	489	593	699	806	917	1,029	1,143	
48	Business support	-	482	730	983	1,241	1,504	1,773	2,047	2,326	2,611	2,902	
49	Non-network opex	-	672	1,017	1,370	1,730	2,097	2,471	2,853	3,243	3,640	4,045	
50	Operational expenditure	-	1,244	1,903	2,603	3,314	4,015	4,747	5,483	6,255	7,021	7,838	

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028

SCHEDULE 12a: REPORT ON ASSET CONDITION

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

sch ref		Asset condition at start of planning period (percentage of units by grade)										
	Voltage	Asset category	Asset class	Units	Grade 1	Grade 2	Grade 3	Grade 4	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years	
7												
8												
9												
10	All	Overhead Line	Concrete poles / steel structure	No.	0.02%	0.72%	31.30%	66.71%	1.25%	3	1.99%	
11	All	Overhead Line	Wood poles	No.	1.19%	9.69%	66.57%	17.16%	5.39%	3	16.27%	
12	All	Overhead Line	Other pole types	No.						N/A		
13	HV	Subtransmission Line	Subtransmission OH up to 66kV conductor	km		5.78%	92.30%	1.92%		3	1.00%	
14	HV	Subtransmission Line	Subtransmission OH 110kV+ conductor	km						N/A		
15	HV	Subtransmission Cable	Subtransmission UG up to 66kV (XLPE)	km			4.84%	95.16%		3	-	
16	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Oil pressurised)	km		22.86%	77.14%			3	-	
17	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Gas pressurised)	km	2.25%	3.39%	94.36%			3	5.64%	
18	HV	Subtransmission Cable	Subtransmission UG up to 66kV (PILC)	km		29.26%	70.74%			3	-	
19	HV	Subtransmission Cable	Subtransmission UG 110kV+ (XLPE)	km						N/A		
20	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Oil pressurised)	km						N/A		
21	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Gas Pressurised)	km						N/A		
22	HV	Subtransmission Cable	Subtransmission UG 110kV+ (PILC)	km						N/A		
23	HV	Subtransmission Cable	Subtransmission submarine cable	km						N/A		
24	HV	Zone substation Buildings	Zone substations up to 66kV	No.			100.00%			4	-	
25	HV	Zone substation Buildings	Zone substations 110kV+	No.						N/A		
26	HV	Zone substation switchgear	22/33kV CB (Indoor)	No.		100.00%				4	100.00%	
27	HV	Zone substation switchgear	22/33kV CB (Outdoor)	No.						N/A		
28	HV	Zone substation switchgear	33kV Switch (Ground Mounted)	No.						N/A		
29	HV	Zone substation switchgear	33kV Switch (Pole Mounted)	No.			50.00%	50.00%		3	-	
30	HV	Zone substation switchgear	33kV RMU	No.						N/A		
31	HV	Zone substation switchgear	50/66/110kV CB (Indoor)	No.						N/A		
32	HV	Zone substation switchgear	50/66/110kV CB (Outdoor)	No.						N/A		
33	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (ground mounted)	No.		3.80%	64.13%	32.07%		3	3.80%	
34	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (pole mounted)	No.						N/A		
35												

		Asset condition at start of planning period (percentage of units by grade)									
	Voltage	Asset category	Asset class	Units	Grade 1	Grade 2	Grade 3	Grade 4	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years
36											
37											
38											
39	HV	Zone Substation Transformer	Zone Substation Transformers	No.	3.85%	17.31%	78.84%			4	3.85%
40	HV	Distribution Line	Distribution OH Open Wire Conductor	km	0.02%	16.55%	70.33%	13.10%		3	1.00%
41	HV	Distribution Line	Distribution OH Aerial Cable Conductor	km		40.85%	59.07%	0.08%		3	1.00%
42	HV	Distribution Line	SWER conductor	km						N/A	
43	HV	Distribution Cable	Distribution UG XLPE or PVC	km	0.01%	0.13%	31.89%	67.97%		3	1.00%
44	HV	Distribution Cable	Distribution UG PILC	km	0.07%	5.96%	83.80%	10.17%		3	1.00%
45	HV	Distribution Cable	Distribution Submarine Cable	km			100.00%			4	-
46	HV	Distribution switchgear	3.3/6.6/11/22kV CB (pole mounted) - reclosers and sectionalisers	No.	7.69%	30.77%	15.39%	46.15%		3	7.69%
47	HV	Distribution switchgear	3.3/6.6/11/22kV CB (Indoor)	No.	2.16%	4.55%	78.43%	14.86%		3	6.71%
48	HV	Distribution switchgear	3.3/6.6/11/22kV Switches and fuses (pole mounted)	No.	5.27%	33.62%	46.16%	14.95%		3	5.27%
49	HV	Distribution switchgear	3.3/6.6/11/22kV Switch (ground mounted) - except RMU	No.	5.85%	15.15%	67.30%	11.70%		3	5.00%
50	HV	Distribution switchgear	3.3/6.6/11/22kV RMU	No.	1.12%	3.90%	73.33%	21.65%		3	5.02%
51	HV	Distribution Transformer	Pole Mounted Transformer	No.	0.88%	1.43%	45.26%	52.43%		3	3.02%
52	HV	Distribution Transformer	Ground Mounted Transformer	No.	1.14%	2.13%	70.90%	25.83%		3	3.00%
53	HV	Distribution Transformer	Voltage regulators	No.						N/A	
54	HV	Distribution Substations	Ground Mounted Substation Housing	No.	0.43%	3.79%	83.11%	12.67%		3	3.00%
55	LV	LV Line	LV OH Conductor	km	0.22%	14.22%	78.98%	6.58%		2	1.00%
56	LV	LV Cable	LV UG Cable	km	1.09%	2.75%	64.88%	31.28%		2	2.00%
57	LV	LV Streetlighting	LV OH/UG Streetlight circuit	km	0.07%	9.09%	66.91%	23.93%		1	2.00%
58	LV	Connections	OH/UG consumer service connections	No.	0.00%	0.04%	96.18%	3.78%		1	1.00%
59	All	Protection	Protection relays (electromechanical, solid state and numeric)	No.	2.54%	3.32%	69.70%	24.44%		3	10.00%
60	All	SCADA and communications	SCADA and communications equipment operating as a single system	Lot	16.47%	27.59%	11.88%	44.06%		3	10.00%
61	All	Capacitor Banks	Capacitors including controls	No.						N/A	
62	All	Load Control	Centralised plant	Lot		8.33%	79.17%	12.50%		3	8.33%
63	All	Load Control	Relays	No.						N/A	
64	All	Civils	Cable Tunnels	km			100.00%			3	-



Company Name

Wellington Electricity Lines Limited

AMP Planning Period

1 April 2018 - 31 March 2028

SCHEDULE 12b: REPORT ON FORECAST CAPACITY

This schedule requires a breakdown of current and forecast capacity and utilisation for each zone substation and current distribution transformer capacity. The data provided should be consistent with the information provided in the AMP. Information provided in this table should relate to the operation of the network in its normal steady state configuration.

sch ref

12b(j): System Growth - Zone Substations

	Current Peak Load (MVA)	Installed Firm Capacity (MVA)	Security of Supply Classification (type)	Transfer Capacity (MVA)	Utilisation of Installed Firm Capacity %	Installed Firm Capacity +5 years (MVA)	Utilisation of Installed Firm Capacity + 5yrs %	Installed Firm Capacity Constraint +5 years (cause)	Explanation
<i>Existing Zone Substations</i>									
8	16	21	N-1	9	76%	21	81%	No constraint within +5 years	
9	16	22	N-1	7	73%	22	77%	No constraint within +5 years	
10	13	19	N-1	11	68%	19	68%	No constraint within +5 years	
11	30	23	N-1	13	129%	36	89%	No constraint within +5 years	Constraint due to Frederick St subtransmission cables. These are planned to be replaced in 2019-2020.
12	11	20	N-1	12	55%	20	65%	No constraint within +5 years	
13	17	22	N-1	11	77%	22	82%	No constraint within +5 years	
14	22	21	N-1	9	105%	21	114%	Subtransmission circuit	After the replacement of the Ngauranga transformers in 2020, load will be shifted to remove this constraint.
15	16	21	N-1	7	76%	21	76%	No constraint within +5 years	
16	12	19	N-1	9	63%	19	74%	No constraint within +5 years	
17	20	16	N-1	17	125%	16	138%	Subtransmission circuit	Manage operationally. Constraint investigation is underway to remove pinch points.
18	15	19	N-1	12	79%	19	84%	No constraint within +5 years	
19	19	16	N-1	12	119%	16	131%	Transformer	After new Pauatahanui zone substation in 2020-2022, load will be shifted to remove this constraint.
20	21	30	N-1	14	70%	30	93%	No constraint within +5 years	
21	16	22	N-1	11	73%	22	82%	No constraint within +5 years	
22	25	25	N-1	16	100%	25	104%	Subtransmission circuit	Manage operationally
23	10	12	N-1	10	83%	12	108%	Transformer	Transformer replacement scheduled in 2020.
24	26	24	N-1	13	108%	24	113%	Transformer	Manage operationally. Currently working with customers on shifting load to adjacent substations
25	21	20	N-1	14	105%	20	110%	Transformer	After new Pauatahanui zone substation in 2020-2022, load will be shifted to remove this constraint.
26	14	18	N-1	12	78%	18	83%	No constraint within +5 years	
27	15	16	N-1	13	94%	16	100%	Transformer	Manage operationally
28	31	30	N-1	21	103%	30	110%	Transformer	Manage operationally
	15	23	N-1	10	65%	23	78%	No constraint within +5 years	
	19	24	N-1	21	79%	24	79%	No constraint within +5 years	
	15	19	N-1	10	79%	19	79%	No constraint within +5 years	
	18	20	N-1	3	90%	20	95%	No constraint within +5 years	
	16	16	N-1	11	100%	16	106%	Transformer	After new Pauatahanui zone substation in 2020-2022, load will be shifted to remove this constraint.
	16	23	N-1	14	70%	23	74%	No constraint within +5 years	

¹ Extend forecast capacity table as necessary to disclose all capacity by each zone substation

Company Name	Wellington Electricity Lines Limited
AMP Planning Period	1 April 2018 - 31 March 2028

SCHEDULE 12C: REPORT ON FORECAST NETWORK DEMAND

This schedule requires a forecast of new connections (by consumer type), peak demand and energy volumes for the disclosure year and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumptions used in developing the expenditure forecasts in Schedule 11a and Schedule 11b and the capacity and utilisation forecasts in Schedule 12b.

sch ref		Number of connections					
		Current Year CY for year ended 31 Mar 17	CY+1 31 Mar 18	CY+2 31 Mar 19	CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22
7	12c(i): Consumer Connections						
8	Number of ICPs connected in year by consumer type						
9							
10							
11	Consumer types defined by EDB*						
12	Domestic	770	770	770	770	770	770
13	Large Commercial	16	16	16	16	16	16
14	Large Industrial	-	-	-	-	-	-
15	Medium Commercial	10	10	10	10	10	10
16	Small Commercial	395	395	395	395	395	395
17	Small Industrial	5	5	5	5	5	5
18	Unmetered	8	8	8	8	8	8
19	Connections total	1,204	1,204	1,204	1,204	1,204	1,204
20	*include additional rows if needed						
21	Distributed generation						
22	Number of connections	180	200	200	200	200	200
23	Capacity of distributed generation installed in year (MVA)	1	1	1	1	1	1
24	12c(ii) System Demand						
25							
26	Maximum coincident system demand (MW)						
27	GXP demand	517	522	527	532	534	536
28	plus Distributed generation output at HV and above	58	58	58	59	59	59
29	Maximum coincident system demand	575	580	585	591	593	595
30	less Net transfers to (from) other EDBs at HV and above	-	-	-	-	-	-
31	Demand on system for supply to consumers' connection points	575	580	585	591	593	595
32	Electricity volumes carried (GWh)						
33	Electricity supplied from GXPs	2,154	2,177	2,177	2,177	2,177	2,177
34	less Electricity exports to GXPs	-	-	-	-	-	-
35	plus Electricity supplied from distributed generation	260	241	241	241	241	241
36	less Net electricity supplied to (from) other EDBs	-	-	-	-	-	-
37	Electricity entering system for supply to ICPs	2,414	2,418	2,418	2,418	2,418	2,418
38	less Total energy delivered to ICPs	2,276	2,297	2,297	2,297	2,297	2,297
39	Losses	138	121	121	121	121	121
40							
41	Load factor	48%	48%	47%	47%	47%	46%
42	Loss ratio	5.7%	5.0%	5.0%	5.0%	5.0%	5.0%

Company Name	Wellington Electricity Lines Limited
AMP Planning Period	1 April 2018 – 31 March 2028
Network / Sub-network Name	

SCHEDULE 12d: REPORT FORECAST INTERRUPTIONS AND DURATION

This schedule requires a forecast of SAIFI and SAIDI for disclosure and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumed impact of planned and unplanned SAIFI and SAIDI on the expenditures forecast provided in Schedule 11a and Schedule 11b.

sch ref		for year ended	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
			31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22	31 Mar 23
8								
9								
10	SAIDI							
11	Class B (planned interruptions on the network)		6.5	5.3	5.3	5.3	5.3	5.3
12	Class C (unplanned interruptions on the network)		44.6	30.1	30.1	30.1	30.1	30.1
13	SAIFI							
14	Class B (planned interruptions on the network)		0.04	0.02	0.02	0.02	0.02	0.02
15	Class C (unplanned interruptions on the network)		0.62	0.53	0.53	0.53	0.53	0.53



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices.

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
3	Asset management policy	To what extent has an asset management policy been documented, authorised and communicated?	3	Wellington Electricity has an Asset Management Policy which is derived from the organisational vision and linked to the organisational strategies, objectives and targets. Wellington Electricity has also drafted an Asset Management Strategy (AM Strategy) and associated Fleet Strategies for discreet assets.		Widely used AM practice standards require an organisation to document, authorise and communicate its asset management policy (eg, as required in PAS 55 para 4.2 i). A key pre-requisite of any robust policy is that the organisation's top management must be seen to endorse and fully support it. Also vital to the effective implementation of the policy, is to tell the appropriate people of its content and their obligations under it. Where an organisation outsources some of its asset-related activities, then these people and their organisations must equally be made aware of the policy's content. Also, there may be other stakeholders, such as regulatory authorities and shareholders who should be made aware of it.	Top management. The management team that has overall responsibility for asset management.	The organisation's asset management policy, its organisational strategic plan, documents indicating how the asset management policy was based upon the needs of the organisation and evidence of communication.
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders?	3	All key components of Wellington Electricity's AM Strategy is covered in the AMP. Wellington Electricity has developed two further Fleet Strategies in 2017 in addition to the three that were completed pre-2017. Development of these Fleet Strategies as well as the overarching AM Strategy has taken into consideration alignment with other organisational policies and key stakeholders and has had peer review undertaken by industry experts.		In setting an organisation's asset management strategy, it is important that it is consistent with any other policies and strategies that the organisation has and has taken into account the requirements of relevant stakeholders. This question examines to what extent the asset management strategy is consistent with other organisational policies and strategies (eg, as required by PAS 55 para 4.3.1 b) and has taken account of stakeholder requirements as required by PAS 55 para 4.3.1 c). Generally, this will take into account the same policies, strategies and stakeholder requirements as covered in drafting the asset management policy but at a greater level of detail.	Top management. The organisation's strategic planning team. The management team that has overall responsibility for asset management.	The organisation's asset management strategy document and other related organisational policies and strategies. Other than the organisation's strategic plan, these could include those relating to health and safety, environmental, etc. Results of stakeholder consultation.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	3	An Asset Management Strategy has been drafted to cover the total management of assets. Lifecycle Strategies have been developed for the major asset classes such as power transformers, sub transmission cables and zone sub circuit breakers. In addition, further fleet strategies have been developed for overhead structures and overhead components. There are 3 more strategies to be written.		Good asset stewardship is the hallmark of an organisation compliant with widely used AM standards. A key component of this is the need to take account of the lifecycle of the assets, asset types and asset systems. (For example, this requirement is recognised in 4.3.1 d) of PAS 55). This question explores what an organisation has done to take lifecycle into account in its asset management strategy.	Top management. People in the organisation with expert knowledge of the assets, asset types, asset systems and their associated life-cycles. The management team that has overall responsibility for asset management. Those responsible for developing and adopting methods and processes used in asset management	The organisation's documented asset management strategy and supporting working documents.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	2	Flowing on from the abovementioned Asset Fleet Strategies, WELL is in the process of putting in place comprehensive asset management plans that cover all lifecycle activities of the key asset classes, aligned to asset management objectives and strategies.		The asset management strategy need to be translated into practical plan(s) so that all parties know how the objectives will be achieved. The development of plan(s) will need to identify the specific tasks and activities required to optimize costs, risks and performance of the assets and/or asset system(s), when they are to be carried out and the resources required.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers.	The organisation's asset management plan(s).



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
3	Asset management policy	To what extent has an asset management policy been documented, authorised and communicated?	The organisation does not have a documented asset management policy.	The organisation has an asset management policy, but it has not been authorised by top management, or it is not influencing the management of the assets.	The organisation has an asset management policy, which has been authorised by top management, but it has had limited circulation. It may be in use to influence development of strategy and planning but its effect is limited.	The asset management policy is authorised by top management, is widely and effectively communicated to all relevant employees and stakeholders, and used to make these persons aware of their asset related obligations.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders? OR The organisation does not have an asset management strategy.	The organisation has not considered the need to ensure that its asset management strategy is appropriately aligned with the organisation's other organisational policies and strategies or with stakeholder requirements. OR The organisation does not have an asset management strategy.	The need to align the asset management strategy with other organisational policies and strategies as well as stakeholder requirements is understood and work has started to identify the linkages or to incorporate them in the drafting of asset management strategy.	Some of the linkages between the long-term asset management strategy and other organisational policies, strategies and stakeholder requirements are defined but the work is fairly well advanced but still incomplete.	All linkages are in place and evidence is available to demonstrate that, where appropriate, the organisation's asset management strategy is consistent with its other organisational policies and strategies. The organisation has also identified and considered the requirements of relevant stakeholders.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	The organisation has not considered the need to ensure that its asset management strategy is produced with due regard to the lifecycle of the assets, asset types or asset systems that it manages. OR The organisation does not have an asset management strategy.	The need is understood, and the organisation is drafting its asset management strategy to address the lifecycle of its assets, asset types and asset systems.	The long-term asset management strategy takes account of the lifecycle of some, but not all, of its assets, asset types and asset systems.	The asset management strategy takes account of the lifecycle of all of its assets, asset types and asset systems.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	The organisation does not have an identifiable asset management plan(s) covering asset systems and critical assets.	The organisation has asset management plan(s) but they are not aligned with the asset management strategy and objectives and do not take into consideration the full asset life cycle (including asset creation, acquisition, enhancement, utilisation, maintenance decommissioning and disposal).	The organisation is in the process of putting in place comprehensive, documented asset management plan(s) that cover all life cycle activities, clearly aligned to asset management objectives and the asset management strategy.	Asset management plan(s) are established, documented, implemented and maintained for asset systems and critical assets to achieve the asset management strategy and asset management objectives across all life cycle phases.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
27	Asset management plan(s)	How has the organisation communicated its plan(s) to all relevant parties to a level of detail appropriate to the receiver's role in their delivery?	3	The plan is communicated to all relevant employees, stakeholders, and contracted service providers to a level of detail appropriate to their participation or business interests in the delivery of the plan, and there is confirmation that they are being used effectively.		Plans will be ineffective unless they are communicated to all those, including contracted suppliers and those who undertake enabling function(s). The plan(s) need to be communicated in a way that is relevant to those who need to use them.	The management team with overall responsibility for the asset management system. Delivery functions and suppliers.	Distribution lists for plan(s). Documents derived from plan(s) which detail the receivers role in plan delivery. Evidence of communication.
29	Asset management plan(s)	How are designated responsibilities for delivery of asset plan actions documented?	3	The asset management plan documents responsibilities for the delivery actions, and appropriate detail is provided to enable delivery of these actions. Roles and responsibilities of individuals and organisational departments are defined.		The implementation of asset management plan(s) relies on (1) actions being clearly identified, (2) an owner allocated and (3) that owner having sufficient delegated responsibility and authority to carry out the work required. It also requires alignment of actions across the organisation. This question explores how well the plan(s) set out responsibility for delivery of asset plan actions.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers. If appropriate, the performance management team.	The organisation's asset management plan(s). Documentation defining roles and responsibilities of individuals and organisational departments.
31	Asset management plan(s)	What has the organisation done to ensure that appropriate arrangements are made available for the efficient and cost effective implementation of the plan(s)? (Note this is about resources and enabling support)	3	Wellington Electricity's arrangements fully cover all necessary requirements for the efficient and cost effective implementation of the Asset Management Plan. They realistically address the resources required and timescales achievable, as well as any changes required to policies, strategies, standards, processes and information systems.		It is essential that the plan(s) are realistic and can be implemented, which requires appropriate resources to be available and enabling mechanisms in place. This question explores how well this is achieved. The plan(s) not only need to consider the resources directly required and timescales, but also the enabling activities, including for example, training requirements, supply chain capability and procurement timescales.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers. If appropriate, the performance management team. Where appropriate the procurement team and service providers working on the organisation's asset-related activities.	The organisation's asset management plan(s). Documented processes and procedures for the delivery of the asset management plan.
33	Contingency planning	What plan(s) and procedure(s) does the organisation have for identifying and responding to incidents and emergency situations and ensuring continuity of critical asset management activities?	3	Wellington Electricity has a suite of appropriate Emergency Response Procedures and Contingency Plans in place to mitigate and manage the impact of a potential High Impact Low Probability event. These are listed and described in Section 11 of this AMP. The use of critical emergency spares is described in Section 4. These plans get tested in a simulated major event situation such as the Crisis Response Simulation conducted in mid 2017.		Widely used AM practice standards require that an organisation has plan(s) to identify and respond to emergency situations. Emergency plan(s) should outline the actions to be taken to respond to specified emergency situations and ensure continuity of critical asset management activities including the communication to, and involvement of, external agencies. This question assesses if, and how well, these plan(s) triggered, implemented and resolved in the event of an incident. The plan(s) should be appropriate to the level of risk as determined by the organisation's risk assessment methodology. It is also a requirement that relevant personnel are competent and trained.	The manager with responsibility for developing emergency plan(s). The organisation's risk assessment team. People with designated duties within the plan(s) and procedure(s) for dealing with incidents and emergency situations.	The organisation's plan(s) and procedure(s) for dealing with emergencies. The organisation's risk assessments and risk registers.



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
27	Asset management plan(s)	How has the organisation communicated its plan(s) to all relevant parties to a level of detail appropriate to the receiver's role in their delivery?	The organisation does not have plan(s) or their distribution is limited to the authors.	The plan(s) are communicated to some of those responsible for delivery of the plan(s). OR Communicated to those responsible for delivery is either irregular or ad-hoc.	The plan(s) are communicated to most of those responsible for delivery but there are weaknesses in identifying relevant parties resulting in incomplete or inappropriate communication. The organisation recognises improvement is needed as is working towards resolution.	The plan(s) are communicated to all relevant employees, stakeholders and contracted service providers to a level of detail appropriate to their participation or business interests in the delivery of the plan(s) and there is confirmation that they are being used effectively.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
29	Asset management plan(s)	How are designated responsibilities for delivery of asset plan actions documented?	The organisation has not documented responsibilities for delivery of asset plan actions.	Asset management plan(s) inconsistently document responsibilities for delivery of plan actions and activities and/or responsibilities and authorities for implementation inadequate and/or delegation level inadequate to ensure effective delivery and/or contain misalignments with organisational accountability.	Asset management plan(s) consistently document responsibilities for the delivery of actions but responsibility/authority levels are inappropriate/ inadequate, and/or there are misalignments within the organisation.	Asset management plan(s) consistently document responsibilities for the delivery actions and there is adequate detail to enable delivery of actions. Designated responsibility and authority for achievement of asset plan actions is appropriate.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
31	Asset management plan(s)	What has the organisation done to ensure that appropriate arrangements are made available for the efficient and cost effective implementation of the plan(s)? (Note this is about resources and enabling support)	The organisation has not considered the arrangements needed for the effective implementation of plan(s).	The organisation recognises the need to ensure appropriate arrangements are in place for implementation of asset management plan(s) and is in the process of determining an appropriate approach for achieving this.	The organisation has arrangements in place for the implementation of asset management plan(s) but the arrangements are not yet adequately efficient and/or effective. The organisation is working to resolve existing weaknesses.	The organisation's arrangements fully cover all the requirements for the efficient and cost effective implementation of asset management plan(s) and realistically address the resources and timescales required, and any changes needed to functional policies, standards, processes and the asset management information system.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
33	Contingency planning	What plan(s) and procedure(s) does the organisation have for identifying and responding to incidents and emergency situations and ensuring continuity of critical asset management activities?	The organisation has not considered the need to establish plan(s) and procedure(s) to identify and respond to incidents and emergency situations.	The organisation has some ad-hoc arrangements to deal with incidents and emergency situations, but these have been developed on a reactive basis in response to specific events that have occurred in the past.	Most credible incidents and emergency situations are identified. Either appropriate plan(s) and procedure(s) are incomplete for critical activities or they are inadequate. Training/ external alignment may be incomplete.	Appropriate emergency plan(s) and procedure(s) are in place to respond to credible incidents and manage continuity of critical asset management activities consistent with policies and asset management objectives. Training and external agency alignment is in place.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
37	Structure, authority and responsibilities	What has the organisation done to appoint member(s) of its management team to be responsible for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s)?	3	Accountability for asset management responsibility from the CEO, through the GM Asset Management, and through functional Line Managers.		In order to ensure that the organisation's assets and asset systems deliver the requirements of the asset management policy, strategy and objectives responsibilities need to be allocated to appropriate people who have the necessary authority to fulfil their responsibilities. (This question, relates to the organisation's assets eg, para b), s 4.4.1 of PAS 55, making it therefore distinct from the requirement contained in para a), s 4.4.1 of PAS 55).	Top management. People with management responsibility for the delivery of asset management policy, strategy, objectives and plan(s). People working on asset-related activities.	Evidence that managers with responsibility for the delivery of asset management policy, strategy, objectives and plan(s) have been appointed and have assumed their responsibilities. Evidence may include the organisation's documents relating to its asset management system, organisational charts, job descriptions of post-holders, annual targets/objectives and personal development plan(s) of post-holders as appropriate.
40	Structure, authority and responsibilities	What evidence can the organisation's top management provide to demonstrate that sufficient resources are available for asset management?	3	An effective process exists for determining, and having in place, the resources needed for asset management functions. It can be demonstrated that resources are matched to asset management requirements.		Optimal asset management requires top management to ensure sufficient resources are available. In this context the term 'resources' includes manpower, materials, funding and service provider support.	Top management. The management team that has overall responsibility for asset management. Risk management team. The organisation's managers involved in day-to-day supervision of asset-related activities, such as frontline managers, engineers, foremen and chargehands as appropriate.	Evidence demonstrating that asset management plan(s) and/or the process(es) for asset management plan implementation consider the provision of adequate resources in both the short and long term. Resources include funding, materials, equipment, services provided by third parties and personnel (internal and service providers) with appropriate skills competencies and knowledge.
42	Structure, authority and responsibilities	To what degree does the organisation's top management communicate the importance of meeting its asset management requirements?	3	Communication is guided through the the annual AMP disclosures, and through weekly and monthly meetings with management teams and service providers.		Widely used AM practice standards require an organisation to communicate the importance of meeting its asset management requirements such that personnel fully understand, take ownership of, and are fully engaged in the delivery of the asset management requirements (eg, PAS 55 s 4.4.1 g).	Top management. The management team that has overall responsibility for asset management. People involved in the delivery of the asset management requirements.	Evidence of such activities as road shows, written bulletins, workshops, team talks and management walkabouts would assist an organisation to demonstrate it is meeting this requirement of PAS 55.
45	Outsourcing of asset management activities	Where the organisation has outsourced some of its asset management activities, how has it ensured that appropriate controls are in place to ensure the compliant delivery of its organisational strategic plan, and its asset management policy and strategy?	3	Wellington Electricity outsources a number of asset management activities, particularly with Service Delivery responsibilities. These are described in Section 4 of the AMP. Comprehensive contracts and performance measures are in place to ensure efficient and cost-effective delivery of these activities.		Where an organisation chooses to outsource some of its asset management activities, the organisation must ensure that these outsourced process(es) are under appropriate control to ensure that all the requirements of widely used AM standards (eg, PAS 55) are in place, and the asset management policy, strategy objectives and plan(s) are delivered. This includes ensuring capabilities and resources across a time span aligned to life cycle management. The organisation must put arrangements in place to control the outsourced activities, whether it be to external providers or to other in-house departments. This question explores what the organisation does in this regard.	Top management. The management team that has overall responsibility for asset management. The manager(s) responsible for the monitoring and management of the outsourced activities. People involved with the procurement of outsourced activities. The people within the organisations that are performing the outsourced activities. The people impacted by the outsourced activity.	The organisation's arrangements that detail the compliance required of the outsourced activities. For example, this this could form part of a contract or service level agreement between the organisation and the suppliers of its outsourced activities. Evidence that the organisation has demonstrated to itself that it has assurance of compliance of outsourced activities.



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
37	Structure, authority and responsibilities	What has the organisation done to appoint member(s) of its management team to be responsible for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s)?	Top management has not considered the need to appoint a person or persons to ensure that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s).	Top management understands the need to appoint a person or persons to ensure that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s).	Top management has appointed an appropriate people to ensure the assets deliver the requirements of the asset management strategy, objectives and plan(s) but their areas of responsibility are not fully defined and/or they have insufficient delegated authority to fully execute their responsibilities.	The appointed person or persons have full responsibility for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s). They have been given the necessary authority to achieve this.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
40	Structure, authority and responsibilities	What evidence can the organisation's top management provide to demonstrate that sufficient resources are available for asset management?	The organisation's top management has not considered the resources required to deliver asset management.	The organisations top management understands the need for sufficient resources but there are no effective mechanisms in place to ensure this is the case.	A process exists for determining what resources are required for its asset management activities and in most cases these are available but in some instances resources remain insufficient.	An effective process exists for determining the resources needed for asset management and sufficient resources are available. It can be demonstrated that resources are matched to asset management requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
42	Structure, authority and responsibilities	To what degree does the organisation's top management communicate the importance of meeting its asset management requirements?	The organisation's top management has not considered the need to communicate the importance of meeting asset management requirements.	The organisations top management understands the need to communicate the importance of meeting its asset management requirements but does not do so.	Top management communicates the importance of meeting its asset management requirements but only to parts of the organisation.	Top management communicates the importance of meeting its asset management requirements to all relevant parts of the organisation.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
45	Outsourcing of asset management activities	Where the organisation has outsourced some of its asset management activities, how has it ensured that appropriate controls are in place to ensure the compliant delivery of its organisational strategic plan, and its asset management policy and strategy?	The organisation has not considered the need to put controls in place.	The organisation controls its outsourced activities on an ad-hoc basis, with little regard for ensuring for the compliant delivery of the organisational strategic plan and/or its asset management policy and strategy.	Controls systematically considered but currently only provide for the compliant delivery of some, but not all, aspects of the organisational strategic plan and/or its asset management policy and strategy. Gaps exist.	Evidence exists to demonstrate that outsourced activities are appropriately controlled to provide for the compliant delivery of the organisational strategic plan, asset management policy and strategy, and that these controls are integrated into the asset management system	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
48	Training, awareness and competence	How does the organisation develop plan(s) for the human resources required to undertake asset management activities - including the development and delivery of asset management strategy, process(es), objectives and plan(s)?	3	Wellington Electricity can demonstrate that role descriptions are in place for all staff required to conduct asset management functions, and that these roles are filled with appropriately qualified personnel.		There is a need for an organisation to demonstrate that it has considered what resources are required to develop and implement its asset management system. There is also a need for the organisation to demonstrate that it has assessed what development plan(s) are required to provide its human resources with the skills and competencies to develop and implement its asset management systems. The timescales over which the plan(s) are relevant should be commensurate with the planning horizons within the asset management strategy considers e.g. if the asset management strategy considers 5, 10 and 15 year time scales then the human resources development plan(s) should align with these. Resources include both 'in house' and external resources who undertake asset management activities.	Senior management responsible for agreement of plan(s). Managers responsible for developing asset management strategy and plan(s). Managers with responsibility for development and recruitment of staff (including HR functions). Staff responsible for training. Procurement officers. Contracted service providers.	Evidence of analysis of future work load plan(s) in terms of human resources. Document(s) containing analysis of the organisation's own direct resources and contractors resource capability over suitable timescales. Evidence, such as minutes of meetings, that suitable management forums are monitoring human resource development plan(s), training plan(s), personal development plan(s), contract and service level agreements.
49	Training, awareness and competence	How does the organisation identify competency requirements and then plan, provide and record the training necessary to achieve the competencies?	3	Position descriptions are in place for all staff required to conduct asset management functions. Staff undertake training and development where required to ensure they can deliver on the requirements of the AMP. Work competencies are listed for all main contracting activities, and Wellington Electricity monitors and ensures that the Contractors' staff have, and maintain their competencies.		Widely used AM standards require that organisations to undertake a systematic identification of the asset management awareness and competencies required at each level and function within the organisation. Once identified the training required to provide the necessary competencies should be planned for delivery in a timely and systematic way. Any training provided must be recorded and maintained in a suitable format. Where an organisation has contracted service providers in place then it should have a means to demonstrate that this requirement is being met for their employees. (eg, PAS 55 refers to frameworks suitable for identifying competency requirements).	Senior management responsible for agreement of plan(s). Managers responsible for developing asset management strategy and plan(s). Managers with responsibility for development and recruitment of staff (including HR functions). Staff responsible for training. Procurement officers. Contracted service providers.	Evidence of an established and applied competency requirements assessment process and plan(s) in place to deliver the required training. Evidence that the training programme is part of a wider, co-ordinated asset management activities training and competency programme. Evidence that training activities are recorded and that records are readily available (for both direct and contracted service provider staff) e.g. via organisation wide information system or local records database.
50	Training, awareness and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training or experience?	3	Training requirements are identified at the start of the year, and reviewed every six months during staff performance reviews. Work competencies are listed for all main contracting activities, and Wellington Electricity monitors and ensures that the Contractors' staff have, and maintain their competencies.		A critical success factor for the effective development and implementation of an asset management system is the competence of persons undertaking these activities. Organisations should have effective means in place for ensuring the competence of employees to carry out their designated asset management function(s). Where an organisation has contracted service providers undertaking elements of its asset management system then the organisation shall assure itself that the outsourced service provider also has suitable arrangements in place to manage the competencies of its employees. The organisation should ensure that the individual and corporate competencies it requires are in place and actively monitor, develop and maintain an appropriate balance of these competencies.	Managers, supervisors, persons responsible for developing training programmes. Staff responsible for procurement and service agreements. HR staff and those responsible for recruitment.	Evidence of a competency assessment framework that aligns with established frameworks such as the asset management Competencies Requirements Framework (Version 2.0); National Occupational Standards for Management and Leadership; UK Standard for Professional Engineering Competence, Engineering Council, 2005.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
48	Training, awareness and competence	How does the organisation develop plan(s) for the human resources required to undertake asset management activities - including the development and delivery of asset management strategy, process(es), objectives and plan(s)?	The organisation has not recognised the need for assessing human resources requirements to develop and implement its asset management system.	The organisation has recognised the need to assess its human resources requirements and to develop a plan(s). There is limited recognition of the need to align these with the development and implementation of its asset management system.	The organisation has developed a strategic approach to aligning competencies and human resources to the asset management system including the asset management plan but the work is incomplete or has not been consistently implemented.	The organisation can demonstrate that plan(s) are in place and effective in matching competencies and capabilities to the asset management system including the plan for both internal and contracted activities. Plans are reviewed integral to asset management system process(es).	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
49	Training, awareness and competence	How does the organisation identify competency requirements and then plan, provide and record the training necessary to achieve the competencies?	The organisation does not have any means in place to identify competency requirements.	The organisation has recognised the need to identify competency requirements and then plan, provide and record the training necessary to achieve the competencies.	The organisation is in the process of identifying competency requirements aligned to the asset management plan(s) and then plan, provide and record appropriate training. It is incomplete or inconsistently applied.	Competency requirements are in place and aligned with asset management plan(s). Plans are in place and effective in providing the training necessary to achieve the competencies. A structured means of recording the competencies achieved is in place.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
50	Training, awareness and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training or experience?	The organization has not recognised the need to assess the competence of person(s) undertaking asset management related activities.	Competency of staff undertaking asset management related activities is not managed or assessed in a structured way, other than formal requirements for legal compliance and safety management.	The organization is in the process of putting in place a means for assessing the competence of person(s) involved in asset management activities including contractors. There are gaps and inconsistencies.	Competency requirements are identified and assessed for all persons carrying out asset management related activities - internal and contracted. Requirements are reviewed and staff reassessed at appropriate intervals aligned to asset management requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
53	Communication, participation and consultation	How does the organisation ensure that pertinent asset management information is effectively communicated to and from employees and other stakeholders, including contracted service providers?	3	In addition to the annual AMP disclosure, regular contract meetings are held between Safety, Asset Management and Service Delivery Managers and the respective service providers. In addition specific asset management is communicated to employees and contractors through safety alerts, technical alerts, network instructions, and at technical forums.		Widely used AM practice standards require that pertinent asset management information is effectively communicated to and from employees and other stakeholders including contracted service providers. Pertinent information refers to information required in order to effectively and efficiently comply with and deliver asset management strategy, plan(s) and objectives. This will include for example the communication of the asset management policy, asset performance information, and planning information as appropriate to contractors.	Top management and senior management representative(s), employee's representative(s), employee's trade union representative(s); contracted service provider management and employee representative(s); representative(s) from the organisation's Health, Safety and Environmental team. Key stakeholder representative(s).	Asset management policy statement prominently displayed on notice boards, intranet and internet; use of organisation's website for displaying asset performance data; evidence of formal briefings to employees, stakeholders and contracted service providers; evidence of inclusion of asset management issues in team meetings and contracted service provider contract meetings; newsletters, etc.
59	Asset Management System documentation	What documentation has the organisation established to describe the main elements of its asset management system and interactions between them?	3	Asset Management documentation and control is in place, and is described in Section 4 of the AMP.		Widely used AM practice standards require an organisation maintain up to date documentation that ensures that its asset management systems (ie, the systems the organisation has in place to meet the standards) can be understood, communicated and operated. (eg, s 4.5 of PAS 55 requires the maintenance of up to date documentation of the asset management system requirements specified throughout s 4 of PAS 55).	The management team that has overall responsibility for asset management. Managers engaged in asset management activities.	The documented information describing the main elements of the asset management system (process(es)) and their interaction.
62	Information management	What has the organisation done to determine what its asset management information system(s) should contain in order to support its asset management system?	3	Asset Management information systems are in place, and these are listed and described in Section 10 of this AMP. They include SCADA, GIS and SAP. Support for these systems is provided by CHED Services.		Effective asset management requires appropriate information to be available. Widely used AM standards therefore require the organisation to identify the asset management information it requires in order to support its asset management system. Some of the information required may be held by suppliers. The maintenance and development of asset management information systems is a poorly understood specialist activity that is akin to IT management but different from IT management. This group of questions provides some indications as to whether the capability is available and applied. Note: To be effective, an asset information management system requires the mobilisation of technology, people and process(es) that create, secure, make available and destroy the information required to support the asset management system.	The organisation's strategic planning team. The management team that has overall responsibility for asset management. Information management team. Operations, maintenance and engineering managers	Details of the process the organisation has employed to determine what its asset information system should contain in order to support its asset management system. Evidence that this has been effectively implemented.
63	Information management	How does the organisation maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?	3	Controls are in place in the form of data quality standards to manage the quality and accuracy of the data entered into the asset management information systems.		The response to the questions is progressive. A higher scale cannot be awarded without achieving the requirements of the lower scale. This question explores how the organisation ensures that information management meets widely used AM practice requirements (eg, s 4.4.6 (a), (c) and (d) of PAS 55).	The management team that has overall responsibility for asset management. Users of the organisational information systems.	The asset management information system, together with the policies, procedure(s), improvement initiatives and audits regarding information controls.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
53	Communication, participation and consultation	How does the organisation ensure that pertinent asset management information is effectively communicated to and from employees and other stakeholders, including contracted service providers?	The organisation has not recognised the need to formally communicate any asset management information.	There is evidence that the pertinent asset management information to be shared along with those to share it with is being determined.	The organisation has determined pertinent information and relevant parties. Some effective two way communication is in place but as yet not all relevant parties are clear on their roles and responsibilities with respect to asset management information.	Two way communication is in place between all relevant parties, ensuring that information is effectively communicated to match the requirements of asset management strategy, plan(s) and process(es). Pertinent asset information requirements are regularly reviewed.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
59	Asset Management System documentation	What documentation has the organisation established to describe the main elements of its asset management system and interactions between them?	The organisation has not established documentation that describes the main elements of the asset management system.	The organisation is aware of the need to put documentation in place and is in the process of determining how to document the main elements of its asset management system.	The organisation is in the process of documenting its asset management system and has documentation in place that describes some, but not all, of the main elements of its asset management system and their interaction.	The organisation has established documentation that comprehensively describes all the main elements of its asset management system and the interactions between them. The documentation is kept up to date.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
62	Information management	What has the organisation done to determine what its asset management information system(s) should contain in order to support its asset management system?	The organisation has not considered what asset management information is required.	The organisation is aware of the need to determine in a structured manner what its asset information system should contain in order to support its asset management system and is in the process of deciding how to do this.	The organisation has developed a structured process to determine what its asset information system should contain in order to support its asset management system and has commenced implementation of the process.	The organisation has determined what its asset information system should contain in order to support its asset management system. The requirements relate to the whole life cycle and cover information originating from both internal and external sources.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
63	Information management	How does the organisation maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?	There are no formal controls in place or controls are extremely limited in scope and/or effectiveness.	The organisation is aware of the need for effective controls and is in the process of developing an appropriate control process(es).	The organisation has developed a controls that will ensure the data held is of the requisite quality and accuracy and is consistent and is in the process of implementing them.	The organisation has effective controls in place that ensure the data held is of the requisite quality and accuracy and is consistent. The controls are regularly reviewed and improved where necessary.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
64	Information management	How has the organisation's ensured its asset management information system is relevant to its needs?	3	Asset Management requirements were fully reviewed during development of the business case to implement SAP-PM, and to upgrade GIS ensuring that they meet Asset Management needs. The systems were again reviewed by Strata Consultants in 2015, and are reviewed annually by CHED Services.		Widely used AM standards need not be prescriptive about the form of the asset management information system, but simply require that the asset management information system is appropriate to the organisations needs, can be effectively used and can supply information which is consistent and of the requisite quality and accuracy.	The organisation's strategic planning team. The management team that has overall responsibility for asset management. Information management team. Users of the organisational information systems.	The documented process the organisation employs to ensure its asset management information system aligns with its asset management requirements. Minutes of information systems review meetings involving users.
69	Risk management process(es)	How has the organisation documented process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle?	3	In January 2016, Wellington Electricity aligned its risk approach with that of CKI by adopting the Enterprise Risk Management (ERM) – Integrated Framework Risk Management Principles and Guidelines Standard. This provides a structured and robust framework to managing risk, which is applied to all business activities, including recently published Fleet Strategies.		Risk management is an important foundation for proactive asset management. Its overall purpose is to understand the cause, effect and likelihood of adverse events occurring, to optimally manage such risks to an acceptable level, and to provide an audit trail for the management of risks. Widely used standards require the organisation to have process(es) and/or procedure(s) in place that set out how the organisation identifies and assesses asset and asset management related risks. The risks have to be considered across the four phases of the asset lifecycle (eg, para 4.3.3 of PAS 55).	The top management team in conjunction with the organisation's senior risk management representatives. There may also be input from the organisation's Safety, Health and Environment team. Staff who carry out risk identification and assessment.	The organisation's risk management framework and/or evidence of specific process(es) and/ or procedure(s) that deal with risk control mechanisms. Evidence that the process(es) and/or procedure(s) are implemented across the business and maintained. Evidence of agendas and minutes from risk management meetings. Evidence of feedback in to process(es) and/or procedure(s) as a result of incident investigation(s). Risk registers and assessments.
79	Use and maintenance of asset risk information	How does the organisation ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?	3	Outputs from risk assessments are fed back into standards, procedures and training through the actions resulting from various meetings and other communications.		Widely used AM standards require that the output from risk assessments are considered and that adequate resource (including staff) and training is identified to match the requirements. It is a further requirement that the effects of the control measures are considered, as there may be implications in resources and training required to achieve other objectives.	Staff responsible for risk assessment and those responsible for developing and approving resource and training plan(s). There may also be input from the organisation's Safety, Health and Environment team.	The organisations risk management framework. The organisation's resourcing plan(s) and training and competency plan(s). The organisation should be able to demonstrate appropriate linkages between the content of resource plan(s) and training and competency plan(s) to the risk assessments and risk control measures that have been developed.
82	Legal and other requirements	What procedure does the organisation have to identify and provide access to its legal, regulatory, statutory and other asset management requirements, and how is requirements incorporated into the asset management system?	3	Wellington Electricity has staff in its office that are responsible for Legal, Regulatory, Statutory and other asset management requirements. These staff are supported by the Regulatory group in a sister company in Melbourne, Powercor and Citipower		In order for an organisation to comply with its legal, regulatory, statutory and other asset management requirements, the organisation first needs to ensure that it knows what they are (eg, PAS 55 specifies this in s 4.4.8). It is necessary to have systematic and auditable mechanisms in place to identify new and changing requirements. Widely used AM standards also require that requirements are incorporated into the asset management system (e.g. procedure(s) and process(es))	Top management. The organisations regulatory team. The organisation's legal team or advisors. The management team with overall responsibility for the asset management system. The organisation's health and safety team or advisors. The organisation's policy making team.	The organisational processes and procedures for ensuring information of this type is identified, made accessible to those requiring the information and is incorporated into asset management strategy and objectives



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
64	Information management	How has the organisation's ensured its asset management information system is relevant to its needs?	The organisation has not considered the need to determine the relevance of its management information system. At present there are major gaps between what the information system provides and the organisations needs.	The organisation understands the need to ensure its asset management information system is relevant to its needs and is determining an appropriate means by which it will achieve this. At present there are significant gaps between what the information system provides and the organisations needs.	The organisation has developed and is implementing a process to ensure its asset management information system is relevant to its needs. Gaps between what the information system provides and the organisations needs have been identified and action is being taken to close them.	The organisation's asset management information system aligns with its asset management requirements. Users can confirm that it is relevant to their needs.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
69	Risk management process(es)	How has the organisation documented process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle?	The organisation has not considered the need to document process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle.	The organisation is aware of the need to document the management of asset related risk across the asset lifecycle. The organisation has plan(s) to formally document all relevant process(es) and procedure(s) or has already commenced this activity.	The organisation is in the process of documenting the identification and assessment of asset related risk across the asset lifecycle but it is incomplete or there are inconsistencies between approaches and a lack of integration.	Identification and assessment of asset related risk across the asset lifecycle is fully documented. The organisation can demonstrate that appropriate documented mechanisms are integrated across life cycle phases and are being consistently applied.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
79	Use and maintenance of asset risk information	How does the organisation ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?	The organisation has not considered the need to conduct risk assessments.	The organisation is aware of the need to consider the results of risk assessments and effects of risk control measures to provide input into reviews of resources, training and competency needs. Current input is typically ad-hoc and reactive.	The organisation is in the process ensuring that outputs of risk assessment are included in developing requirements for resources and training. The implementation is incomplete and there are gaps and inconsistencies.	Outputs from risk assessments are consistently and systematically used as inputs to develop resources, training and competency requirements. Examples and evidence is available.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
82	Legal and other requirements	What procedure does the organisation have to identify and provide access to its legal, regulatory, statutory and other asset management requirements, and how is requirements incorporated into the asset management system?	The organisation has not considered the need to identify its legal, regulatory, statutory and other asset management requirements.	The organisation identifies some its legal, regulatory, statutory and other asset management requirements, but this is done in an ad-hoc manner in the absence of a procedure.	The organisation has procedure(s) to identify its legal, regulatory, statutory and other asset management requirements, but the information is not kept up to date, inadequate or inconsistently managed.	Evidence exists to demonstrate that the organisation's legal, regulatory, statutory and other asset management requirements are identified and kept up to date. Systematic mechanisms for identifying relevant legal and statutory requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
88	Life Cycle Activities	How does the organisation establish implement and maintain process(es) for the implementation of its asset management plan(s) and control of activities across the creation, acquisition or enhancement of assets. This includes design, modification, procurement, construction and commissioning activities?	3	Consultants are often used to assist during the design stage. Scope of work is clearly defined and controlled through a Short Form Agreement. Procurement is controlled through an approved materials standard. Construction and commissioning activities are outsourced, and these are carefully controlled through contracts with the service providers.		Life cycle activities are about the implementation of asset management plan(s) i.e. they are the "doing" phase. They need to be done effectively and well in order for asset management to have any practical meaning. As a consequence, widely used standards (eg, PAS 55 s 4.5.1) require organisations to have in place appropriate process(es) and procedure(s) for the implementation of asset management plan(s) and control of lifecycle activities. This question explores those aspects relevant to asset creation.	Asset managers, design staff, construction staff and project managers from other impacted areas of the business, e.g. Procurement	Documented process(es) and procedure(s) which are relevant to demonstrating the effective management and control of life cycle activities during asset creation, acquisition, enhancement including design, modification, procurement, construction and commissioning.
91	Life Cycle Activities	How does the organisation ensure that process(es) and/or procedure(s) for the implementation of asset management plan(s) and control of activities during maintenance (and inspection) of assets are sufficient to ensure activities are carried out under specified conditions, are consistent with asset management strategy and control cost, risk and performance?	3	There is a general inspection plan in place with remedial actions derived from the prioritisation of critical defects. Ongoing training is carried out to standardise the level of consistency across the inspection and condition assessment process, and how the results are then optimised within the maintenance planning function. These plans are reviewed and optimised on an annual basis.		Having documented process(es) which ensure the asset management plan(s) are implemented in accordance with any specified conditions, in a manner consistent with the asset management policy, strategy and objectives and in such a way that cost, risk and asset system performance are appropriately controlled is critical. They are an essential part of turning intention into action (eg, as required by PAS 55 s 4.5.1).	Asset managers, operations managers, maintenance managers and project managers from other impacted areas of the business	Documented procedure for review. Documented procedure for audit of process delivery. Records of previous audits, improvement actions and documented confirmation that actions have been carried out.
95	Performance and condition monitoring	How does the organisation measure the performance and condition of its assets?	3	Wellington Electricity annually rates all assets against Asset Health indicators that is based on the AHl's guideline published by the EEA. This is used to measure the performance and condition of its assets. This is informed by the results of the inspection and maintenance programme conducted by its maintenance service provider at frequencies and according to procedures detailed in maintenance standards. The AHl analysis in turn assists with the development and update of the Fleet Strategies and replacement programmes.		Widely used AM standards require that organisations establish implement and maintain procedure(s) to monitor and measure the performance and/or condition of assets and asset systems. They further set out requirements in some detail for reactive and proactive monitoring, and leading/lagging performance indicators together with the monitoring or results to provide input to corrective actions and continual improvement. There is an expectation that performance and condition monitoring will provide input to improving asset management strategy, objectives and plan(s).	A broad cross-section of the people involved in the organisation's asset-related activities from data input to decision-makers, i.e. an end-to-end assessment. This should include contactors and other relevant third parties as appropriate.	Functional policy and/or strategy documents for performance or condition monitoring and measurement. The organisation's performance monitoring frameworks, balanced scorecards etc. Evidence of the reviews of any appropriate performance indicators and the action lists resulting from these reviews. Reports and trend analysis using performance and condition information. Evidence of the use of performance and condition information shaping improvements and supporting asset management strategy, objectives and plan(s).
99	Investigation of asset-related failures, incidents and nonconformities	How does the organisation ensure responsibility and the authority for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformance is clear, unambiguous, understood and communicated?	3	Wellington Electricity has procedures which clearly outline the roles and responsibilities for managing major incidents and emergency situations. The Asset Failure Investigation standard describes the process and responsibilities for investigating asset-related failures.		Widely used AM standards require that the organisation establishes implements and maintains process(es) for the handling and investigation of failures incidents and non-conformities for assets and sets down a number of expectations. Specifically this question examines the requirement to define clearly responsibilities and authorities for these activities, and communicate these unambiguously to relevant people including external stakeholders if appropriate.	The organisation's safety and environment management team. The team with overall responsibility for the management of the assets. People who have appointed roles within the asset-related investigation procedure, from those who carry out the investigations to senior management who review the recommendations. Operational controllers responsible for managing the asset base under fault conditions and maintaining services to consumers. Contractors and other third parties as appropriate.	Process(es) and procedure(s) for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformance. Documentation of assigned responsibilities and authority to employees. Job Descriptions, Audit reports. Common communication systems i.e. all Job Descriptions on Internet etc.



Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
88	Life Cycle Activities	How does the organisation establish implement and maintain process(es) for the implementation of its asset management plan(s) and control of activities across the creation, acquisition or enhancement of assets. This includes design, modification, procurement, construction and commissioning activities?	The organisation does not have process(es) in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning.	The organisation is aware of the need to have process(es) and procedure(s) in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning but currently do not have these in place (note: procedure(s) may exist but they are inconsistent/incomplete).	The organisation is in the process of putting in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning. Gaps and inconsistencies are being addressed.	Effective process(es) and procedure(s) are in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
91	Life Cycle Activities	How does the organisation ensure that process(es) and/or procedure(s) for the implementation of asset management plan(s) and control of activities during maintenance (and inspection) of assets are sufficient to ensure activities are carried out under specified conditions, are consistent with asset management strategy and control cost, risk and performance?	The organisation does not have process(es)/procedure(s) in place to control or manage the implementation of asset management plan(s) during this life cycle phase.	The organisation is aware of the need to have process(es) and procedure(s) in place to manage and control the implementation of asset management plan(s) during this life cycle phase but currently do not have these in place and/or there is no mechanism for confirming they are effective and where needed modifying them.	The organisation is in the process of putting in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during this life cycle phase. They include a process for confirming the process(es)/procedure(s) are effective and if necessary carrying out modifications.	The organisation has in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during this life cycle phase. They include a process, which is itself regularly reviewed to ensure it is effective, for confirming the process(es)/ procedure(s) are effective and if necessary carrying out modifications.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
95	Performance and condition monitoring	How does the organisation measure the performance and condition of its assets?	The organisation has not considered how to monitor the performance and condition of its assets.	The organisation recognises the need for monitoring asset performance but has not developed a coherent approach. Measures are incomplete, predominantly reactive and lagging. There is no linkage to asset management objectives.	The organisation is developing coherent asset performance monitoring linked to asset management objectives. Reactive and proactive measures are in place. Use is being made of leading indicators and analysis. Gaps and inconsistencies remain.	Consistent asset performance monitoring linked to asset management objectives is in place and universally used including reactive and proactive measures. Data quality management and review process are appropriate. Evidence of leading indicators and analysis.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
99	Investigation of asset-related failures, incidents and nonconformities	How does the organisation ensure responsibility and the authority for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformance is clear, unambiguous, understood and communicated?	The organisation has not considered the need to define the appropriate responsibilities and the authorities.	The organisation understands the requirements and is in the process of determining how to define them.	The organisation are in the process of defining the responsibilities and authorities with evidence. Alternatively there are some gaps or inconsistencies in the identified responsibilities/authorities.	The organisation have defined the appropriate responsibilities and authorities and evidence is available to show that these are applied across the business and kept up to date.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
105	Audit	What has the organisation done to establish procedure(s) for the audit of its asset management system (process(es))?	2	CKI has internal auditors in CHED Services in Melbourne that select usually two areas to do comprehensive audits on each year. Not all areas of Asset Management have been audited.		This question seeks to explore what the organisation has done to comply with the standard practice AM audit requirements (eg, the associated requirements of PAS 55 s 4.6.4 and its linkages to s 4.7).	The management team responsible for its asset management procedure(s). The team with overall responsibility for the management of the assets. Audit teams, together with key staff responsible for asset management. For example, Asset Management Director, Engineering Director. People with responsibility for carrying out risk assessments	The organisation's asset-related audit procedure(s). The organisation's methodology(s) by which it determined the scope and frequency of the audits and the criteria by which it identified the appropriate audit personnel. Audit schedules, reports etc. Evidence of the procedure(s) by which the audit results are presented, together with any subsequent communications. The risk assessment schedule or risk registers.
109	Corrective & Preventative action	How does the organisation instigate appropriate corrective and/or preventive actions to eliminate or prevent the causes of identified poor performance and non conformance?	3	Incident and root cause analysis investigations and corrective actions involve both WE Wellington Electricity and its service providers, and are logged, reviewed and discussed at weekly & bi-weekly meetings. A programme called 1Fics is used to track and keep information relating to all incidents and corrective actions until they have been completed and the incident closed out.		Having investigated asset related failures, incidents and non-conformances, and taken action to mitigate their consequences, an organisation is required to implement preventative and corrective actions to address root causes. Incident and failure investigations are only useful if appropriate actions are taken as a result to assess changes to a businesses risk profile and ensure that appropriate arrangements are in place should a recurrence of the incident happen. Widely used AM standards also require that necessary changes arising from preventive or corrective action are made to the asset management system.	The management team responsible for its asset management procedure(s). The team with overall responsibility for the management of the assets. Audit and incident investigation teams. Staff responsible for planning and managing corrective and preventive actions.	Analysis records, meeting notes and minutes, modification records. Asset management plan(s), investigation reports, audit reports, improvement programmes and projects. Recorded changes to asset management procedure(s) and process(es). Condition and performance reviews. Maintenance reviews
113	Continual Improvement	How does the organisation achieve continual improvement in the optimal combination of costs, asset related risks and the performance and condition of assets and asset systems across the whole life cycle?	2	The Asset Fleet Strategies are developed to analyse the performance and condition of assets across the whole life cycle, as well as maintenance and replacement costs, and any associated asset-related risks. Once these Asset Fleet Strategies have been developed (five have been completed thus far), they will be periodically reviewed and update to inform future AMP's. Three fleet strategies require a review.		Widely used AM standards have requirements to establish, implement and maintain process(es)/procedure(s) for identifying, assessing, prioritising and implementing actions to achieve continual improvement. Specifically there is a requirement to demonstrate continual improvement in optimisation of cost risk and performance/condition of assets across the life cycle. This question explores an organisation's capabilities in this area—looking for systematic improvement mechanisms rather than reviews and audit (which are separately examined).	The top management of the organisation. The manager/team responsible for managing the organisation's asset management system, including its continual improvement. Managers responsible for policy development and implementation.	Records showing systematic exploration of improvement. Evidence of new techniques being explored and implemented. Changes in procedure(s) and process(es) reflecting improved use of optimisation tools/techniques and available information. Evidence of working parties and research.
115	Continual Improvement	How does the organisation seek and acquire knowledge about new asset management related technology and practices, and evaluate their potential benefit to the organisation?	3	Being part of a wider international group, WELL places a high level of importance on learnings that can be made from its sister companies within the group, and from within the industry in New Zealand. There is a 6 weekly colloquium held between sister companies to discuss the latest in AM practices from across the world.		One important aspect of continual improvement is where an organisation looks beyond its existing boundaries and knowledge base to look at what 'new things are on the market'. These new things can include equipment, process(es), tools, etc. An organisation which does this (eg, by the PAS 55 s 4.6 standards) will be able to demonstrate that it continually seeks to expand its knowledge of all things affecting its asset management approach and capabilities. The organisation will be able to demonstrate that it identifies any such opportunities to improve, evaluates them for suitability to its own organisation and implements them as appropriate. This question explores an organisation's approach to this activity.	The top management of the organisation. The manager/team responsible for managing the organisation's asset management system, including its continual improvement. People who monitor the various items that require monitoring for 'change'. People that implement changes to the organisation's policy, strategy, etc. People within an organisation with responsibility for investigating, evaluating, recommending and implementing new tools and techniques, etc.	Research and development projects and records, benchmarking and participation knowledge exchange professional forums. Evidence of correspondence relating to knowledge acquisition. Examples of change implementation and evaluation of new tools, and techniques linked to asset management strategy and objectives.

Company Name	Wellington Electricity
AMP Planning Period	1 April 2018 - 31 March 2028
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
105	Audit	What has the organisation done to establish procedure(s) for the audit of its asset management system (process(es))?	The organisation has not recognised the need to establish procedure(s) for the audit of its asset management system.	The organisation understands the need for audit procedure(s) and is determining the appropriate scope, frequency and methodology(s).	The organisation is establishing its audit procedure(s) but they do not yet cover all the appropriate asset-related activities.	The organisation can demonstrate that its audit procedure(s) cover all the appropriate asset-related activities and the associated reporting of audit results. Audits are to an appropriate level of detail and consistently managed.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
109	Corrective & Preventative action	How does the organisation instigate appropriate corrective and/or preventive actions to eliminate or prevent the causes of identified poor performance and non conformance?	The organisation does not recognise the need to have systematic approaches to instigating corrective or preventive actions.	The organisation recognises the need to have systematic approaches to instigating corrective or preventive actions. There is ad-hoc implementation for corrective actions to address failures of assets but not the asset management system.	The need is recognized for systematic instigation of preventive and corrective actions to address root causes of non compliance or incidents identified by investigations, compliance evaluation or audit. It is only partially or inconsistently in place.	Mechanisms are consistently in place and effective for the systematic instigation of preventive and corrective actions to address root causes of non compliance or incidents identified by investigations, compliance evaluation or audit.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
113	Continual Improvement	How does the organisation achieve continual improvement in the optimal combination of costs, asset related risks and the performance and condition of assets and asset systems across the whole life cycle?	The organisation does not consider continual improvement of these factors to be a requirement, or has not considered the issue.	A Continual Improvement ethos is recognised as beneficial, however it has just been started, and or covers partially the asset drivers.	Continuous improvement process(es) are set out and include consideration of cost risk, performance and condition for assets managed across the whole life cycle but it is not yet being systematically applied.	There is evidence to show that continuous improvement process(es) which include consideration of cost risk, performance and condition for assets managed across the whole life cycle are being systematically applied.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
115	Continual Improvement	How does the organisation seek and acquire knowledge about new asset management related technology and practices, and evaluate their potential benefit to the organisation?	The organisation makes no attempt to seek knowledge about new asset management related technology or practices.	The organisation is inward looking, however it recognises that asset management is not sector specific and other sectors have developed good practice and new ideas that could apply. Ad-hoc approach.	The organisation has initiated asset management communication within sector to share and, or identify 'new' to sector asset management practices and seeks to evaluate them.	The organisation actively engages internally and externally with other asset management practitioners, professional bodies and relevant conferences. Actively investigates and evaluates new practices and evolves its asset management activities using appropriate developments.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Schedule 14a: Mandatory Explanatory Notes on Forecast Information

(In this Schedule, clause references are to the Electricity Distribution Information Disclosure Determination 2012)

This Schedule provides for EDBs to provide explanatory notes to reports prepared in accordance with clause 2.6.5.

This Schedule is mandatory—EDBs must provide the explanatory comment specified below, in accordance with clause 2.7.2. This information is not part of the audited disclosure information, and so is not subject to the assurance requirements specified in section 2.8.

Commentary on difference between nominal and constant price capital expenditure forecasts (Schedule 11a)

In the box below, comment on the difference between nominal and constant price capital expenditure for the disclosure year, as disclosed in Schedule 11a.

Box 1: Commentary on difference between nominal and constant price capital expenditure forecasts

Network and Non-network capital expenditure:

The difference represents inflation and is 2.0% per annum across the planning period

The rates are based on the midpoint of the RBNZ's target inflation range.

Commentary on difference between nominal and constant price operational expenditure forecasts (Schedule 11b)

In the box below, comment on the difference between nominal and constant price operational expenditure for the disclosure year, as disclosed in Schedule 11b.

Box 2: Commentary on difference between nominal and constant price operational expenditure forecasts

The difference represents inflation and is 2.0% per annum across the planning period

The rates are based on the midpoint of the RBNZ's target inflation range.

Appendix D Summary of AMP Coverage of Information Disclosure Requirements

Information Disclosure Requirements 2012 clause	AMP section
3.1 A summary that provides a brief overview of the contents and highlights information that the EDB considers significant	1
3.2 Details of the background and objectives of the EDB's asset management and planning processes	3,5
3.3 A purpose statement which-	
3.3.1 makes clear the purpose and status of the AMP in the EDB's asset management practices. The purpose statement must also include a statement of the objectives of the asset management and planning processes	2.1
3.3.2 states the corporate mission or vision as it relates to asset management	3.1
3.3.3 identifies the documented plans produced as outputs of the annual business planning process adopted by the EDB	5.2
3.3.4 states how the different documented plans relate to one another, with particular reference to any plans specifically dealing with asset management	5.2
3.3.5 includes a description of the interaction between the objectives of the AMP and other corporate goals, business planning processes, and plans	3.1 & 5.2
3.4 Details of the AMP planning period , which must cover at least a projected period of 10 years commencing with the disclosure year following the date on which the AMP is disclosed	1.1
3.5 The date that it was approved by the directors	1.1
3.6 A description of stakeholder interests (owners, consumers etc.) which identifies important stakeholders and indicates-	
3.6.1 how the interests of stakeholders are identified	3.6.1
3.6.2 what these interests are	3.6.1
3.6.3 how these interests are accommodated in asset management practices	3.6.1
3.6.4 how conflicting interests are managed	3.6.2

Information Disclosure Requirements 2012 clause	AMP section
3.7 A description of the accountabilities and responsibilities for asset management on at least 3 levels, including- 3.7.1 governance—a description of the extent of director approval required for key asset management decisions and the extent to which asset management outcomes are regularly reported to directors 3.7.2 executive—an indication of how the in-house asset management and planning organisation is structured 3.7.3 field operations—an overview of how field operations are managed, including a description of the extent to which field work is undertaken in-house and the areas where outsourced contractors are used	3.2.2 3.2.4 & 3.2.5 3.2.5 & 4.3.1
3.8 All significant assumptions: 3.8.1 quantified where possible 3.8.2 clearly identified in a manner that makes their significance understandable to interested persons, including 3.8.3 a description of changes proposed where the information is not based on the EDB's existing business 3.8.4 the sources of uncertainty and the potential effect of the uncertainty on the prospective information 3.8.5 the price inflator assumptions used to prepare the financial information disclosed in nominal New Zealand dollars in the Report on Forecast Capital Expenditure set out in Schedule 11a and the Report on Forecast Operational Expenditure set out in Schedule 11b.	Appendix A Appendix A Appendix A Appendix A Schedule 14a
3.9 A description of the factors that may lead to a material difference between the prospective information disclosed and the corresponding actual information recorded in future disclosures	1.3 - 1.5 & 1.7.1 & Appendix A
3.10 An overview of asset management strategy and delivery	4.1 & 4.3
3.11 An overview of systems and information management data	10.1 & 10.4
3.12 A statement covering any limitations in the availability or completeness of asset management data and disclose any initiatives intended to improve the quality of this data	10.3
3.13 A description of the processes used within the EDB for- 3.13.1 managing routine asset inspections and network maintenance 3.13.2 planning and implementing network development projects	7.4 & 7.5 8

Information Disclosure Requirements 2012 clause	AMP section
3.13.3 measuring network performance.	6.1
3.14 An overview of asset management documentation, controls and review processes	4.4
3.15 An overview of communication and participation processes	3.6
3.16 The AMP must present all financial values in constant price New Zealand dollars except where specified otherwise;	Appendix A
3.17 The AMP must be structured and presented in a way that the EDB considers will support the purposes of AMP disclosure set out in clause 2.6.2 of the determination.	6.1 & 4.2.& 7 & 8
<p>4. The AMP must provide details of the assets covered, including-</p> <p>4.1 a high-level description of the service areas covered by the EDB and the degree to which these are interlinked, including-</p> <p>4.1.1 the region(s) covered</p> <p>4.1.2 identification of large consumers that have a significant impact on network operations or asset management priorities</p> <p>4.1.3 description of the load characteristics for different parts of the network 4.1.4 peak demand and total energy delivered in the previous year, broken down by sub-network, if any.</p>	<p>3.3</p> <p>3.4.</p> <p>3.5</p> <p>3.5 & 8.2</p>
<p>4.2 a description of the network configuration, including-</p> <p>4.2.1 identifying bulk electricity supply points and any distributed generation with a capacity greater than 1 MW. State the existing firm supply capacity and current peak load of each bulk electricity supply point;</p> <p>4.2.2 a description of the subtransmission system fed from the bulk electricity supply points, including the capacity of zone substations and the voltage(s) of the subtransmission network(s). The AMP must identify the supply security provided at individual zone substations, by describing the extent to which each has n-x subtransmission security or by providing alternative security class ratings;</p> <p>4.2.3 a description of the distribution system, including the extent to which it is underground;</p> <p>4.2.4 a brief description of the network's distribution substation arrangements;</p> <p>4.2.5 a description of the low voltage network including the extent to which it is underground; and</p> <p>4.2.6 an overview of secondary assets such as protection relays, ripple injection systems, SCADA and telecommunications systems.</p>	<p>3.4 & 8.1.9</p> <p>3.4 & 8.4 – 8.6</p> <p>3.3 & 3.4 & 7.1</p> <p>3.4 & 7.5.2</p> <p>3.4,7.5.3,7.5.4</p> <p>7.5.8 - 7.5.9</p>
4.3 If sub-networks exist, the network configuration information referred to in subclause 4.2 above must be disclosed for each sub-network .	8

Information Disclosure Requirements 2012 clause	AMP section
<p>Network assets by category</p> <p>4.4 The AMP must describe the network assets by providing the following information for each asset category-</p> <p>4.4.1 voltage levels;</p> <p>4.4.2 description and quantity of assets;</p> <p>4.4.3 age profiles; and</p> <p>4.4.4 a discussion of the condition of the assets, further broken down into more detailed categories as considered appropriate. Systemic issues leading to the premature replacement of assets or parts of assets should be discussed.</p>	<p>3.4; 7.1&App F</p> <p>7.1</p> <p>7.5</p> <p>7.5</p>
<p>4.5 The asset categories discussed in subclause 4.4 above should include at least the following-</p> <p>4.5.1 Sub transmission</p> <p>4.5.2 Zone substations</p> <p>4.5.3 Distribution and LV lines</p> <p>4.5.4 Distribution and LV cables</p> <p>4.5.5 Distribution substations and transformers</p> <p>4.5.6 Distribution switchgear</p> <p>4.5.7 Other system fixed assets</p> <p>4.5.8 Other assets;</p> <p>4.5.9 assets owned by the EDB but installed at bulk electricity supply points owned by others;</p> <p>4.5.10 EDB owned mobile substations and generators whose function is to increase supply reliability or reduce peak demand; and 4.5.11 other generation plant owned by the EDB.</p>	<p>7.5.1</p> <p>7.5.2</p> <p>7.5.3</p> <p>7.5.4</p> <p>7.5.5 & 7.5.6</p> <p>7.5.6</p> <p>7.5.7</p> <p>7.5.8</p> <p>7.5.9</p> <p>N/A</p>
<p><u>Service Levels</u></p> <p>5. The AMP must clearly identify or define a set of performance indicators for which annual performance targets have been defined. The annual performance targets must be consistent with business strategies and asset management objectives and be provided for each year of the AMP planning period. The targets should reflect what is practically achievable given the current network configuration, condition and planned expenditure levels. The targets should be disclosed for each year of the AMP planning period.</p>	<p>5</p>
<p>6. Performance indicators for which targets have been defined in clause 5 above must include SAIDI and SAIFI values for the next 5 disclosure years.</p>	<p>6.1.1</p>

Information Disclosure Requirements 2012 clause	AMP section
7. Performance indicators for which targets have been defined in clause 5 above should also include- 7.1 Consumer oriented indicators that preferably differentiate between different consumer types; 7.2 Indicators of asset performance, asset efficiency and effectiveness, and service efficiency, such as technical and financial performance indicators related to the efficiency of asset utilisation and operation.	3.6 & 5.3.1 5.2 & 7.2 – 7.5
8. The AMP must describe the basis on which the target level for each performance indicator was determined. Justification for target levels of service includes consumer expectations or demands, legislative, regulatory, and other stakeholders' requirements or considerations. The AMP should demonstrate how stakeholder needs were ascertained and translated into service level targets.	3.6 & 5
9. Targets should be compared to historic values where available to provide context and scale to the reader.	6
10. Where forecast expenditure is expected to materially affect performance against a target defined in clause 5 above, the target should be consistent with the expected change in the level of performance.	1 & 6
<u>Network Development Planning</u>	
11. AMPs must provide a detailed description of network development plans, including— 11.1 A description of the planning criteria and assumptions for network development;	8.1
11.2 Planning criteria for network developments should be described logically and succinctly. Where probabilistic or scenario-based planning techniques are used, this should be indicated and the methodology briefly described;	8
11.3 A description of strategies or processes (if any) used by the EDB that promote cost efficiency including through the use of standardised assets and designs;	672 & 8.1.6
11.4 The use of standardised designs may lead to improved cost efficiencies. This section should discuss- 11.4.1 the categories of assets and designs that are standardised; 11.4.2 the approach used to identify standard designs.	7.2 & 8.1.6 7.2 & 8.1.6
11.5 A description of strategies or processes (if any) used by the EDB that promote the energy efficient operation of the network .	8.1.7
11.6 A description of the criteria used to determine the capacity of equipment for different types of assets or different parts of the network .	8.1.10
11.7 A description of the process and criteria used to prioritise network development projects and how these processes and criteria align with the overall corporate goals and vision.	4.2 & 8.3

Information Disclosure Requirements 2012 clause	AMP section
<p>11.8 Details of demand forecasts, the basis on which they are derived, and the specific network locations where constraints are expected due to forecast increases in demand;</p> <p>11.8.1 explain the load forecasting methodology and indicate all the factors used in preparing the load estimates;</p> <p>11.8.2 provide separate forecasts to at least the zone substation level covering at least a minimum five year forecast period. Discuss how uncertain but substantial individual projects/developments that affect load are taken into account in the forecasts, making clear the extent to which these uncertain increases in demand are reflected in the forecasts;</p> <p>11.8.3 identify any network or equipment constraints that may arise due to the anticipated growth in demand during the AMP planning period; and</p> <p>11.8.4 discuss the impact on the load forecasts of any anticipated levels of distributed generation in a network, and the projected impact of any demand management initiatives.</p>	4.2 & 8.3
<p>11.9 Analysis of the significant network level development options identified and details of the decisions made to satisfy and meet target levels of service, including-</p> <p>11.9.1 the reasons for choosing a selected option for projects where decisions have been made;</p> <p>11.9.2 the alternative options considered for projects that are planned to start in the next five years and the potential for non-network solutions described;</p> <p>11.9.3 consideration of planned innovations that improve efficiencies within the network, such as improved utilisation, extended asset lives, and deferred investment.</p>	8.2 8.2.78.4 – 8.6 9.1.3 - 9.1.5
<p>11.10 A description and identification of the network development programme including distributed generation and non-network solutions and actions to be taken, including associated expenditure projections. The network development plan must include-</p> <p>11.10.1 a detailed description of the material projects and a summary description of the non-material projects currently underway or planned to start within the next 12 months;</p> <p>11.10.2 a summary description of the programmes and projects planned for the following four years (where known); and</p> <p>11.10.3 an overview of the material projects being considered for the remainder of the AMP planning period.</p>	8.4 – 8.6 7 & 8
<p>11.11 A description of the EDB's policies on distributed generation, including the policies for connecting distributed generation. The impact of such generation on network development plans must also be stated.</p>	8.1.9

Information Disclosure Requirements 2012 clause	AMP section
<p>11.12 A description of the EDB's policies on non-network solutions, including-</p> <p>11.12.1 economically feasible and practical alternatives to conventional network augmentation. These are typically approaches that would reduce network demand and/or improve asset utilisation; and</p> <p>11.12.2 the potential for non-network solutions to address network problems or constraints.</p>	<p>8.1.8</p> <p>8.4.3.1 & 8.5.3.1</p>
<p><u>Lifecycle Asset Management Planning (Maintenance and Renewal)</u></p> <p>12. The AMP must provide a detailed description of the lifecycle asset management processes, including—</p> <p>12.1 The key drivers for maintenance planning and assumptions;</p> <p>12.2 Identification of routine and corrective maintenance and inspection policies and programmes and actions to be taken for each asset category, including associated expenditure projections. This must include-</p> <p>12.2.1 the approach to inspecting and maintaining each category of assets, including a description of the types of inspections, tests and condition monitoring carried out and the intervals at which this is done;</p> <p>12.2.2 any systemic problems identified with any particular asset types and the proposed actions to address these problems; and</p> <p>12.2.3 budgets for maintenance activities broken down by asset category for the AMP planning period.</p>	<p>7.2 & 7.3</p> <p>7.4</p> <p>7.5</p> <p>7.5</p> <p>7.6</p>
<p>12.3 Identification of asset replacement and renewal policies and programmes and actions to be taken for each asset category, including associated expenditure projections. This must include-</p> <p>12.3.1 the processes used to decide when and whether an asset is replaced or refurbished, including a description of the factors on which decisions are based, and consideration of future demands on the network and the optimum use of existing network assets;</p> <p>12.3.2 a description of innovations made that have deferred asset replacement;</p> <p>12.3.3 a description of the projects currently underway or planned for the next 12 months;</p> <p>12.3.4 a summary of the projects planned for the following four years (where known); and</p> <p>12.3.5 an overview of other work being considered for the remainder of the AMP planning period.</p> <p>12.4 The asset categories discussed in subclauses 12.2 and 12.3 above should include at least the categories in subclause 4.5 above.</p>	<p>7.2 – 7.4</p> <p>7.5</p> <p>7.6</p> <p>7.6</p> <p>7.5 – 7.6</p> <p>Yes</p>

Information Disclosure Requirements 2012 clause	AMP section
<p><u>Non-Network Development, Maintenance and Renewal</u></p> <p>13. AMPs must provide a summary description of material non-network development, maintenance and renewal plans, including—</p> <p>13.1 a description of non-network assets;</p> <p>13.2 development, maintenance and renewal policies that cover them;</p> <p>13.3 a description of material capital expenditure projects (where known) planned for the next five years;</p> <p>13.4 a description of material maintenance and renewal projects (where known) planned for the next five years.</p>	<p>10.1</p> <p>10.2 & 10.3</p> <p>10.4</p> <p>10.7</p>
<p>14. AMPs must provide details of risk policies, assessment, and mitigation, including—</p> <p>14.1 Methods, details and conclusions of risk analysis;</p> <p>14.2 Strategies used to identify areas of the network that are vulnerable to high impact low probability events and a description of the resilience of the network and asset management systems to such events;</p> <p>14.3 A description of the policies to mitigate or manage the risks of events identified in sub clause 14.2;</p> <p>14.4 Details of emergency response and contingency plans.</p>	<p>4.7</p> <p>11</p> <p>4.7.3</p> <p>11.4</p>
<p>15. AMPs must provide details of performance measurement, evaluation, and improvement, including—</p> <p>15.1 A review of progress against plan, both physical and financial;</p>	<p>Appendix B</p>
<p>15.2 An evaluation and comparison of actual service level performance against targeted performance;</p>	<p>5</p>
<p>15.3 An evaluation and comparison of the results of the asset management maturity assessment disclosed in the Report on Asset Management Maturity set out in Schedule 13 against relevant objectives of the EDB’s asset management and planning processes.</p>	<p>4.5</p>
<p>15.4 An analysis of gaps identified in subclauses 15.2 and 15.3 above. Where significant gaps exist (not caused by one-off factors), the AMP must describe any planned initiatives to address the situation.</p>	<p>4.5</p>
<p><u>Capability to deliver</u></p> <p>16. AMPs must describe the processes used by the EDB to ensure that-</p> <p>16.1 The AMP is realistic and the objectives set out in the plan can be achieved;</p> <p>16.2 The organisation structure and the processes for authorisation and business capabilities will support the implementation of the AMP plans.</p>	<p>1.7</p> <p>3.2</p>

Appendix E Glossary of Abbreviations

AAC	All Aluminium Conductor
AAAC	All Aluminium Alloy Conductor
ABS	Air Break Switch
ACSR	Aluminium Conductor Steel Reinforced
ADMS	Advanced Distribution Management System
ADSS	All Dielectric Self Supporting
ACI	Asset Criticality Indicator
AHI	Asset Health Indicator
AMI	Advanced Metering Infrastructure
ANM	Advanced Network Management
BAU	Business as Usual
BRMP	Business Recovery Management Plan
Capex	Capital Expenditure
CB	Circuit Breaker
CBD	Central Business District
CCT	Covered Conductor Thick
CDEMA	Civil Defence and Emergency Management Amendment Act (2016)
CEO	Chief Executive Officer
CIC	Capital Investment Committee
CKI	CK Infrastructure Holdings Limited
CMP	Crisis Management Plan
CPI	Consumer Price Index
CPP	Customised Price Path
CPRG	Constant Price Revenue Growth
CT	Current Transformer
Cu	Copper
DC	Direct Current
DER	Distributed Energy Resources
DG	Distributed Generation
DGA	Dissolved Gas Analysis



DMS	Distribution Management System
DP	Degree of Polymerisation
DPP	Default Price-quality Path
DR	Demand Response
DSA	Detailed Seismic Assessment
DSO	Distribution System Operator
DTS	Distributed Temperature Sensing
EDB	Electricity Distribution Business
EDO	Expulsion Drop-out Fuse
EEA	Electricity Engineers Association
EECA	Energy Efficiency and Conservation Authority
EEP	Emergency Evacuation Plan
EIPC	Electricity Industry Participation Code
EMS	Energy Management System
ENA	Electricity Network Association
ENMAC	Electricity Network Management and Control
ERP	Emergency Response Plan
ETR	Estimated Time of Restoration
EV	Electric Vehicle
FDIR	Fault Detection, Isolation and Restoration
FPI	Fault Passage Indicators
GWh	Gigawatt Hour
GIS	Geographical Information System
GXP	Grid Exit Point
HCC	Hutt City Council
HILP	High Impact Low Probability
HLR	High Level Request/Response
HSE	Health, Safety and Environmental
HSW	Health and Safety Work Act (2015)
HV	High Voltage
ICP	Installation Control Point
IEEE	Institute of Electrical and Electronic Engineers

IISC	International Infrastructure Services Company (NZ Branch)
IEP	Initial Evaluation Procedure of Seismic Assessment
ISO	International Standards Organisation
IoT	Internet of Things
IIoT	Industrial Internet of Things
IT	Information Technology
ITRP	Information Technology Recovery Plan
km	Kilometre
KPI	Key Performance Indicator
kV	Kilovolt
kVA	Kilovolt Ampere
kW	Kilowatt
kWh	Kilowatt hour
LED	Light Emitting Diode
LTI	Lost time injury
LTIFR	Lost time injuries per 1,000,000 hours worked
LV	Low Voltage
LVABC	Low Voltage Aerial Bundled Conductor
MAR	Maximum Allowable Revenue
MBIE	Ministry of Business Innovation and Employment
MEMP	Major Event Management Plan
MEFRP	Major Event Field Response Plan
MUoSA	Model Use of System Agreement
MW	Megawatt
MWFM	Mobile Workforce Management
MVA	Megavolt Ampere
NBS	New Building Standard
NCR	Network Control Room
NDP	Network Development Plan
NICAD	Nickel Cadmium Battery
NIWA	National Institute of Water and Atmospheric Research
NPV	Net Present Value



NZTA	New Zealand Transport Agency
OCB	Oil Circuit Breaker
OD-ID	Outdoor to Indoor conversion
ODV	Optimised Deprival Value/Valuation
O&M	Operating and Maintenance
OLTC	On Load Tap Changer
OMS	Outage Management System
Opex	Operational Expenditure
OT	Operational Technology
PAHL	Power Asset Holdings Limited
PCC	Porirua City Council
PCS	Power Control System
PDC	Polarisation Depolarisation Current
PIAS	Paper Insulated Aluminium Sheath Cable
PILC	Paper Insulated Lead Cable
PLC	Programmable Logic Controller
PM	Preventative Maintenance
PV	Photovoltaic Generation
PVC	Polyvinyl Chloride
RMU	Ring Main Unit
RTU	Remote Terminal Unit
RY	Regulatory Year (1 April – 31 March)
SAIDI	System Average Interruption Duration Index
SAIFI	System Average Interruption Frequency Index
SAP	Systems Applications and Processes
SCADA	Supervisory Control and Data Acquisition System
SCPP	Streamlined Customised Price Path
SF ₆	Sulphur Hexafluoride
SPS	Special Protection Scheme
TASA	Tap Changer Activity Signature Analysis
TCA	Transformer Condition Assessment
TNIFR	Total notifiable injuries per 1,000,000 hours worked

UFB	Ultrafast Broadband
URM	Unreinforced Masonry
UHCC	Upper Hutt City Council
VRLA	Valve Regulated Lead Acid Battery
VT	Voltage Transformer
WCC	Wellington City Council
WELL	WELL Lines Limited
WeLG	Wellington Lifelines Group
WOM	Work Order Management
W/S	Winter / Summer
XLPE	Cross Linked Polyethylene insulation



Appendix F Single Line Diagram

